

U1B #1 Fan Bandytown
Started 3-9-10

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Company Performance Coal
Mine U1B
Location Naoma Rateigh W.V.
Post Office County State

Reorder from
Chapman Printing
(800) 999-2471
Form # MS-021

Form 6-1491
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. **Do not** mail this book to the Bureau of Mines.

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-9-10

Time 9:30 AM

Fan UBB # 1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.8"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes Greased Fan

Signed Al Farley
(examiner) 4-431

T. Moore
Mine Foreman Mine Manager

3339
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-10-10

Time 10:30 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.6"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes

Signed C. H. Family
(examiner)
4-431

T. M. ...
Mine Foreman Mine Manager

33359
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-11-10

Time 1:30 PM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.5'

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes _____

Signed Ch. Farley
(examiner)
4-431

T. Moore
Mine Foreman Mine Manager

33359
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/12/10

Time _____

Fan UBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 5"

Fan Signal Check (monthly) OK ON 2/21/10

Previous Check Made 1/17/10

Automatic Closing Doors (monthly) 2/21/10

Previous Examination Made 1/17/10

Remarks or changes Greased Fan + motor ~~C#~~

Signed Paul [Signature]
(examiner)

8-4031

T. Moore
Mine Foreman Mine Manager

33359
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/13/10

Time 1:45 AM

Fan UBB #1 fan

Location Randy Town

Fan Operating Properly yes

Water Gage Pressure 4.7"

Fan Signal Check (monthly) 2/21/10

Previous Check Made 1/17/10

Automatic Closing Doors (monthly) 2/21/10

Previous Examination Made 1/17/10

Remarks or changes Fan alarm check

Called in By Paul Thomson
Signed Andrew Jones 4701
(examiner)

T. Moore
Mine Foreman Mine Manager

33354
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/14/10

Time 9:30AM

Fan MBB #1 FAN

Location BANDTOWN

Fan Operating Properly YES

Water Gage Pressure 4.7"

Fan Signal Check (monthly) OK ON 3/13/10

Previous Check Made 2/27/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/21/10

Remarks or changes Compressor off started up running @ 12:00 PM
EMVRO crew filled up comp. with fuel @ 9:00 AM

Signed Paul Hyman 8-4031
(examiner)

T. Moore
Mine Foreman Mine Manager

3339
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-15-10

Time 4:30 Pm

Fan UBB #1 Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 5.2"

Fan Signal Check (monthly) OK on 3/13/10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes

Signed [Signature] (examiner) 4431

[Signature] Mine Foreman Mine Manager

33353 Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-16-10
Time 11:30 Am

Fan UBB #1 Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes Creased Fan

Signed Albert Foulk
(examiner) 4-431

T. Moore
Mine Foreman Mine Manager

33359
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-17-10

Time 1:30 PM

Fan U/BB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.0"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes Changed Fuel Filters on Compressor

Signed Ch Farley
(examiner)
4-431

T. J. Moore
Mine Foreman Mine Manager

33389
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-18-10

Time 11:30 AM

Fan UBB #1 Fan

Location Bardytown

Fan Operating Properly Yes

Water Gage Pressure 4.9"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes

Signed Ch Family
(examiner)
4-431

T. Moore
Mine Foreman Mine Manager

35359
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-19-10
Time 10:30 Am

Fan UBB #1 Fan

Location Bandy low

Fan Operating Properly Yes

Water Gage Pressure 4.9"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes Overhaul Fan

Signed Oh Family
(examiner) 4-431

T. Moore
Mine Foreman Mine Manager

33357
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-20-10
Time 1:00 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.9"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes _____

Signed Ch. Family
(examiner)
4431

T. Moore
Mine Foreman Mine Manager

33357
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-21-10

Time 9:30 AM

Fan LIBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.9"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes _____

Signed Cole Faulk
(examiner) 4-431

T. M. Moore
Mine Foreman Mine Manager

33259
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-22-10
Time 9:30 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes

Signed Ch. Taylor
(examiner) 4-1031

T. Moore
Mine Foreman Mine Manager

33389
Certificate Number

[Signature]
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/23/10

Time 5:10 pm

Fan UBB #1 FAN

Location BAWDY TOWN

Fan Operating Properly YES

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3/13/10

Previous Check Made 2/21/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/6/10

Remarks or changes Increased FAN

Signed Paul [Signature]
examiner 8403

T. Moore
Mine Foreman Mine Manager

33759
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-24-10

Time 10:38

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes

Signed Ch Farley
(examiner) 4-431

T. Moore
Mine Foreman Mine Manager

33389
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-25-18

Time 11:30 Am

Fan YBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.2"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made _____

Remarks or changes _____

Signed Ch. Fink
(examiner) 4-431

T. Moore
Mine Foreman Mine Manager

33589
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/26/10

Time 11:00pm

Fan WBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3/13/10

Previous Check Made 2/21/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/21/10

Remarks or changes NONE

greased FAN

Signed Paul Hyman
(Examiner)
8-4031

T. Moore
Mine Foreman Mine Manager

33389
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/27/10

Time 4:25 pm

Fan 4BB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3/13/10

Previous Check Made 2/20/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/20/10

Remarks or changes N/A

COMPRESSOR OUT OF FUEL DOWN.

Filled up, Running now.

Signed Paul Skyr
(example)
8-4031

T. M. ...
Mine Foreman Mine Manager

33357
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/28/10

Time 5:30 AM

Fan 5BB #1

Location BANDYTOWN

Fan Operating Properly yes

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3/31/10

Previous Check Made 2/21/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/21/10

Remarks or changes NONE

Signed Paul Thym
(examiner) 8-4031

T. Moore
Mine Foreman Mine Manager

3339
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/29/10

Time 3:15 PM

Fan U1BB #1

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 3/13/10

Previous Check Made 2/21/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/21/10

Remarks or changes COMPRESSOR DOWN. OUT OF FUEL

Filled up Running now.

Signed Paul Thym
(examiner) 8-4031

T. Moore
Mine Foreman Mine Manager

33359
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3/30/10

Time 1:36 pm

Fan UBB #1

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 3/13/10

Previous Check Made 2/21/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/21/10

Remarks or changes NONE

Signed Paul Myers
(examiner) 8-4031

T. Moore
Mine Foreman Mine Manager

35359
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-31-10

Time 11:30 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes _____

Signed Al Farley
(examiner) 4431

T. Moore
Mine Foreman Mine Manager

33389
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 4/1/10

Time 1:30 pm

Fan U.B.B #1

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3/13/10

Previous Check Made 2/21/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/21/10

Remarks or changes Greased FAN
calibrate chart

Signed Paul Symm
(examiner) 804031

Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 4-2-10

Time 9:30 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.1 "

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes

Signed Cal Farley
(examiner) 4-431

Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 4/3/10

Time 1:30 AM

Fan UBB#1

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3/13/10

Previous Check Made 2/21/10

Automatic Closing Doors (monthly) 3/13/10

Previous Examination Made 2/21/10

Remarks or changes - ELECTRIC COMPRESSOR BIT THE DUST,

MACHINE IS DOWN. Logan Corp will FIX SAT. EVE

- Diesel unit DOWN ALSO, RPL Fuel Filters (DOWN ABOUT 30 MIN.)

+ Filled with Fuel RUNNING OK NOW @ 115 PSI / 1700 CFM

- Diesel Compressor Running OK 9:00 AM Ah-Fully
+ Filled Fuel

Signed Paul Meyer
(examiner) 8-4031

Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 4-4-10

Time 12:30 AM

Fan UBB #1

Location BANDY TOWN

Fan Operating Properly yes

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes

Signed called in by Paul Thomas
(examiner)

Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 4-5-10

Time 7:30 AM

Fan UBB # 1

Location BANDY TOWN

Fan Operating Properly yes

Water Gage Pressure 5.1"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes

Signed called in by Phil Jones
(examiner)

Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 4-6-10

Time 8:15 Am

Fan USB #1 Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 2.8"

Fan Signal Check (monthly) 3-13-10

Previous Check Made 2-21-10

Automatic Closing Doors (monthly) 3-13-10

Previous Examination Made 2-21-10

Remarks or changes Changed Chart MSHA inspector Present

Signed Ch. Fuchs
(examiner)
4-431

Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant