

OUT - BY

10.
2-4
25 C. Reef
25

EXAMINATION OF ELECTRICAL EQUIPMENT



Company Performance
Mine L-wall (out By)
Location UPB Raleigh NC
Post Office County State

Re-order from
**BJW Printing and
Office Supplies**
P. O. Box 1309
Beckley, W. Va. 25801
Phone (304) 253-7361

Form 6—1492
(March 1970)


Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. This book is approved by the Director of The West Virginia Department of Mines and The U. S. Bureau of Mines.

9


EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-10-09	Out By	Mother Drive	None obs	None	
		Trippac Drive	None obs	None	
		Splitter Box	None obs	None	

Weekly tests of grounding devices (diodes)

SET Fire Suppression OFF was good at mother Drive + Trippac Drive
 Also tested slip for mother Drive OK



Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
------	----------	----------------------------------	----------------------	--------------	----------

Examinations of low- medium-voltage power circuit breakers (monthly)

9-10-09	Tripper Drive	Checked Breakers and Ground monitors 1 Breaker wouldn't set up. corrected			
		Checked ground Resistor	OK		

Nancy Lane DR-2882

	Mother Drive	Checked Breakers and Ground f/f. with Test Buttons Tested Ground monitors	OK		
--	--------------	--	----	--	--

DL

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-14-09	1012	HAULER	out of Service	Damaged off	R Hale
3-350	1027 R1	630-2 HAULER	out of Service	Broke Frame	R Hale
9-15-09	35C Scoop T 339-136-R	replaced flat washers in Breaker Panel + Side Panel repaired Battery lead on Breaker Panel, replaced rear offside light bulb Battery lids not secured. (Corrected all)			Robert Hale

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-17-09	Mother Drive	Gauge Brake		Corrected	RH
	Mother Drive Power center		Bolts out of lids	Corrected	RH
	CTW		None observed at time of Exam		RH
	Tripper Drive		Gauge Brake	Corrected	RH
	Tripper Power center		Mat missing at blade switch	Corrected	RH
	Spitter Box		None observed at time of Exam		RH
Set fire Supp off on Mother Dr + Tripper, Both worked at Time of Exam					RH

Robert
R. Hale
3-350

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-24-09	outby	Mother Drive	Strings on water sprays	Corrected	Robert Hale
		M/D Power center	None observed at time of Exam	None	Robert Hale
		CTW	None observed at time of Exam	None	Robert Hale
		Pinch roller	None observed at time of Exam	None	Robert Hale
		Tripper Drive	Strings on water sprays + Cathheads labeled wrong	Corrected	Robert Hale
		Tripper Power Center	Cathheads labeled wrong	Corrected	Robert Hale
		Splitter Box	None observed at time of Exam	None	Robert Hale
		Set Fire Supp	off at M/Drive + Tripper time of Exam	both worked at	Robert Hale
		<u>Weekly tests of grounding devices (diodes)</u>			

Robert Hale
3350

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-30-09	outby Tripper	Trickle Duster	None observed		A. Kavanagh NR 2882
10-1-09	outby	M/Drive	Strings on water Sprays	Corrected	Robert Hale
		M/D Power center	None observed at time of Exam	None	Robert Hale
		CTW	None observed at time of Exam	None	Robert Hale
		Pinch Roller	None observed at time of Exam	None	Robert Hale
		Tripper Drive	Strings on water Sprays	Corrected	Robert Hale
		Tripper Power center	Accum of Dust	Corrected	Robert Hale

Robert Hale
3-350

Weekly tests of grounding devices (diodes)

Splitter Box	None observed at time of Exam	None	Robert Hale
Set fire Supp off At M/D + Tripper			
Both worked at Time of Exam			Robert Hale

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-8-09	outby	M/Drive	Strings on Sprays	Corrected	Robert Hale
		M/D Power Center	None observed at time of Exam	None	Robert Hale
		CTW	None observed at time of Exam	None	Robert Hale
		Pinch Rollers	None observed at time of Exam	None	Robert Hale
		Tripper Drive	Strings on Sprays	Corrected	Robert Hale
		Tripper Power Center	None observed at time of Exam	None	Robert Hale
		Splitter Box	Accum of Dust	Corrected	Robert Hale
		Set Fire Supp off at M/D & Tripper		Both worked at	Robert Hale
		Time of Exam			

3-350
Robert Hale

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
------	----------	----------------------------------	----------------------	--------------	----------

Examinations of low- medium-voltage power circuit breakers (monthly)

10.15.09	Tipper Drive	Tested Ground Fault and monitors	OK	DL NR2882	
----------	--------------	----------------------------------	----	-----------	--

T. Moore 33359

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-15-09	LD on the	Motter Drive	Fire snuff sprang grabbed out	cleaned	Sham Ock 8-11
		Power Center	Dusty	cleaned	Sham Ock 8-11
		CTW	Fire snuff sprang grabbed off	cleaned	Sham Ock 8-11
		Pinch Roller	None Observed	None	Sham Ock 8-11
		Tripper Drive	None Observed	None	Sham Ock 8-11
		Starter Box	None Observed	None	Sham Ock 8-11
		Motter Drive Starter	None Observed	None	Sham Ock 8-11

Weekly tests of grounding devices (diodes)

10-15-09	SCOOP	Batter Lids not seen	secured	Sham Ock 3-466
	SCOOP Charger	None obs	None	Sham Ock 3-466
	1012 Hailer	Breaker Reset cable not hooked up	hooked up	Sham Ock 3-466
	Hailer Charger	None obs	None	Sham Ock 3-466

Monthly examinations of methane monitors

Tested Motter Drive, CTW, and Tripper Fire Suppression.
All are O.K.

Sham Ock 8-11
10-15-09

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-22-09	LW Outby	Mothor Drive	Dirty Sprays	Cleaned Sprays	Shane Cook 8-17
		Starters	None Observed	None	Shane Cook 8-17
		Power Centers	None Observed	None	Shane Cook 8-17
		CTW	Dirty Sprays	Cleaned Sprays	Shane Cook
		Pinch Rollers	None Observed	None	Shane Cook 8-17
		Tripper Drive	None Observed	None	Shane Cook
		Starters	None Observed	None	Shane Cook 8-17

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-25-09	Longwall-outhby	D-Box on main rail	None observed at time of Exam	R.H.	10
		D-Box AT End of Track	None observed at time of Exam	R.H.	
		2/wall Starter Box	None observed at time of Exam	R.H.	
		4/wall Power Center	None observed at time of Exam	R.H.	
		51BK Splitter Box	None observed at time of Exam	R.H.	
		Tripper Power Center	None observed at time of Exam	R.H.	
E-Stop circuit worked on All Boxes, #1 #2 #3 Phase Test + ground Test					
All OK OK on 51BK Splitter Box. Robert Hale 3-350					

Examinations of low- medium-voltage power circuit breakers (monthly)

T. Moore 33359

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Item	Examiner	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken
Exam	RH	10-29-07	LWentby	Mother Drive	Dirty Sprays	Corrected
Exam	RH			Starter	No Obs	No
Exam	RH			Power Center	No Obs	No
Exam	RH			CTU	Dirty Sprays	Corrected
Exam	RH			Pinch Roller	No Obs	No
Exam	RH			Tripper Drive	Dirty Sprays	Corrected
Exam	RH			Starter	No Obs	No
ground Test						

Weekly tests of grounding devices (diodes)

Tested CTU, Tripper, and meth Drive Line Sigs,
all O.K.

[Signature]

10-29-07

Monthly examinations of methane monitors

T. Moore 33359

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-29-07	L. W. Hartley	Mother Drive	Dirty Sprays	Corrected	S. J. [Signature] 8-17
		Starter	Nac Obend	None	
		Power Center	Nac Obend	None	
		CTW	Dirty Sprays	Corrected	
		Pinch Roller	Nac Obend	None	
		Tripper Drive	Dirty Sprays	Corrected	
		Starter	Nac Obend	None	

Weekly tests of grounding devices (diodes)

Tested CTW, Tripper, and Mother Drive Line equipment
 All O.K.
 S. J. [Signature] 8-17
 10-29-07

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-29-09	LW outby	scoop	none observed	none	4-675 Michael Medley
10-29-09	LW outby	scoop charger	none observed	none	4-675 Michael Medley
10-29-09	LW outby	hauler charger	none observed	none	4-675 Michael Medley
10-29-09	LW outby	hauler	none observed	none	4-675 Michael Medley
10-29-09	LW outby	D-Box on monorail	none observed	none	4-675 Michael Medley
10-29-09	LW outby	gate box	none observed	none	4-675 Michael Medley

~~scribble~~

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

Ti Moore 33359

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-5-09	LW	CTW	Dirty deluge spray	Cleaned	Shanley 8-07
		Mother Drive	"	"	" "
		Starter for Tripper	None Obs	None	Shanley 8-07
		Starter for Mother Drive	None Obs	None	Shanley 8-07
		Splitter	None Obs	None	Shanley
		Power Centre	None Obs	None	Shanley

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

T. Moore 33357

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-12-09	outby	Mother Drive	belt strings on several sprogs	Corrected	Chadfeip 3-35
11-12-09	outby	Starter	none observed	none	Chadfeip 3-35
11-12-09	outby	Power Center	none observed	none	Chadfeip 3-35
11-12-09	outby	CTW	belt strings on several sprogs	Corrected	Chadfeip 3-35
11-12-09	outby	Pinch Roller	none observed	none	Chadfeip 3-35
11-12-09	outby	Tripper Drive	belt strings on several sprogs	Corrected	Chadfeip 3-35
11-12-09	outby	Starter	none observed	none	Chadfeip 3-35
11-12-09	outby	Powercenter	top of box dusty	Corrected	Chadfeip 3-35

~~Weekly tests of grounding devices (diodes)~~

11-12-09 outby Tested CTW, Mother Drive & Tripper fine suppression, all checks were OK — Chadfeip 3-35

Monthly examinations of methane monitors

T. Johnson 33359

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-19-09	Outby	Tripper Drive, Starter and Power center were removed	from service - will no longer be carried in book - Chad Feif 3-35		
11-19-09	Outby	Mother Drive	belt straps on several sprogs	Corrected	Chad Feif 3-35
11-19-09	Outby	Starter	none observed	none	Chad Feif 3-35
11-19-09	Outby	CTW	none observed	none	Chad Feif 3-35
11-19-09	Outby	Pinch Roller	none observed	none	Chad Feif 3-35
11-19-09	Outby	Power center	none observed	none	Chad Feif 3-35

~~Weekly tests of grounding devices (diodes)~~

11-19-09 Tested Mother Drive, CTW fire suppression, all checks were OK - Chad Feif 3-35

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-28-09	outby	Mother Drive	removed ^{Belt} strings off of Sprays	corrected	Robert Hale
"	"	Starter	none observed at time of Exam	None	Robert Hale
"	"	CTW	none observed at time of Exam	None	Robert Hale
"	"	Pinch Roller	none observed at time of Exam	None	Robert Hale
"	"	Power Center	none observed at time of Exam	None	Robert Hale
11-28-09	Tested Mother Drive & CTW Fine Suppression on				
	all checks OK	cut strings ^{Belt} off All sprays			Robert Hale 3-350

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

T. Moore 33359

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

sr	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	12-3-09	Outby	Mother Drive	none observed	none	Chad Feil 3-35
	12-3-09	Outby	Starters	none observed	none	Chad Feil 3-35
	12-3-09	Outby	CTW	none observed	none	Chad Feil 3-35
	12-3-09	Outby	Pinch Roller	none observed	none	Chad Feil 3-35
	12-3-09	Outby	Powercenter	none observed	none	Chad Feil 3-35

12-3-09 Tested Mother Drive & CTW fire suppression — all checks were
OK as done at exam — Chad Feil 3-35

T. Moore 33309

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-18-09	outby	Mother Drive	None observed at time of Exam	None	Robert Hale
"	"	Starter	None observed at time of Exam	None	Robert Hale
"	"	CTW	None observed at time of Exam	None	Robert Hale
"	"	Pinch Roller	None observed at time of Exam	None	Robert Hale
"	"	Power center	None observed at time of Exam	None	Robert Hale
"	"				3-350
"	"	Tested M/O + CTW Fire Suppression - All checks were OK At Time of Exam			Robert Hale 3-350 (Cut String off Sprays)

Weekly tests of grounding devices (diodes)

12-10-09	90 Brk	# 1 LW well water pump	New installation	none observed	D. Kapets
12-10-09	42 Brk on Ellis	# 2 LW well water Pump	New installation	none observed	D. Kapets NR-2882 T. Moore 3-3359

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-17-09		Mother Drive	Spray Dirty	Clean	Shan Olin 8-17
		Starter	None Observed	None	Shan Olin 8-17
		Splitter	None Observed	None	Shan Olin 8-17
		C.T.W	Spray Dirty	Clean	Shan Olin 8-17
		Pinch Roller	None Observed	None	Shan Olin 8-17
12-17-09	90 Brk.	Well Water Pump	None Observed	-	P. Laverty
12-17-09	42 Brk.	Well Water Pump	None Observed	-	P. Laverty NR-2882

Weekly tests of grounding devices (diodes)

12-22-09	L/W	1010 hauler put back in Service	opening in control panel & Breaker panel	corrected corrected	
			Light at deck damaged (Oil & dust accumulation) in process of cleaning	ordered light Tagged out Bulb out	
12-22-09	L/W	1012 hauler	Need Lead Seal & light Tree repaired	Tagged out	Bulb out
12-22-09	L/W	Double Head bolter	Spot Light on ATRs missing	out of Service ordered light	Bulb out Bulb out
12-22-09	L/W	Track bolter	None Observed	bolter not in use out of Service	Bulb out Bulb out

Monthly examinations of methane monitors

12-22-09	L/W	fork lift & charger at supply hole		out of Service Not being used	Bulb out Bulb out
----------	-----	------------------------------------	--	----------------------------------	----------------------

T. Moore 33353

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-26-09		Mother Drive	None Observed	None	[Signature] 8-17
		Splitter	None Observed	None	[Signature] 8-21
		CTW	None Observed	None	Felton Gray 3-549
		Starter	None Observed	None	[Signature] 8-17
		Pinch Roller	None Observed	None	[Signature] 8-17

Weekly tests of grounding devices (diodes)

12-24-09		90-Break only Ellis Well Water Pump	None Observed		[Signature]
" " "		42 Break indy Ellis Well Water Pump	None Observed		[Signature] NR-2882
					T. Moore 33309

Monthly examinations of methane monitors

350

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Examiner	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	12-31-09	Outby	Mother Drive	Strings on fire sprays	corrected	Chad Lip 3-35
	12-31-09	Outby	Starter	none observed	none	Chad Lip 3-35
	12-31-09	Outby	Power center	none observed	none	Chad Lip 3-35
	12-31-09	Outby	CTW	none observed	none	Chad Lip 3-35
	12-31-09	Outby	Pinch roller Starter	none observed	none	Chad Lip 3-35
<p>12-31-09 Tested Mother Drive & CTW fire suppression - all checks were OK at time of exam - Chad Lip 3-35</p>						
Weekly tests of grounding devices (diodes)						
	12-31-09	90 Brk outby Ellis	#1 Well Water Pump	None observed		A. Harvey
	12-31-09	42 Brk inby Ellis	#2 Well Water Pump	" "		D. Tomlin IR-2802 T. Moore 3335-9

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Examiner	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	1-7-10	Outby	Mother Drive	strings on fire sprays	corrected	Chadler 3-35
	1-7-10	Outby	Starters	none observed	none	Chadler 3-35
	1-7-10	Outby	Powercenter	none observed	none	Chadler 3-35
	1-7-10	Outby	CTW	none observed	none	Chadler 3-35
	1-7-10	Outby	Pinch Roller Starter	none observed	none	Chadler 3-35

1-7-10 Tested Mother Drive + CTW line suppression — all checks were
OK at time of exam — Chadler 3-35

Trey Moore 33359

Weekly tests of grounding devices (diodes)

01-07-10 90Bk #1 Well water pump none observed
01-07-10 42Bk Inby Ellis #2 well water pump none observed

D. Harvey
R. Zarecky NR-2882

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

iner	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	1-14-10	Outby	Mother Drive	strings on fire sprays	Connected	Chad Feip 3-35
	1-14-10	Outby	starter	none observed	none	Chad Feip 3-35
	1-14-10	Outby	Power center	none observed	none	Chad Feip 3-35
	1-14-10	Outby	CTW	none observed	none	Chad Feip 3-35
	1-14-10	Outby	Pineh Roller Starter	none observed	none	Chad Feip 3-35

1-14-10 Tested Mother Drive CTW fire suppression — all checks were OK at time of exam — Chad Feip 3-35

Weekly tests of grounding devices (diodes)

1-14-10	Tested All Test Buttons on All Breakers on M/D Power center				Robert Hale 3-350
	All checks were OK at Time of Exam				
01-14-10	#40 Brk #1 well water pump		None observed	—	D. Henry NR 2882
01-14-10	90 Brk in by Ellis #2 well water pump		None observed	—	D. Henry NR 2882

Monthly examinations of methane monitors

T. Moore 33389

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-21-10	Outby	Mother Drive	String on fire sprays	corrected	Robert Hale 3:350
		Starter	None observed at time of Exam	None	Robert Hale
		Power Center	None observed at time of Exam	None	Robert Hale
		CTW	Hydro leak on winch Motor	Corrected	Robert Hale
		Pinch roller	None observed at time of Exam	None	Robert Hale
1-21-10		Tested M/O + CTW Fire Suppression - All checks OK			
		At Time of Exam	Robert Hale	3:350	

Weekly tests of grounding devices (diodes)

1-22-10	Outby Long Wall @ mouth	Fork lift	None Observed	None	Dullert Bailey
		Fork lift charger	None Observed	None	A Bailey
		Bacyrus hauler	None Observed	None out of service	D Bailey
		Ba hauler charger	out of service		D Bailey
01-24-10	#1 Well Water Pump		None observed	—	J. Zeng
01-24-10	#2 Well Water Pump		None observed	—	J. Zeng NR-2882

Monthly examinations of methane monitors

T. M. Moore 33359

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-29-10	LW	fork lift	None Observed		Gilbert Bailey
		fork lift charger	None Observed		Gilbert Bailey
		Bucyrus Hauler	out of service		Gilbert Bailey
		Hauler Charger	Out of service		Gilbert Bailey
		#1 well water pump	None Observed		Gilbert Bailey
		#2 well water pump	None Observed		Gilbert Bailey

Weekly tests of grounding devices (diodes)

2-5-10	LW	Wall Mt fork lift	None Observed	T. Moore 53389	Gilbert Bailey
		fork lift charger	None Observed		Gilbert Bailey
		#1 well water pump	None Observed		Gilbert Bailey
		#2 well water pump	None Observed		Gilbert Bailey

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

er	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	2-11-10	LW	1012 hauler	bolts out of light at canopy	corrected	Delbert B.
			1010 hauler	None Observed	None	Delbert Bailey
			hauler charger	None Observed	None	Delbert Bailey
			wall mount fork lift	None Observed	None	Delbert Bailey
			fork lift charger	None Observed	None	Delbert Bailey
			#1 well pump	None Observed	None	Delbert Bailey
			#2 well pump	None Observed	None	Delbert Bailey

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Number	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	2-18-10	LW	#1 Well water pump	None Observed	None	Duffin B
			#2 " " "	None Observed	None	Duffin B
			Wall Mart fork lift	None Observed	None	Duffin B
			Wall Mart Fork lift charger	None Observed	None	Duffin B

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

iner	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	2-25-10	LW	# 1 Well water pump	None Observed	None	J. [Signature]
			# 2 Well water pump	None Observed	"	J. [Signature]
			Wall Mart fork lift	None Observed	"	J. [Signature]
			Wall Mart fork lift charges	None Observed	"	J. [Signature]

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-4-10	L wall	#1 well water pump	None Observed	None	Delbert Bailey
		#2 well water pump	None Observed	"	Delbert Bailey
		w.m. Fork lift	None observed	"	Delbert Bailey
		w.m. Fork lift charger	None Observed	"	Delbert Bailey

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-11-10	Lites	#1 well pump	None Observed	None	Dellat Bailey
		#2 Well pump	None Observed	None	Dellat Bailey
		WM Fork lift	Start Switch Damaged	Tagged out	Dellat Bailey
		WM Fork lift charger	None Observed	None	Dellat Bailey

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

er	Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
	03-18-10	#2 Brk. In by Ellis	#2 well water Pump	None Observed	—	Jerry Lantz
	03-18-10	90 Brk out by Ellis	#1 well water Pump	None Observed	—	J. Lantz IUR-2882
	3-18-10	Wall Mart	fork lift	Out of Service Tagged out		Dellert Bailem
			fork lift charger	None Observed	None	Dellert Bailem

Weekly tests of grounding devices (diodes)

3-27	Wall Mart	fork lift	Damaged start switch	corrected	Dellert B.
		fork lift charger	None Observed	None	Dellert B.
	42 Brk in by Ellis	#2 well water pump	None Observed		Dellert B.
	90 Brk out by Ellis	#1 well water pump	None Observed		Dellert Bailem

Monthly examinations of methane monitors

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
4-1-10	Out by	Wall Mark fork lift	None Observed	None	D. J. Bailey
		Wall Mark fork lift charger	No. Just	Corrected	D. J. Bailey
		#1 well water pump	None Observed	None	D. J. Bailey
		#2 Well water pump	None Observed	None	D. J. Bailey

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors