

Eunice Portal

MAN Trip CHARGES

Started 1-25-10

**EXAMINATION OF
ELECTRICAL EQUIPMENT**

Company -----

Mine -----

Location -----

Post Office

County

State

Re-order from
BJW Printing and
Office Supplies
P. O. Box 1309
Beckley, W. Va. 25801

Phone (304) 253-7361

Form 6—1492
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. This book is approved by the Director of The West Virginia Department of Mines and The U. S. Bureau of Mines.

1
2
2
2
2
2
2
2

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-27-10	Evnice Portal	#1 charger	NONE Found		M Waddock 4-765
1-27-10	Evnice Portal	#2 charger	NONE Found		M Waddock 4-765
1-27-10	Evnice Portal	#3 ^{new} charger	nut missing	Repaired (corrected on 1-28-09)	M Waddock 4-765
1-28-10	Evnice Portal	#4 charger	NONE Found		M Waddock 4-765
<u>Weekly tests of grounding devices (diodes)</u>					
1-28-10	Evnice Portal	#5 charger	not in service		M Waddock 4-765
1-28-10	Punch out	Punch out D Box	Ground Fault Breakers	checked E stop	M Waddock 4-765
2-3-10	Evnice Portal	#1 charger	nut missing	ok corrected	M Waddock 4-765
2-3-10	Evnice Portal	#2 charger	NONE Found		M Waddock 4-765
2-3-10	Evnice Portal	#3 charger	NONE Found		M Waddock 4-765
2-3-10	Evnice Portal	#4 charger	NONE Found		M Waddock 4-765
<u>Monthly examinations of methane monitors</u>					
2-3-10	Evnice Portal	#5 charger	Ground clamp missing	corrected	M Waddock 4-765
2-3-10	Punch out	Punch out D Box	NONE Found		M Waddock 4-765
2-11-10	Evnice Portal	#1 charger	nut missing	corrected	M Waddock 4-765

EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner	
2-11-10	Evrite Portal	# 2 charger	Bulb make Battery Plug	corrected	M Winkler	2
2-11-10	Evrite Portal	# 3 charger	none found		M Winkler	2
2-11-10	Evrite Portal	# 4 charger	none found		M Winkler	2
2-11-10	Evrite Portal	# 5 charger	Ground clamp not being used	corrected	M Winkler	2
2-11-10	Evrite Portal	Punch out O Box	none found		M Winkler	2
2-17-10	Evrite Portal	# 1 charger	none found		M Winkler	2
2-17-10	Evrite Portal	# 2 charger	none found		M Winkler	2
2-17-10	Evrite Portal	# 3 charger	none found		M Winkler	3
2-17-10	Evrite Portal	# 4 charger	none found		M Winkler	3
2-17-10	Evrite Portal	# 5 charger	none found		M Winkler	3
2-17-10	Evrite Portal	Punch out O Box	none found		M Winkler	3
2-24-10	Evrite Portal	# 1 charger	Ground clamp not being used	corrected	M Winkler	3
2-24-10	Evrite Portal	# 2 charger	none found		M Winkler	3
2-24-10	Evrite Portal	# 3 charger	natt missing	corrected	M Winkler	3

~~Examinations of low-medium voltage power circuit breakers (monthly)~~

T. Moore 43359

EXAMINATION OF ELECTRICAL EQUIPMENT

~~Examination of electrical equipment (weekly)~~

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-24-10	Eunice Portal	# 4 charger	none Found		M. L. Wood 4-765
2-24-10	Eunice Portal	# 5 charger	none Found		M. L. Wood 4-765
2-24-10	Eunice Portal	Punch out D Box	Ground Felted (Bent) wires checked E Stop	tested ok	M. L. Wood 4-765
2-24-10	5 Ell's Head	# 6 charger	Entrance glands loose	corrected	M. L. Wood 4-765
<u>Weekly tests of grounding devices (diodes)</u>					
2-24-10	5 Ell's Head	# 7 charger	Entrance glands loose	corrected	M. L. Wood 4-765
2-24-10	5 Ell's Head	# 2 D-Box	# 1 & # 2 circuits Test ok # 3 & # 4 will not set up	Reported	M. L. Wood 4-765
3-3-10	Eunice Portal	# 1 charger	Clamp from cable to Box loose	corrected	M. L. Wood 4-765
3-3-10	Eunice Portal	# 2 charger	none Found		M. L. Wood 4-765
3-3-10	Eunice Portal	# 3 charger	Entrance cable clamp loose Put plug in knockout hole	corrected	M. L. Wood 4-765
3-3-10	Eunice Portal	# 4 charger	none Found		M. L. Wood 4-765
<u>Monthly examinations of methane monitors</u>					
3-3-10	Eunice Portal	# 5 charger	put plug in knockout hole tighter clamps	corrected	M. L. Wood 4-765
3-3-10	5 Ell's Head	# 6 charger	none Found		M. L. Wood 4-765
3-3-10	5 Ell's Head	# 7 charger	none Found		M. L. Wood 4-765

J. Moore 3359

EXAMINATION OF ELECTRICAL EQUIPMENT

~~Power centers and transformers prior to movement~~

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-3-10	Eunice punch out	punch out D Box	none Found		M. L. Lockett
3-3-10	5 Ellis Head #2	D Box	1, 2 & 4, ckt circuits ok # 3 ckt circuit out of service	Reported	M. L. Lockett
3-11-10	Eunice Portal #1	charger	none Found		M. L. Lockett
3-11-10	Eunice Portal #2	charger	Ground clamp not being used	corrected	M. L. Lockett
3-11-10	Eunice Portal #3	charger	none Found		M. L. Lockett
3-11-10	Eunice Portal #4	charger	none Found		M. L. Lockett
3-11-10	Eunice Portal #5	charger	none Found		M. L. Lockett
3-11-10	5 Ellis Head #6	charger	Ground clamp was not being used	corrected	M. L. Lockett
3-11-10	5 Ellis Head #7	charger	none Found		M. L. Lockett
3-11-10	5 Ellis Head #2	D Box	# 3 ckt out of service	Reported	M. L. Lockett
3-11-10	Eunice Portal	punch out D Box	none Found		M. L. Lockett
3-17-10	Eunice Portal #1	charger	none Found		M. L. Lockett
3-17-10	Eunice Portal #2	charger	Ground clamp not being used	corrected	M. L. Lockett

T. Moore 35359

EXAMINATION OF ELECTRICAL EQUIPMENT

~~Examination of electrical equipment (weekly)~~

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-17-10	Eunice Portal	# 3 charger	changed out male plug	corrected	William Wood
3-17-10	Eunice Portal	# 4 charger	none found		4-765 W Wood
3-17-10	Eunice Portal	# 5 charger	none found		4-765 W Wood
3-17-10	5 Ellis head	# 6 charger	ground clamp not being used		4-765 W Wood
Weekly tests of grounding devices (diodes)					
3-17-10	5 Ellis head	# 7 charger	none found		4-765 W Wood
3-17-10	5 Ellis head	# 2 D Box	none found		4-765 W Wood
3-17-10	Eunice Portal	Punch out D Box	# 3 ckt out of service	Repaired	4-765 W Wood
3-26-10	Eunice Portal	# 1 charger	none found		4-765 W Wood
3-26-10	Eunice Portal	# 2 charger	ground lead missing	corrected	4-765 W Wood
3-26-10	Eunice Portal	# 3 charger	none found		4-765 W Wood
Monthly examinations of methane monitors					
3-26-10	Eunice Portal	# 4 charger	ground clamp not being used	corrected	4-765 W Wood
3-26-10	Eunice Portal	# 5 charger	none found		4-765 W Wood
3-26-10	5 Ellis Head	# 6 charger	none found		4-765 W Wood

EXAMINATION OF ELECTRICAL EQUIPMENT

~~Power centers and transformers prior to movement~~

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-26-10	5 Ellis Head	#6 charger	none Found		M. L. Hood
3-26-10	5 Ellis Head	#2 D Box	none Found		M. L. Hood
3-26-10	Evnice Portal	Punch out D Box	Ground Fault & E Stop Tested ok		M. L. Hood
3-31-10	Evnice Portal	#1 charger	none Found		M. L. Hood
3-31-10	Evnice Portal	#2 charger	none Found		M. L. Hood
3-31-10	Evnice Portal	#3 charger	none Found		M. L. Hood
3-31-10	Evnice Portal	#4 charger	set screw loose on make plug (plug loose)	corrected	M. L. Hood
3-31-10	Evnice Portal	#5 charger	none Found		M. L. Hood
Examinations of low medium voltage power circuit breakers (monthly)					
3-31-10	5 Ellis Head	#6 charger	found damp not being used	corrected	M. L. Hood
3-31-10	5 Ellis Head	#7 charger	none Found		M. L. Hood
3-31-10	5 Ellis Head	#2 D Box	none Found		M. L. Hood
3-31-10	Evnice Portal	punch out D Box	none Found		M. L. Hood