

**EXAMINATION OF  
ELECTRICAL EQUIPMENT**

Hand Tools & Shop  
Started 12-21-07

Company -----  
Mine -----  
Location -----  
                    Post Office                    County                    State

Re-order from  
BJW Printing and  
Office Supplies  
P. O. Box 1309  
Beckley, W. Va. 25801  
Phone (304) 253-7361

Form 6—1492  
(March 1970)

Budget Bureau No. 42-R1589  
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. This book is approved by the Director of The West Virginia Department of Mines and The U. S. Bureau of Mines.

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-21-07	Shop	Crane	None Found		Rarity 4-2040
12-21-07	Shop	Air Compressor	None Found		Rarity 4-2040
12-21-07	Shop	4" x 9" Grinders	None Found		Rarity 4-2040
12-21-07	Shop	1 Welder	Cable Damaged	Corrected	Rarity 4-2040
Weekly tests of grounding devices (diodes)					
12-21-07	Bathhouse	Water Heaters	None Found		Rarity 4-2040
12-21-07	Shop	Band Saw	None Found		Rarity 4-2040
12-21-07	Shop	#1 + #2 Ext Cords	Tested OK		Rarity 4-2040
12-21-07	Shop	Magnetic + Hand Drills	None Found		Rarity 4-2040
12-21-07	Shop	Shop	None Found		Rarity 4-2040
12-28-07	Shop	Crane	None Found		Rarity 4-2040
Monthly examinations of methane monitors					
12-28-07	Shop	Air Compressor	None Found		Rarity 4-2040
12-28-07	Shop	Shop	Needs Repair	Corrected	Rarity 4-2040
12-28-07	Bathhouse	Water Heaters	None Found		Rarity 4-2040

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-28-07	Shop	4" x 9" Grinders	4" Grinder switch would lock	Corrected	R. Kelly 4-2008
12-28-07	Shop	1 + 2 Ext. Cords	Tested OK		R. Kelly 4-2008
12-28-07	Shop	Magnetic + Hand Drills	None Found		R. Kelly 4-2008
12-28-07	Shop	Bandsaw	None Found		R. Kelly 4-2008
12-28-07	Shop	1 Welder	None Found		R. Kelly 4-2008
1-4-08	Shop	Shop	Needed cleaned	Corrected	R. Kelly 4-2008
1-4-08	Shop	Crow	None Found		R. Kelly 4-2008
1-4-08	Shop	Air Compressor	None Found		R. Kelly 4-2008
Examinations of low- medium-voltage power circuit breakers (monthly)					
1-4-08	Shop	1 + 2 Ext Cords	None Found Tested OK		R. Kelly 4-2008
1-4-08	Shop	Magnetic + Hand Drills	None Found		R. Kelly 4-2008
1-4-08	Shop	Bandsaw	None Found		R. Kelly 4-2008
1-4-08	Shop	1 Welder	None Found		R. Kelly 4-2008
1-4-08	Shop	4" x 9" Grinders	None Found		R. Kelly 4-2008
1-4-08	Bathroom	Water Heaters	None Found		R. Kelly 4-2008

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-11-08	Shop	Shop	None Found		Raulty 4-204
1-11-08	shop	Crane	None Found		Raulty 4-204
1-11-08	Shop	Air Compressor	None Found		Raulty 4-204
1-11-08	Bathhouse	Water Heaters	None Found		Raulty 4-204
Weekly tests of grounding devices (diodes)					
1-11-08	Shop	1 Welder	None Found		Raulty 4-204
1-11-08	Shop	4-9" Grinders	None Found		Raulty 4-204
1-11-08	Shop	Magnetic Hand Drills	None Found		Raulty 4-204
1-11-08	Shop	1-2 Ext Cords	Tested OK		Raulty 4-204
1-11-08	Shop	Bandsaw	None Found		Raulty 4-204
1-18-08	Shop	Shop	Needs Ground	Corrected	Raulty 4-204
Monthly examinations of methane monitors					
1-18-08	Shop	Crane	Needs Ground Rail	order Placed	Raulty 4-204
1-18-08	Shop	Air Compressor	Water Pallets are the Compressor block off	> Corrected	Raulty 4-204
1-18-08	Shop	1-2 Ext Cords	Tested OK		Raulty 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-18-08	Shop	Magnetic + Hand Drills	None Found		R. Canty
1-18-08	Shop	1 Welder	None Found		R. Canty
1-18-08	Shop	Band Saw	None Found		R. Canty
1-18-08	Shop	4" x 9" Grinders	None Found		R. Canty
1-18-08	Bath house	Water Heaters	None Found		R. Canty
1-25-08	Shop	CRANE	None Found		R. Canty
1-25-08	Shop	Air Compressor	None Found		R. Canty
1-25-08	Shop	1 x 2 Est Cords	Tested OK		R. Canty
Examinations of low- medium-voltage power circuit breakers (monthly)					
1-25-08	Shop	Magnetic + Hand Drills	None Found		R. Canty
1-25-08	Shop	4" x 9" Grinders	None Found		R. Canty
1-25-08	Bathhouse	Water Heaters	None Found		R. Canty
1-25-08	Shop	Band saw	None Found		R. Canty
1-25-08	Shop	1 Welder	Need new cables		R. Canty
1-25-08	Shop	Cables taken	INSIDE		R. Canty
1-25-08	Shop	Shop	None Found		R. Canty

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-1-08	Shop	Shop	Needed cleaned	Corrected	Raitt 4-204 J
2-1-08	Shop	Air Compressors	None Found		Raitt 4-204 J
2-1-08	Bath house	Water Heaters	None Found		Raitt 4-204 J
2-1-08	Shop	CRAW	None Found		Raitt 4-204 J
Weekly tests of grounding devices (diodes)					
2-1-08	Shop	1+2 Ext. Cords	Tested OK		Raitt 4-204 J
2-1-08	Shop	4" + 9" Grinders	None Found		Raitt 4-204 J
2-1-08	Shop	Magnetic + Hand Drills	None Found		Raitt 4-204 J
2-1-08	Shop	Band Saw	None Found		Raitt 4-204 J
2-1-08	Shop	1 welder	None Found		Raitt 4-204 J
2-8-08	Shop	CRAW	None Found		Raitt 4-204 J
Monthly examinations of methane monitors					
2-8-08	Shop	Air Compressor	None Found		Raitt 4-204 J
2-8-08	Shop	1 welder	Installed new cables		Raitt 4-204 J
2-8-08	Shop	1 + 2 Ext. Cords	Tested OK		Raitt 4-204 J

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-8-08	shop	4" & 9" Grinders	None found		Randy 4-20-08
2-8-08	Bathroom	Water Heaters	None found		Randy 4-20-08
2-8-08	shop	BANDSAW	None found		Randy 4-20-08
2-8-08	shop	Magnetic Hand Drills	abuse found		Randy 4-20-08
2-8-08	shop	Shop	Need cleaned	Corrected	Randy 4-20-08
2-15-08	shop	CRANE	Need Grounding. ordered Corrected RC 2-22-08		Randy 4-20-08
2-15-08	Bathroom	Water Heaters	Door need replaced		Randy 4-20-08
2-15-08	shop	Air Compressor	None found		Randy 4-20-08
Examinations of low- medium-voltage power circuit breakers (monthly)					
2-15-08	shop	1 & 2 Ext Cords	Tested OK		Randy 4-20-08
2-15-08	shop	4" & 9" Grinders	None found		Randy 4-20-08
2-15-08	shop	BANDSAW	None found		Randy 4-20-08
2-15-08	shop	1 Welder	None found		Randy 4-20-08
2-15-08	shop	Magnetic Hand Drills	abuse found		Randy 4-20-08



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-15-08	Shop	Shop	None found		Raulty 4-204
2-22-08	Shop	CRANE	Need Ground Rail Corrected 2-22-08		Raulty 4-204
2-22-08	Shop	Air Compressor	None found		Raulty 4-204
2-22-08	shop	4" & 9" Grinders	None found		Raulty 4-204
Weekly tests of grounding devices (diodes)					
2-22-08	Shop	BANDSAW	None found		Raulty 4-204
2-22-08	shop	Magnetic & Hand Drill	None found		Raulty 4-204
2-22-08	Bathroom	Water Heaters	None found		Raulty 4-204
2-22-08	shop	1 & 2 Ext Cords	Tested OK		Raulty 4-204
2-22-08	shop	Shop	needed cleaned	Corrected	Raulty 4-204
2-22-08	Shop	1 welder	None found		Raulty 4-204
Monthly examinations of methane monitors					
2-29-08	Shop	Shop	needed cleaned	Corrected	Raulty 4-204
2-29-08	Shop	CRANE	None found		Raulty 4-204
2-29-08	shop	Air Compressor	No mat	Corrected	Raulty 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-29-08	Shop	1 Welder	No mat	Corrected	Raitch 4-2009
2-29-08	Shop	4" x 9" Grinders	None Found		Raitch 4-2009
2-29-08	Shop	1 + 2 Ext Cords	Tested OK		Raitch 4-2009
2-29-08	Bathroom	Water heaters	None Found		Raitch 4-2009
2-29-08	Shop	Magnetic + Hand Drills	None Found		Raitch 4-2009
2-29-08	Shop	Bandsaw	None Found		Raitch 4-2009
3-6-08	Shop	Shop	No Fire Ext 1 missing at Welder	(Corrected)	Raitch 4-2009

Examinations of low- medium-voltage power circuit breakers (monthly)

3-6-08	shop	1 Welder	None Found		Raitch 4-2009
3-6-08	Shop	4" x 9" Grinders	None Found		Raitch 4-2009
3-6-08	shop	Magnetic + Hand Drills	None Found		Raitch 4-2009
3-6-08	Shop	1 + 2 Ext Cords	Tested OK		Raitch 4-2009
3-6-08	Bathroom	Water Heaters	None Found		Raitch 4-2009

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-6-08	shop	Bandsaw	None found		Raulty
3-6-08	shop	Crane	None found		Raulty
3-6-08	shop	Air Compressor	None found		Raulty
3-14-08	shop	Crane	None found		Raulty
Weekly tests of grounding devices (diodes)					
3-14-08	shop	Air Compressor	None found		Raulty
3-14-08	shop	4" & 9" Grinders	None found		Raulty
3-14-08	shop	Magnetic & Hand Drills	None found		Raulty
3-14-08	shop	1 & 2 Ext Cords	Tested OK		Raulty
3-14-08	Bath house	Water Heaters	None found		Raulty
3-14-08	shop	1 Welder	None found		Raulty
Monthly examinations of methane monitors					
3-14-08	shop	Bandsaw	None found		Raulty
3-14-08	shop	Shop	None found		Raulty

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-20-08	Shop	Shop	None Found		R.ault
3-20-08	Shop	CRANE	None Found		R.ault
3-20-08	Shop	Air Compressor	None Found		R.ault
3-20-08	Shop	1+2 Ext Cords	Tested OK		R.ault
3-20-08	Shop	4" x 9" Grinders	None Found		R.ault
3-20-08	Shop	Bandsaw	None Found		R.ault
3-20-08	Bathroom	Water Heaters	None Found		R.ault
3-20-08	Shop	Magnetic Hand Drills	None Found		R.ault
Examinations of low-medium-voltage power circuit breakers (monthly)					
3-20-08	Shop	1 welder	None Found		R.ault
3-27-08	Shop	Air Compressor	None Found		R.ault
3-27-08	Shop	CRANE	None Found		R.ault
3-27-08	Shop	1+2 Ext Cord	Tested OK		R.ault
3-27-08	Shop	4" x 9" Grinders	None Found		R.ault

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-27-08	Shop	Band Saw	None Found		Raith 4-20-08
3-27-08	Shop	Magnetic & Hand Drills	None Found		Raith 4-20-08
3-27-08	Bathhouse	Water Heaters	None Found		Raith 4-20-08
3-27-08	Shop	1 Welder	None Found		Raith 4-20-08
Weekly tests of grounding devices (diodes)					
3-27-08	Shop	Shop	None Found		Raith 4-20-08
4-3-08	Shop	Crank	None Found		Raith 4-20-08
4-3-08	Shop	Air Compressor	None Found		Raith 4-20-08
4-3-08	Shop	Shop	Welder Ground Connected		Raith 4-20-08
4-3-08	Shop	4" & 9" Grinders	Plug bad on 9" Grinders	Corrected	Raith 4-20-08
4-3-08	Bathhouse	Water Heaters	None Found		Raith 4-20-08
Monthly examinations of methane monitors					
4-3-08	Shop	1 Welder	Cable damaged	Corrected	Raith 4-20-08
4-3-08	Shop	1 & 2 Est Cords	Tested OK		Raith 4-20-08
4-3-08	Shop	Band Saw	None Found		Raith 4-20-08

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
4-3-08	Shop	Magnetic & Hand Drills	None Found		Raitt
4-11-08	Shop	Shop	No ID on 1 Power box & 2 Power box	> Corrected	Raitt
4-11-08	Shop	Crane	None Found		Raitt
4-11-08	Shop	Air Compressor	Compressor bad Taken out of service		Raitt
4-11-08	Shop	1 Welder	None Found		Raitt
4-11-08	Shop	Bandsaw	None Found		Raitt
4-11-08	Shop	1 & 2 Ext Cords	Tested OK		Raitt
4-11-08	Bath house	Water Heaters	None Found		Raitt
Examinations of low- medium-voltage power circuit breakers (monthly)					
4-11-08	Shop	Magnetic & Hand Drills	None Found		Raitt
4-11-08	Shop	9" & 4" Grinders	None Found		Raitt
4-17-08	Shop	Shop	None Found		Raitt
4-17-08	Shop	Crane	None Found		Raitt
4-17-08	Shop	1 & 2 Ext Cords	Tested OK		Raitt
4-17-08	Bathhouse	Water Heaters	None Found		Raitt

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
4-17-08	Shop	4" & 9" Grinder	None Found		R. Kelly 4-20-08
4-17-08	Shop	1 welder	Red Holder bad	Corrected	R. Kelly 4-20-08
4-17-08	Shop	Air Compressor	Bearing bad out of Service		R. Kelly 4-20-08
4-17-08	Shop	Magnetic & Hand Drill	None Found		R. Kelly 4-20-08
Weekly tests of grounding devices (diodes)					
4-17-08	Shop	BANDSAW	None Found		R. Kelly 4-20-08
4-25-08	Shop	CRANE	None Found		R. Kelly 4-20-08
4-25-08	Shop	Air Compressor	out of Service		R. Kelly 4-20-08
4-25-08	Shop	1 & 2 Ext Cords	Tested OK		R. Kelly 4-20-08
4-25-08	Shop	HAND & MAGNETIC DRILLS	None Found		R. Kelly 4-20-08
4-25-08	Shop	Shop	Needle changed	Corrected	R. Kelly 4-20-08
Monthly examinations of methane monitors					
4-25-08	Shop	4" & 9" GRINDERS	None Found		R. Kelly 4-20-08
4-25-08	Bathroom	Water Heater	Door locked	checking on key	R. Kelly 4-20-08
4-25-08	Shop	1 welder	None Found		R. Kelly 4-20-08

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
4-25-08	Shop	Bandsaw	None Found		Raulty 4-20-08
5-1-08	Shop	Crane	None Found		Raulty 4-20-08
5-1-08	Shop	Air Compressor	out of Service for Repair		Raulty 4-20-08
5-1-08	Shop	4" & 9" Grinders	None Found		Raulty 4-20-08
5-1-08	Shop	Bandsaw	None Found		Raulty 4-20-08
5-1-08	Shop	1 & 2 Ext. Cid	Tested OK		Raulty 4-20-08
5-1-08	Bathroom	Water Heater	None Found		Raulty 4-20-08
5-1-08	Shop	Shop	None Found		Raulty 4-20-08
Examinations of low- medium-voltage power circuit breakers (monthly)					
5-1-08	Shop	Hand & Magnetic Drills	None Found		Raulty 4-20-08
5-1-08	Shop	1 Welder	None Found		Raulty 4-20-08
5-9-08	Shop	Shop	None Found		Raulty 4-20-08
5-9-08	Shop	Air Compressor	out of Service for Repair		Raulty 4-20-08
5-9-08	Shop	Crane	None Found		Raulty 4-20-08



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
5-9-08	Shop	4" x 9" Grinders	None Found		R. Carthy
5-9-08	Shop	BAND SAW	None Found		R. Carthy
5-9-08	Bath house	Water Heaters	None Found		R. Carthy
5-9-08	Shop	1 & 2 Ext Cords	Tested OK		R. Carthy
Weekly tests of grounding devices (diodes)					
5-9-08	Shop	1 welder	None Found		R. Carthy
5-9-08	Shop	Magnetic & Hand Drills	None Found		R. Carthy
5-16-08	Shop	CRANE	None Found		R. Carthy
5-16-08	Shop	Air Compressor	out of Service for Repair		R. Carthy
5-16-08	Shop	4" x 9" Grinders	None Found		R. Carthy
5-16-08	Shop	1 welder	None Found		R. Carthy
Monthly examinations of methane monitors					
5-16-08	Shop	BAND SAW	None Found		R. Carthy
5-16-08	Shop	1 & 2 Ext Cords	Tested OK		R. Carthy
5-16-08	Bath house	Water Heaters	None Found		R. Carthy

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
5-16-08	Shop	Shop	None Found		R. Canty
5-16-08	Shop	Hand & Magnetic Drills	None Found		R. Canty
5-22-08	Shop	CRANE	None Found		R. Canty
5-22-08	Shop	Air Compressor	out of Service		R. Canty
5-22-08	Shop	1 & 2 Est. Cords	for Repair tested OK		R. Canty
5-22-08	Bathroom	Water Heaters	None Found		R. Canty
5-22-08	Shop	4" & 9" Grinders	None Found		R. Canty
5-22-08	Shop	1 Welder	Cable Damaged Corroded		R. Canty
Examinations of low- medium-voltage power circuit breakers (monthly)					
5-22-08	Shop	Bandsaw	None Found		R. Canty
5-22-08	Shop	Hand & Magnetic Drills	None Found		R. Canty
5-22-08	Shop	Shop	Welder Cleared Corroded		R. Canty
5-30-08	Shop	CRANE	None Found		R. Canty
5-30-08	Shop	Air Compressor	out of Service		R. Canty
5-30-08	Shop	Shop	None Found		R. Canty

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
5-30-08	Shop	4" 9" Grinders	None Found		Raulty 4-204
5-30-08	Bathhouse	Water Heaters	None Found		Raulty 4-204
5-30-08	Shop	Magnetic Hand Drills	None Found		Raulty 4-204
5-30-08	Shop	1 Welder	None Found		Raulty 4-204
Weekly tests of grounding devices (diodes)					
5-30-08	Shop	Band Saw	None Found		Raulty 4-204
5-30-08	Shop	1+2 Ext Cords	Tested OK		Raulty 4-204
6-6-08	Shop	Shop	Neutral Chiral	Corrected	Raulty 4-204
6-6-08	Shop	CARC	None Found		Raulty 4-204
6-6-08	Shop	Air Compressor	out of Service		Raulty 4-204
6-6-08	Bathhouse	Water Heaters	None Found		Raulty 4-204
Monthly examinations of methane monitors					
6-6-08	Shop	1+2 Ext Cords	Tested OK		Raulty 4-204
6-6-08	Shop	Magnetic & Hand Drills	None Found		Raulty 4-204
6-6-08	Shop	4" 9" Grinders	None Found		Raulty 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
6-6-08	Shop	1 Welder	None Found		R. Canty 4-2008
6-6-08	Shop	Bandsaw	None Found		R. Canty 4-2008
6-13-08	Shop	Shop	overhead SW down	Reported	R. Canty 4-2008
6-13-08	Shop	Air Compressor	out of Service		R. Canty 4-2008
6-13-08	Shop	Crane	Switch broken	Conded	R. Canty 4-2008
6-13-08	Shop	1 Welder	None Found		R. Canty 4-2008
6-13-08	Shop	4' x 9" Grinders	None Found		R. Canty 4-2008
6-13-08	Bathroom	Water Heaters	None Found		R. Canty 4-2008
Examinations of low- medium-voltage power circuit breakers (monthly)					
6-13-08	shop	Magnetic Hand Drills	None Found		R. Canty 4-2008
6-13-08	Shop	1+2 Ext cord	Tested OK		R. Canty 4-2008
6-20-08	Shop	Crane	None Found		R. Canty 4-2008
6-20-08	Shop	Air Compressor	out of Service		R. Canty 4-2008
6-20-08	Shop	Shop	None Found		R. Canty 4-2008
1-20-08	Bathroom	Water Heaters	None Found		R. Canty 4-2008

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
6-20-08	Shop	1 & 2 Est Cords	Tested OK		Rault 4-2008
6-20-08	Shop	4" & 9" Grinders	None Found		Rault 4-2008
6-20-08	Shop	1 Welder	None Found		Rault 4-2008
6-20-08	Shop	Magnetic & Hand Drills	None Found		Rault 4-2008
Weekly tests of grounding devices (diodes)					
6-23-08	Shop	Shop	None Found	Corrected	Rault 4-2008
6-23-08	Shop	CRAUC	None Found		Rault 4-2008
6-23-08	Shop	Air Compressor	out of Service		Rault 4-2008
6-23-08	Bath house	Water Heaters	None Found		Rault 4-2008
6-23-08	Shop	4" & 9" Grinders	None Found		Rault 4-2008
6-23-08	Shop	1 Welder	None Found		Rault 4-2008
Monthly examinations of methane monitors					
6-23-08	Shop	1 & 2 Est Cords	Tested OK		Rault 4-2008
6-23-08	Shop	Magnetic & Hand Drills	None Found		Rault 4-2008

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
7-11-08	Shop	Shop	Overhead Fan inoperative	Reported	R. Kelly 4-204
7-11-08	Shop	Crane	None found		R. Kelly 4-204
7-11-08	Shop	Air Compressor	out of Service		R. Kelly 4-204
7-11-08	Shop	Magnetic & Hand Drills	None found		R. Kelly 4-204
7-11-08	Shop	1+2 Ext Cords	Tested OK		R. Kelly 4-204
7-11-08	Bathroom	Water Heaters	None found		R. Kelly 4-204
7-11-08	Shop	4" & 9" Grinders	None found		R. Kelly 4-204
7-11-08	Shop	Bandsaw	None found		R. Kelly 4-204
Examinations of low- medium-voltage power circuit breakers (monthly)					
7-11-08	Shop	1 Welder	None found		R. Kelly 4-204
7-18-08	Shop	Shop	Overhead Fan inoperative	Reported	R. Kelly 4-204
7-18-08	Shop	Air Compressor	out of Service For Repair	Parts ordered	R. Kelly 4-204
7-18-08	Bathroom	Water Heaters	None found		R. Kelly 4-204
7-18-08	Shop	Crane	None found		R. Kelly 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
7-18-08	Shop	4" x 9" Grinders	None Found		Raitly 4-204
7-18-08	Shop	1+2 Ext. Cords	Tested OK		Raitly 4-204
7-18-08	Shop	Band saw	None Found		Raitly 4-204
7-18-08	Shop	1 Welder	Damaged Cable	Corrected	Raitly 4-204
Weekly tests of grounding devices (diodes)					
7-18-08	Shop	Magnetic & Hand Drills	None Found		Raitly 4-204
7-25-08	Shop	Crane	None Found		Raitly 4-204
7-25-08	Shop	Air Compressor	out of Service Parts ordered		Raitly 4-204
7-25-08	Shop	1+2 Ext Cords	Tested OK		Raitly 4-204
7-25-08	Bathroom	Water Heaters	None Found		Raitly 4-204
7-25-08	Shop	Shop	overhead Fan inoperative	Reported	Raitly 4-204
Monthly examinations of methane monitors					
7-25-08	Shop	Magnetic & Hand Drill	None Found		Raitly 4-204
7-25-08	Shop	Band saw	None Found		Raitly 4-204
7-25-08	Shop	4" x 9" Grinders	None Found		Raitly 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
7-25-08	shop	1 Welder	None Found		R. Lait
8-1-08	shop	Shop	overhead Fan inoperative	parts ordered	R. Lait
8-1-08	shop	Crane	None Found		R. Lait
8-1-08	shop	Air Compressor	out of Service	Parts ordered	R. Lait
8-1-08	shop	1+2 Ext Cords	Tested OK		R. Lait
8-1-08	shop	1 Welder	Red Holes had Ground clamp bad	Corrected	R. Lait
8-1-08	Bath house	Water Heaters	None Found		R. Lait
8-1-08	shop	Magnetic Hand Drills	None Found		R. Lait
Examinations of low- medium-voltage power circuit breakers (monthly)					
8-1-08	shop	Band Saw 4" x 9" Grinders	None Found		R. Lait
8-7-08	shop	Shop	overhead Fan inoperative		R. Lait
8-7-08	shop	Crane	out of Service	Reported	R. Lait
8-7-08	shop	1 Welder	None Found		R. Lait
8-7-08	shop	4" x 9" Grinders	None Found		R. Lait



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
8-7-08	shop	Magnetic + Hand Drills	None found		Rault 4-20-08
8-7-08	Bathhouse	Water Heaters	None found		Rault 4-20-08
8-7-08	shop	Bandsaw	None found		Rault 4-20-08
8-7-08	shop	1+2 Ext Cords	Tested OK		Rault 4-20-08
Weekly tests of grounding devices (diodes)					
8-7-08	shop	Air Compressor	out of service		Rault 4-20-08
8-15-08	shop	shop	overhead Fan inoperative	Parts ordered	Rault 4-20-08
8-15-08	Bathhouse	Water Heaters	None found		Rault 4-20-08
8-15-08	shop	CRANE	List inoperative		Rault 4-20-08
8-15-08	shop	Air Compressor	checked + repaired by Crane America out of service		Rault 4-20-08
8-15-08	shop	1+2 Extension Cords	Tested OK		Rault 4-20-08
Monthly examinations of methane monitors					
8-15-08	shop	Bandsaw	None found		Rault 4-20-08
8-15-08	shop	Magnetic + Hand Drill	None found		Rault 4-20-08
8-15-08	shop	1 Welder	None found		Rault 4-20-08

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous condition	Action taken	Examiner
8-15-08	Shop	4" x 9" Grinders	None Found		Railly
8-15-08	Shop	1+2 Power box	None Found		Railly
8-15-08	Shop	1-2-3 Fans	None Found		Railly
8-22-08	Shop	Crane	None Found		Railly
8-22-08	Shop	Air Compressor	out of Service		Railly
8-22-08	Shop	1 Welder	None Found		Railly
8-22-08	Shop	4" x 9" Grinders	None Found		Railly
8-22-08	Shop	Bandsaw	None Found		Railly
Examinations of low- medium-voltage power circuit breakers (monthly)					
8-22-08	Bathroom	Water Heaters	None Found		Railly
8-22-08	Shop	1-2-3 Fans	None Found		Railly
8-22-08	Shop	1-2 Power box	None Found		Railly
8-22-08	Shop	Shop	Needed Ground	Consolid	Railly
8-22-08	Shop	1+2 Ext. Cords	Tested OK		Railly

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
8-29-08	Shop	Hand + Magnetic Drills	None Found		Rantle 4-2008
8-29-08	Shop	Crane	None Found		Rantle 4-2008
8-29-08	Shop	Air Compressor	out of Service. Parts ordered		Rantle 4-2008
8-29-08	Shop	4' x 9" Grinders	None Found		Rantle 4-2008
Weekly tests of grounding devices (diodes)					
8-29-08	Shop	1 Welder	None Found		Rantle 4-2008
8-29-08	Bath house	Water Heaters	None Found		Rantle 4-2008
8-29-08	Shop	BANDSAW	None Found		Rantle 4-2008
8-29-08	Shop	1-2 Ext Cords	Tested OK		Rantle 4-2008
8-29-08	Shop	1-2-3 Fans	None Found		Rantle 4-2008
8-29-08	Shop	Shop	Fire Ext missing	Corrected	Rantle 4-2008
Monthly examinations of methane monitors					
8-29-08	Shop	1-2 Power box	None Found		Rantle 4-2008
8-29-08	Shop	Magnetic + Hand Drills	None Found		Rantle 4-2008

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-5-08	Shop	5 <sup>1/2</sup> Overhead Fan inoperative		Parts ordered	Rantz
9-5-08	Shop	1+2 Ext. Cords	Tested OK		Rantz
9-5-08	Shop	Crowc	None Found		Rantz
9-5-08	Shop	Air Compressor	out of Service		Rantz
9-5-08	Bathhouse	Water Heaters	None Found		Rantz
9-5-08	Shop	Magnetic + Hand Drills	None Found		Rantz
9-5-08	Shop	Bandsaw	None Found		Rantz
9-5-08	Shop	1-2-3 Fans	None Found		Rantz
Examinations of low- medium-voltage power circuit breakers (monthly)					
9-5-08	Shop	1+2 Power Box	None Found		Rantz
9-5-08	Shop	1 Welder	None Found		Rantz
9-5-08	Shop	4"+9" Grinders	None Found		Rantz
9-12-08	Shop	Crowc	None Found		Rantz
9-12-08	Shop	Air Compressor	out of Service	Concrete Q 9-17-08 RC	Rantz

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-12-08	Shop	Shop	overhead Fan inoperative	Parts ordered	Raith 4-20-09
9-12-08	Shop	1+2 Est Cords	Tested OK		Raith 4-20-09
9-12-08	Shop	4" x 9" Grinders	None found		Raith 4-20-09
9-12-08	Shop	Magnetic + Hand Drills	None found		Raith 4-20-09
Weekly tests of grounding devices (diodes)					
9-12-08	Shop	Bandsaw	None found		Raith 4-20-09
9-12-08	Shop	1-2-3 Fans	None found		Raith 4-20-09
9-12-08	Bathroom	Water Heaters	None found		Raith 4-20-09
9-12-08	Shop	1+2 Power box	None found		Raith 4-20-09
9-12-08	Shop	1 Welder	None found		Raith 4-20-09
9-19-08	Shop	CRAW	None found		Raith 4-20-09
Monthly examinations of methane monitors					
9-19-08	Shop	Air Compressor	None found		Raith 4-20-09
9-19-08	Shop	Shop	overhead Fan inoperative	Parts ordered	Raith 4-20-09
9-19-08	Bathroom	Water Heaters	None found		Raith 4-20-09

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-19-08	Shop	1 Welder	None Found		R. Kelly
9-19-08	Shop	1-2-3 FANS	None Found		R. Kelly
9-19-08	Shop	1-2 Power box	None Found		R. Kelly
9-19-08	Shop	Magnetic → Hand Drills	None Found		R. Kelly
9-19-08	Shop	1-2 Ext Cords	Tested OK		R. Kelly
9-19-08	Shop	BAND SAW	None Found		R. Kelly
9-19-08	Shop	4" → 9" Grinders	None Found		R. Kelly
9-25-08	Shop	CRANE	None Found		R. Kelly
Examinations of low- medium-voltage power circuit breakers (monthly)					
9-25-08	Shop	Air Compressor	Control inoperative		R. Kelly
9-25-08	Bathroom	Water Heaters	None Found		R. Kelly
9-25-08	Shop	1 Welder	None Found		R. Kelly
9-25-08	Shop	4" → 9" Grinders	None Found		R. Kelly
9-25-08	Shop	1-2 Ext Cords	Tested OK		R. Kelly

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-25-08	Shop	1-2-3 Fans	None Found		R. Kelly 4-2008
9-25-08	Shop	1-2 Power box	None Found		R. Kelly 4-2008
9-25-08	Shop	BANDSAW	None Found		R. Kelly 4-2008
9-25-08	Shop	Magnetic & Hand Drills	None Found		R. Kelly 4-2008
Weekly tests of grounding devices (diodes)					
9-25-08	Shop	Shop	overhead Fan down	Reported	R. Kelly 4-2008
10-3-08	Shop	CAGE	None Found		R. Kelly 4-2008
10-3-08	Shop	Air Compressor	out of service		R. Kelly 4-2008
10-3-08	Bathhouse	Water Heaters	None Found		R. Kelly 4-2008
10-3-08	Shop	1 Welder	No mat	Corrected	R. Kelly 4-2008
10-3-08	Shop	BANDSAW	None Found		R. Kelly 4-2008
Monthly examinations of methane monitors					
10-3-08	Shop	Magnetic & Hand Drills	None Found		R. Kelly 4-2008
10-3-08	Shop	1-2-3 Fans	None Found		R. Kelly 4-2008
10-3-08	Shop	1-2 Ext. Cords	Tested OK		R. Kelly 4-2008

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examined by
10-3-08	Shop	4" x 9" Grinders	None Found		Kant
10-3-08	Shop	1 x 2 Power Box	None Found		Kant
10-3-08	Shop	Shop	over head Fan inoperative	Reported	Kant
10-10-08	Shop	CRANE	None Found		Kant
10-10-08	Shop	Air Compressor	out of Service		Kant
10-10-08	Shop	1 x 2 Power Box	No mat	Contact	Kant
10-10-08	Shop	1-2-3 FANS	None Found		Kant
10-10-08	Shop	Bandsaw	None Found		Kant
Examinations of low- medium-voltage power circuit breakers (monthly)					
10-10-08	Shop	4" x 9" Grinders	None Found		Kant
10-10-08	Shop	1 x 2 Ext. Cords	Tested OK		Kant
10-10-08	Bathhouse	Water Heaters	None Found		Kant
10-10-08	Shop	Shop	overhead Fan Down	Reported	Kant
10-10-08	Shop	1 Welder	Cable damaged	Contact	Kant



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-10-08	Shop	Magnetic & Hand Drills	None Found		Kantle 4-204
10-17-08	Shop	CRANE	None Found		Kantle 4-204
10-17-08	Shop	Air Compressor	out of Service		Kantle 4-204
10-17-08	Shop	Shop	overhead FAN inoperative	Reported	Kantle 4-204

Weekly tests of grounding devices (diodes)

10-17-08	Shop	1-2-3 FANS	None Found		Kantle 4-204
10-17-08	Shop	1-2 Power Box	None Found		Kantle 4-204
10-17-08	Shop	Magnetic & HAND Drills	None Found		Kantle 4-204
10-17-08	Shop	4" x 9" Grinders	None Found		Kantle 4-204
10-17-08	Shop	1-2 Ext Cords	Tested OK		Kantle 4-204
10-17-08	Bathroom	water heaters	None Found		Kantle 4-204

Monthly examinations of methane monitors

10-17-08	Shop	1 Welder	None Found		Kantle 4-204
10-17-08	Shop	BANDSAW	None Found		Kantle 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-24-08	Shop	Shop	overhead crane inoperative	Reported	Kathy
10-24-08	Bathhouse	Water Heaters	None Found		Kathy
10-24-08	Shop	Crane	None Found		Kathy
10-24-08	Shop	Air Compressor	out of Service		Kathy
10-24-08	Shop	1 Welder	None Found		Kathy
10-24-08	Shop	1-2-3 Fans	abuse found		Kathy
10-24-08	Shop	1-2 Power box	no mat	Corrected	Kathy
10-24-08	Shop	4" & 9" Grinders	None Found		Kathy
Examinations of low- medium-voltage power circuit breakers (monthly)					
10-24-08	Shop	Bandsaw	None Found		Kathy
10-24-08	Shop	Magnetic Hand Drills	None Found		Kathy
10-24-08	Shop	1+2 Ext. Cords	Tested OK		Kathy
10-31-08	Shop	Crane	None Found		Kathy
10-31-08	Shop	Air Compressor	out of Service		Kathy
10-31-08	Shop	Shop	overhead Fan inoperative	Reported	Kathy

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-31-08	Shop	4" x 9" Grinder	None found		Raith 4-204
10-31-08	Shop	Magnetic & Hand Drills	None found		Raith 4-204
10-31-08	Shop	1+2 Power Box	None found		Raith 4-204
10-31-08	Shop	1-2-3 Fans	None found		Raith 4-204
Weekly tests of grounding devices (diodes)					
10-31-08	Shop	1 Welder	None found		Raith 4-204
10-31-08	Bathroom	Water Heaters	None found		Raith 4-204
10-31-08	Shop	1+2 Ext Cords	Rated OK		Raith 4-204
10-31-08	Shop	Bandsaw	None found		Raith 4-204
11-6-08	Shop	Crane	None found		Raith 4-204
11-6-08	Shop	Air Compressor	out of service		Raith 4-204
Monthly examinations of methane monitors					
11-6-08	Shop	1+2 Ext. Cords	Rated OK		Raith 4-204
11-6-08	Shop	Magnetic & Hand Drills	None found		Raith 4-204
11-6-08	Bath house	water Heater	1 contactor bad	Corrected	Raith 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-6-08	Shop	Bandsaw	None Found		R. Canty 4-204
11-6-08	Shop	4" & 9" Grinders	None Found		R. Canty 4-204
11-6-08	Shop	1-2 Power box	None Found		R. Canty 4-204
11-6-08	Shop	1-2-3 Fans	None Found		R. Canty 4-204
11-6-08	Shop	Shop	overhead Fan impactive	Reported	R. Canty 4-204
11-6-08	Shop	1 Welder	None Found		R. Canty 4-204
11-14-08	Shop	Crank	None Found		R. Canty 4-204
11-14-08	Shop	Air Compressor	out of Service		R. Canty 4-204
Examinations of low- medium-voltage power circuit breakers (monthly)					
11-14-08	Shop	Shop	overhead Fan impactive	Reported	R. Canty 4-204
11-14-08	Shop	4" & 9" Grinders	None Found		R. Canty 4-204
11-14-08	Shop	Bandsaw	None Found		R. Canty 4-204
11-14-08	Shop	Magnetic & Hand Drills	None Found		R. Canty 4-204
11-14-08	Shop	1-2-3 Fans	None Found		R. Canty 4-204
11-14-08	Shop	1-2 Power box	No MAT	Cancelled	R. Canty 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-14-08	Bathhouse	Water Heaters	None Found		Rail 4-204
11-14-08	Shop	1-2 Ext. Cords	Tested OK		Rail 4-204
11-14-08	Shop	1 Welder	None Found		Rail 4-204
11-21-08	Shop	Air Compressor	out of Service		Rail 4-204
Weekly tests of grounding devices (diodes)					
11-21-08	Shop	Crane	None Found		Rail 4-204
11-21-08	Shop	Shop	overhead Fan repetitive	Repaired	Rail 4-204
11-21-08	Bathhouse	Water Heaters	None Found		Rail 4-204
11-21-08	Shop	4" & 9" Grinders	None Found		Rail 4-204
11-21-08	Shop	1-2 Power box	None Found		Rail 4-204
11-21-08	Shop	1-2-3 Fans	None Found		Rail 4-204
Monthly examinations of methane monitors					
11-21-08	Shop	1-2 Ext Cords	Tested OK		Rail 4-204
11-21-08	Shop	Hand + Magnetic Drills	None Found		Rail 4-204
11-21-08	Shop	Bandsaw	None Found		Rail 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-21-08	Shop	1 Welder	None Found		Rally
12-5-08	Shop	Shop	overhead Fan inoperative	Reported	Rally
12-5-08	Shop	Crane	Hoist inoperative	Corrected	Rally
12-5-08	Shop	Air Compressor	out of Service		Rally
12-5-08	Shop	4" & 9" Grinders	None Found		Rally
12-5-08	Shop	BAND SAW	None Found		Rally
12-5-08	Shop	1 & 2 Ext Cords	Tested OK		Rally
12-5-08	Bathroom	Water Heaters	None Found		Rally
Examinations of low- medium-voltage power circuit breakers (monthly)					
12-5-08	Shop	1 & 2 Power boxes	None Found		Rally
12-5-08	Shop	Hand & Magnetic Drills	None Found		Rally
12-5-08	Shop	1 welder	None Found		Rally
12-12-08	Shop	Shop	overhead Fan inoperative	Reported	Rally
12-12-08	Shop	Crane	None Found		Rally

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-12-08	Shop	Air Compressor	out of Service		Rarity 4-204P
12-12-08	Bathhouse	Water Heaters	None Found		Rarity 4-204P
12-12-08	Shop	1+2 Power box	None Found		Rarity 4-204P
12-12-08	Shop	4" & 9" Grinders	None Found		Rarity 4-204P
Weekly tests of grounding devices (diodes)					
12-12-08	Shop	1+2 Ext Cords	Tested OK		Rarity 4-204P
12-12-08	Shop	BANDSAW	None Found		Rarity 4-204P
12-12-08	Shop	Hand & Magnetic Drill	None Found		Rarity 4-204P
12-12-08	Shop	1 Welder	None Found		Rarity 4-204P
12-19-08	Shop	Shop	overhead Fan inoperative	Repaired	Rarity 4-204P
12-19-08	Bathhouse	Water Heaters	None Found		Rarity 4-204P
Monthly examinations of methane monitors					
12-19-08	Shop	CHANCE	None Found		Rarity 4-204P
12-19-08	Shop	Air Compressor	out of Service		Rarity 4-204P
12-19-08	Shop	4" & 9" Grinders	None Found		Rarity 4-204P

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-19-08	shop	Bandsaw	None found		Rant
12-19-08	shop	1+2 Ext Cords	Tested OK		Rant
12-19-08	shop	1 Welder	None found		Rant
12-19-08	shop	1+2 Power box	None found		Rant
12-19-08	shop	1+2+3 Fans	None found		Rant
12-19-08	shop	Hand + Magnetic Drills	None found		Rant
12-26-08	shop	Shop	overhead Fan down		Rant
12-26-08	shop	Crane	None found		Rant
Examinations of low- medium-voltage power circuit breakers (monthly)					
12-26-08	shop	Air Compressor	out of service		Rant
12-26-08	shop	1 Welder	None found		Rant
12-26-08	shop	1-2-3 Fans	None found		Rant
12-26-08	shop	1+2 Power Box	None found		Rant
12-26-08	shop	Magnetic + Hand Drill	None found		Rant



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-26-08	Shop	Bandsaw	None Found		L Canty 4-2009
12-26-08	Shop	1+2 Ext Cords	Tested OK		L Canty 4-2009
12-26-08	Bathroom	Water Heaters	None Found		L Canty 4-2009
12-26-08	Shop	4" x 9" Grinders	None Found		L Canty 4-2009
Weekly tests of grounding devices (diodes)					
1-2-09	Shop	Shop	overhead FAN down		L Canty 4-2009
1-2-09	Shop	Crane	yearly Test done by Crane America		L Canty 4-2009
1-2-09	Shop	Air Compressor	out of Service		L Canty 4-2009
1-2-09	Shop	4" x 9" Grinders	None Found		L Canty 4-2009
1-2-09	Shop	Bandsaw	None Found		L Canty 4-2009
1-2-09	Shop	1+2 Ext Cords	Tested OK		L Canty 4-2009
Monthly examinations of methane monitors					
1-2-09	Shop	1+2 Power Box	None Found		L Canty 4-2009
1-2-09	Shop	1-2-3 FAN	out of Service		L Canty 4-2009
1-2-09	Shop	1 Welder	None Found		L Canty 4-2009

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examine
1-2-09	Bathroom	Water Heaters	None Found		1-
1-2-09	Shop	Hand & Magnetic Drills	None Found		1-
1-8-09	Shop	Shop	over head Fan impactive	Reported	1-
1-8-09	Shop	CRAW	None Found		1-
1-8-09	Shop	Air Compressor	out of Service		
1-8-09	Shop	1-2 Power box	None Found		1-
1-8-09	Shop	1-2-3 Fans	out of Service		1-
1-8-09	Bathroom	Water Heaters	None Found		1-
Examinations of low- medium-voltage power circuit breakers (monthly)					
1-8-09	Shop	4" & 9" Grinders	None Found		1-
1-8-09	Shop	Hand & Magnetic Drills	None Found		1-
1-8-09	Shop	1-2 Ext Cords	Tested OK		1-
1-8-09	Shop	1 Welder	None Found		1-
1-8-09	Shop	Band saw	None Found		1-

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-16-09	Shop	Shop	overhead Fan down	Reported	K. Canty
1-16-09	Shop	CRANE	None Found		K. Canty
1-16-09	Shop	Air Compressor	out of Service		K. Canty
1-16-09	Shop	1-2 Ext Cords	Tested OK		K. Canty
Weekly tests of grounding devices (diodes)					
1-16-09	Shop	Magnetic Hand Tools	None Found		K. Canty
1-16-09	Shop	1-2 Power box	None Found		K. Canty
1-16-09	Shop	1-2-3 FANS	out of Service		K. Canty
1-16-09	Shop	4" x 9" Grinders	None Found		K. Canty
1-16-09	Shop	Bandsaw	None Found		K. Canty
1-16-09	Shop	1 Welder	None Found		K. Canty
Monthly examinations of methane monitors					
1-16-09	Bathhouse	Water Heaters	None Found		K. Canty
1-23-09	Shop	CRANE	None Found		K. Canty
1-23-09	Bathhouse	Water Heaters	None Found		K. Canty

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examined
1-23-09	Shop	Air Compressor	out of Service		Ready 4-20-09
1-23-09	shop	1-2 Power box	None Found		Ready 4-20-09
1-23-09	shop	1+2 Ext Cords	Tested OK		Ready 4-20-09
1-23-09	shop	BANDSAW	None Found		Ready 4-20-09
1-23-09	shop	Magnetic + Hand Drills	None Found		Ready 4-20-09
1-23-09	Shop	1 Welder	None Found		Ready 4-20-09
1-23-09	Shop	4" + 9" Grinders	None Found		Ready 4-20-09
1-30-09	Shop	Shop	needed down	Cancelled	Ready 4-20-09
Examinations of low- medium-voltage power circuit breakers (monthly)					
1-30-09	Shop	CRANE	None Found		Ready 4-20-09
1-30-09	Bathroom	Water heaters	None Found		Ready 4-20-09
1-30-09	Shop	Air Compressor	out of Service		Ready 4-20-09
1-30-09	Shop	4" + 9" Grinders	None Found		Ready 4-20-09
1-30-09	Shop	BANDSAW	None Found		Ready 4-20-09
1-30-09	Shop	1+2 Ext Cords	Tested OK		Ready 4-20-09

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-30-09	Shop	Magnetic & Hand Drills	None Found		Randy 4-20-09
1-30-09	Shop	1 Welder	None Found		Randy 4-20-09
1-30-09	Shop	1+2 Power box	no mat	Corrected	Randy 4-20-09
2-6-09	Shop	Shop	Need Closed	Corrected	Randy 4-20-09
Weekly tests of grounding devices (diodes)					
2-6-09	Shop	RANC	None Found		Randy 4-20-09
2-6-09	Shop	Air Compressor	out of Service		Randy 4-20-09
2-6-09	Shop	1+2 Ext Cords	Tested OK		Randy 4-20-09
2-6-09	Shop	1+2 Power box	None Found		Randy 4-20-09
2-6-09	Shop	1 Welder	None Found		Randy 4-20-09
2-6-09	Shop	4" & 9" Grinders	None Found		Randy 4-20-09
Monthly examinations of methane monitors					
2-6-09	Bath house	Water Heaters	None Found		Randy 4-20-09
2-6-09	Shop	Band saw	None Found		Randy 4-20-09
2-6-09	Shop	Magnetic & Hand Drills	None Found		Randy 4-20-09

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-13-09	Shop	Shop	Need cleaned	Cancelled	Randy 4-20-09
2-13-09	Shop	Crane	None found		Randy 4-20-09
2-13-09	Shop	Air Compressor	out of Service		Randy 4-20-09
2-13-09	Shop	1+2 Est Cords	Tested OK		Randy 4-20-09
2-13-09	Shop	1+2 Power box	None found		Randy 4-20-09
2-13-09	Shop	4" x 9" Grinders	None found		Randy 4-20-09
2-13-09	Shop	Band Saw	None found		Randy 4-20-09
2-13-09	Shop	Magnetic & Hand Drills	None found		Randy 4-20-09
Examinations of low- medium-voltage power circuit breakers (monthly)					
2-13-09	Bathhouse	Water Heaters	None found		Randy 4-20-09
2-13-09	Shop	1 Welder	None found		Randy 4-20-09
2-20-09	Shop	Shop	Need cleaned	Cancelled	Randy 4-20-09
2-20-09	Shop	Crane	None found		Randy 4-20-09
2-20-09	Shop	Air Compressor	out of Service		Randy 4-20-09

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-20-09	Shop	1 Welder	None Found		Raitch 4-209
2-20-09	Bathroom	Water Heaters	None Found		Raitch 4-209
2-20-09	Shop	1+2 Power box	None Found		Raitch 4-209
2-20-09	Shop	1+2 Ext. Cords	Tested OK		Raitch 4-209
Weekly tests of grounding devices (diodes)					
2-20-09	Shop	4" + 9" Grounders	None Found		Raitch 4-209
2-20-09	Shop	Magnetic + Hand Drills	None Found		Raitch 4-209
2-20-09	Shop	Bandsaw	None Found		Raitch 4-209
2-27-09	Shop	Shop	Neutral Ground Connected		Raitch 4-209
2-27-09	Shop	Air Compressor	None Found		Raitch 4-209
2-27-09	Shop	CRANE	None Found		Raitch 4-209
Monthly examinations of methane monitors					
2-27-09	Shop	1+2 Ext Cords	Tested OK		Raitch 4-209
2-27-09	Shop	1+2 Power box	None Found		Raitch 4-209
2-27-09	Shop	Magnetic + Hand Drills	None Found		Raitch 4-209

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Inspector
2-27-09	Shop	BANDSAW	None Found		Rent 4-20-09
2-27-09	Bathhouse	Water heaters	None Found		Rent 4-20-09
2-27-09	Shop	4" x 9" Grinders	None Found		Rent 4-20-09
2-27-09	Shop	1 Welder	Cable damaged	Corrected	Rent 4-20-09
3-6-09	Shop	Shop	Need Channel	Corrected	Rent 4-20-09
3-6-09	Shop	CRANE	None Found		Rent 4-20-09
3-6-09	Shop	Air Compressor	out of service		Rent 4-20-09
3-6-09	Shop	4" x 9" Grinders	None Found		Rent 4-20-09
Examinations of low- medium-voltage power circuit breakers (monthly)					
3-6-09	Bath house	Water heaters	None Found		Rent 4-20-09
3-6-09	Shop	BANDSAW	None Found		Rent 4-20-09
3-6-09	Shop	Magnetic + Hand Drills	None Found		Rent 4-20-09
3-6-09	Shop	1 welder	None Found		Rent 4-20-09
3-6-09	Shop	1+2 Ext Cords	Tested OK		Rent 4-20-09
3-6-09	Shop	1+2 Power box	None Found		Rent 4-20-09



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-13-09	Shop	Shop	2 First Aid boxes missing	Reported	Kant
3-13-09	Shop	CRANE	None Found		Kant
3-13-09	Shop	Air Compressor	out of Service		Kant
3-13-09	Shop	1+2 Ext Cords	Tested OK		Kant
Weekly tests of grounding devices (diodes)					
3-13-09	Shop	1+2 Power box	None Found		Kant
3-13-09	Bathhouse	Water Heaters	None Found		Kant
3-13-09	Shop	4" x 9" Grinders	None Found		Kant
3-13-09	Shop	1 Welder	None Found		Kant
3-13-09	Shop	Bandsaw	None Found		Kant
3-13-09	Shop	Magnetic Hand Drills	None Found		Kant
Monthly examinations of methane monitors					
3-20-09	Shop	Shop	2 First Aid boxes missing	Reported	Kant
3-20-09	Bathhouse	Water Heaters	None Found		Kant
3-20-09	Shop	CRANE	None Found		Kant

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-20-09	Shop	Air Compressors	out of Service		R. [Signature]
3-20-09	Shop	1+2 Power box	No mat	Corrected	R. [Signature]
3-20-09	Shop	1-2 Ext Cords	Tested OK		R. [Signature]
3-20-09	Shop	4" x 9" Grinders	None Found		R. [Signature]
3-20-09	Shop	Magnetic & Hand Drills	None Found		R. [Signature]
3-20-09	Shop	Bandsaw	None Found		R. [Signature]
3-20-09	Shop	1 Welder	None Found		R. [Signature]
3-26-09	Shop	Shop	2 First Aid boxes missing	Reported Corrected 3-30-09	R. [Signature]
Examinations of low- medium-voltage power circuit breakers (monthly)					
3-26-09	Shop	Crane	None Found		R. [Signature]
3-26-09	Shop	Air Compressor	out of Service		R. [Signature]
3-26-09	Shop	1+2 Ext. Cords	Tested OK		R. [Signature]
3-26-09	Bathroom	Water Heaters	None Found		R. [Signature]
3-26-09	Shop	1+2 Power box	No mat	Corrected	R. [Signature]

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examine
3-26-09	Shop	Magnetic & Hand Drill	None Found		4-20-09 Kant
3-26-09	Shop	1 Welder	None Found		4-20-09 Kant
3-26-09	Shop	4" & 9" Grinders	None Found		4-20-09 Kant
3-26-09	Shop	BANDSAW	None Found		4-20-09 Kant
Weekly tests of grounding devices (diodes)					
4-3-09	Shop	Shop	None Found	Corrected	4-20-09 Kant
4-3-09	Bathhouse	Water Heaters	None Found		4-20-09 Kant
4-3-09	Shop	CRANE	None Found		4-20-09 Kant
4-3-09	Shop	Air Compressors	None Found		4-20-09 Kant
4-3-09	Shop	1+2 Power box	None Found		4-20-09 Kant
4-3-09	Shop	1+2 Ext. Cord	Tested OK		4-20-09 Kant
Monthly examinations of methane monitors					
4-3-09	Shop	4" & 9" Grinders	None Found		4-20-09 Kant
4-3-09	shop	Magnetic & Hand Drill	None Found		4-20-09 Kant
4-3-09	Shop	1 Welder	None Found		4-20-09 Kant

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Inspector
4-3-09	Shop	Bandsaw	None Found		Kant
4-8-09	Shop	Shop	None Found		Kant
4-8-09	Shop	Air Compressor	out of Service		Kant
4-8-09	Shop	CRAC	None Found		Kant
4-8-09	Shop	1-2 Power box	None Found		Kant
4-8-09	Shop	1-2 Ext. Cables	Tested OK		Kant
4-8-09	Shop	4" x 9" Grinders	None Found		Kant
4-8-09	Shop	Bandsaw	None Found		Kant
Examinations of low- medium-voltage power circuit breakers (monthly)					
4-8-09	Bathhouse	Water Heaters	None Found		Kant
4-8-09	Shop	1 Welder	None Found		Kant
4-8-09	Shop	Magnetic Hand Drills	None Found		Kant
4-17-09	Shop	Shop	Needs Panel Connected		Kant
4-17-09	Bathhouse	Water Heaters	None Found		Kant

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
4-17-09	Shop	Crane	None found		Rentz
4-17-09	Shop	Air Compressor	out of Service		Rentz
4-17-09	Shop	1-2 Power box	NO MAT	Corrected	Rentz
4-17-09	Shop	1-2 Ext. Cords	Tested OK		Rentz
Weekly tests of grounding devices (diodes)					
4-17-09	Shop	Bandsaw	None found		Rentz
4-17-09	Shop	4" x 9" Grinder	None found		Rentz
4-17-09	Shop	Magnetic + Hand Drill	None found		Rentz
4-17-09	Shop	1 Welder	None found		Rentz
4-23-09	Shop	Shop	None found		Rentz
4-23-09	Shop	Crane	None found		Rentz
Monthly examinations of methane monitors					
4-23-09	Shop	Air Compressor	out of Service		Rentz
4-23-09	Bathhouse	Water Heaters	None found		Rentz
4-23-09	Shop	1 welder	Cable changed	Corrected	Rentz

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examined by
4-23-09	Shop	1 & 2 Power box	No mat	Corrected	Randy
4-23-09	Shop	1 Ext Cord	Tested OK		Randy
4-23-09	Shop	Magnetic & Hand Drills	None Found		Randy
4-23-09	Shop	4" & 9" Grinders	None Found		Randy
4-23-09	Shop	Bandsaw	None Found		Randy
5-1-09	Shop	Shop	Needle Clamp	Corrected	Randy
5-1-09	Shop	Crane	None Found		Randy
5-1-09	Shop	Air Compressor	out of Service		Randy
Examinations of low- medium-voltage power circuit breakers (monthly)					
5-1-09	Shop	1 & 2 Power box	no mat	Corrected	Randy
5-1-09	Shop	7 Ext. Cord	Tested OK		Randy
5-1-09	Shop	4" & 9" Grinders	None Found		Randy
5-1-09	Shop	Magnetic & Hand Drills	None Found		Randy
5-1-09	Shop	1 Welder	None Found		Randy

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
5-1-09	Shop	Bandsaw	None found		R. Canty 4-20-09
5-1-09	Bath house	Water Heaters	None found		R. Canty 4-20-09
5-8-09	Shop	Crane	None found		R. Canty 4-20-09
5-8-09	Shop	Air Compressor	out of service		R. Canty 4-20-09
Weekly tests of grounding devices (diodes)					
5-8-09	Shop	4" x 9" Grounders	None found		R. Canty 4-20-09
5-8-09	Shop	1-2 Power box	No mat	Corrected	R. Canty 4-20-09
5-8-09	Shop	2 Ext Cord	Tested OK		R. Canty 4-20-09
5-8-09	Bathroom	Water Heaters	None found		R. Canty 4-20-09
5-8-09	Shop	Bandsaw	None found		R. Canty 4-20-09
5-8-09	Shop	Magnetic Hand Drills	None found		R. Canty 4-20-09
Monthly examinations of methane monitors					
5-8-09	Shop	1 Welder	None found		R. Canty 4-20-09
5-8-09	Shop	Shop	Needed cleaned	Corrected	R. Canty 4-20-09
5-15-09	Shop	Air Compressor	out of service		R. Canty 4-20-09

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Inspector
5-15-09	Shop	CRANE	None Found		K. [Signature]
5-15-09	Bathhouse	Water Heaters	None Found		K. [Signature]
5-15-09	Shop	2 Ext Cord	Tested OK		K. [Signature]
5-15-09	Shop	Magnetic + Hand Drills	None Found		K. [Signature]
5-15-09	Shop	4" x 9" Grinders	None Found		K. [Signature]
5-15-09	Shop	1 + 2 Power box	No mat	Corrected	K. [Signature]
5-15-09	Shop	1 + 2 + 3 FANS	None Found		K. [Signature]
5-15-09	Shop	BANDSAW	None Found		K. [Signature]
Examinations of low- medium-voltage power circuit breakers (monthly)					
5-15-09	Shop	1 Welder	Cable Damaged	Corrected	K. [Signature]
5-15-09	Shop	Gas Welder	No Ground Clamp	Corrected	K. [Signature]
5-15-09	Shop	Shop	Weld Clamp	Corrected	K. [Signature]
5-21-09	Shop	CRANE	None Found		K. [Signature]
5-21-09	Shop	Air Compressor	None Found		K. [Signature]



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
5-21-09	Shop	1-2-3 Fans	None Found		Kantel 4-207
5-21-09	Shop	1-2 Power box	None Found		Kantel 4-207
5-21-09	Shop	2 Ext Cord	Tested OK		Kantel 4-207
5-21-09	Shop	4'x9" Genset	None Found		Kantel 4-207
Weekly tests of grounding devices (diodes)					
5-21-09	Shop	Magnetic & Hand Drills	None Found		Kantel 4-207
5-21-09	Shop	1 Welder	Cable Damaged	Coated	Kantel 4-207
5-21-09	Shop	Gas Welder	None Found		Kantel 4-207
5-21-09	Shop	Bandsaw	None Found		Kantel 4-207
5-21-09	Bathroom	Water Heaters	None Found		Kantel 4-207
5-29-09	Shop	Shop	Need Change	Corrected	Kantel 4-207
Monthly examinations of methane monitors					
5-29-09	Shop	Crane	None Found		Kantel 4-207
5-29-09	Shop	Air Compressor	out of Service		Kantel 4-207
5-29-09	Shop	1 Welder	Cable Damaged	Corrected	Kantel 4-207

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Inspector
5-29-09	Shop	Magnetic & Hand Drills	None Found		[Signature]
5-29-09	Shop	#2 Ext Cord	Tested OK		[Signature]
5-29-09	Shop	BANDSAW	None Found		[Signature]
5-29-09	Shop	1 & 2 Power Box	no mat	Corrected	[Signature]
5-29-09	Shop	1 & 2-3 FANS	None Found		[Signature]
5-29-09	Shop	4" & 9" Grinders	None Found		[Signature]
5-29-09	Bathhouse	Water Heaters	None Found		[Signature]
6-5-09	Shop	Shop	Trash needs take out	Corrected	[Signature]
Examinations of low- medium-voltage power circuit breakers (monthly)					
6-5-09	Shop	Crank	None Found		[Signature]
6-5-09	Shop	Air Compressor	None Found		[Signature]
6-5-09	Shop	4" & 9" Grinders	None Found		[Signature]
6-5-09	Shop	BANDSAW	None Found		[Signature]
6-5-09	Shop	1 & 2 Power box	no mat	Corrected	[Signature]

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
6-5-09	Shop	2 Ext Cord	Tested OK		<i>[Signature]</i> 4-2019
6-5-09	Shop	1 Welder	Cable damaged	Corrected	<i>[Signature]</i> 4-2019
6-5-09	Bathroom	Water Heaters	None Found		<i>[Signature]</i> 4-2019
6-5-09	Shop	Magnetic Hand Drills	None Found		<i>[Signature]</i> 4-2019
Weekly tests of grounding devices (diodes)					
6-5-09	Shop	1-2-3 Fans	None Found		<i>[Signature]</i> 4-2019
6-12-09	Shop	Shop	overhead Fan inoperative	Reported	<i>[Signature]</i> 4-2019
6-12-09	Shop	1-2-3 Fans	None Found		<i>[Signature]</i> 4-2019
6-12-09	Shop	1-2 Power box	None Found		<i>[Signature]</i> 4-2019
6-12-09	Bathroom	Water Heaters	None Found		<i>[Signature]</i> 4-2019
6-12-09	Shop	2 Ext Cord	Tested OK		<i>[Signature]</i> 4-2019
Monthly examinations of methane monitors					
6-12-09	Shop	4" x 9" Grinders	None Found		<i>[Signature]</i> 4-2019
6-12-09	Shop	Magnetic Hand Drills	None Found		<i>[Signature]</i> 4-2019
6-12-09	Shop	1 welder	Cable damaged	Corrected	<i>[Signature]</i> 4-2019

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
6-12-09	Shop	Crane	None Found		R. Canty
6-12-09	Shop	Air Compressor	None Found		R. Canty
6-12-09	Shop	Bandsaw	None Found		R. Canty
6-19-09	Shop	Shop	overhaul Fan impervative	made Forecast for Repair	R. Canty
6-19-09	shop	Crane	None Found		R. Canty
6-19-09	Shop	Air Compressor	None Found		R. Canty
6-19-09	Bathroom	Water Heaters	None Found		R. Canty
6-19-09	Shop	4" x 9" Grinders	None Found		R. Canty
Examinations of low- medium-voltage power circuit breakers (monthly)					
6-19-09	Shop	Bandsaw	None Found		R. Canty
6-19-09	Shop	Magnetic Hand Drills	None Found		R. Canty
6-19-09	Shop	1-2 Power box	None Found		R. Canty
6-19-09	Shop	1-2-3 Fans	None Found		R. Canty
6-19-09	Shop	1 Welder	Cable changed	Corrected	R. Canty
6-19-09	Shop	2 Ext. Cord	Tested OK		R. Canty

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
6-26-09	Shop	Shop	overhead Fan magnetic	Reported	R. Canty 4-204
6-26-09	Shop	CRANE	None Found		R. Canty 4-204
6-26-09	Shop	Air Compressor	None Found		R. Canty 4-204
6-26-09	Shop	#2 Ext. Cord	Tested OK		R. Canty 4-204
Weekly tests of grounding devices (diodes)					
6-26-09	Shop	Magnetic Hand Drills	None Found		R. Canty 4-204
6-26-09	Shop	BANDSAW	None Found		R. Canty 4-204
6-26-09	Bath house	Water Heaters	None Found		R. Canty 4-204
6-26-09	Shop	1-2-3 FANS	None Found		R. Canty 4-204
6-26-09	Shop	1-2 Power box	Mat too small	Corrected	R. Canty 4-204
6-26-09	Shop	1 Welder	Cable damage	Corrected	R. Canty 4-204
Monthly examinations of methane monitors					
6-26-09	Shop	4" x 9" Grinders	None Found		R. Canty 4-204
6-26-09	Shop	6 impact	None Found		R. Canty 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examined
7-3-09	Shop	Shop	None Found	Corrected	Keith 4-20-09
7-3-09	Shop	Crane	None Found		Keith 4-20-09
7-3-09	Shop	1-2 Power box	None Found		Keith 4-20-09
7-3-09	Shop	1-2-3 FAN	None Found		Keith 4-20-09
7-3-09	Shop	4" x 9" Grinders	None Found		Keith 4-20-09
7-3-09	Shop	Band saw	None Found		Keith 4-20-09
7-3-09	Bathroom	Water Heaters	None Found		Keith 4-20-09
7-3-09	Shop	#2 Ext Cord	Tested OK		Keith 4-20-09
Examinations of low- medium-voltage power circuit breakers (monthly)					
7-3-09	Shop	Magnetic Hand Drills	None Found		Keith 4-20-09
7-3-09	Shop	1/2 impact	None Found		Keith 4-20-09
7-3-09	Shop	1 Welder	None Found		Keith 4-20-09
7-3-09	Shop	Air Compressor	None Found		Keith 4-20-09

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
7-10-09	Shop	Crane	None Found		Raitz 4-2010
7-10-09	Shop	Air Compressor	None Found		Raitz 4-2010
7-10-09	Shop	Shop	Ground to small in 12 charges	Corrected	Raitz 4-2010
7-10-09	Bath house	Water Heaters	None Found		Raitz 4-2010
Weekly tests of grounding devices (diodes)					
7-10-09	Shop	4" & 9" Grinders	None Found		Raitz 4-2010
7-10-09	Shop	Magnetic & Hand Drills	None Found		Raitz 4-2010
7-10-09	Shop	2 Ext. Cord	Tested OK		Raitz 4-2010
7-10-09	Shop	1-2 Power box	None Found		Raitz 4-2010
7-10-09	Shop	1-2-3 Fans	None Found		Raitz 4-2010
7-10-09	Shop	1/2 impact	None Found		Raitz 4-2010
Monthly examinations of methane monitors					
7-10-09	Shop	1 welder	Damaged Cable	Corrected	Raitz 4-2010
7-10-09	Shop	Bandsaw	None Found		Raitz 4-2010

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
7-17-09	Shop	CRANE	None Found		R Cantley
7-17-09	Shop	Shop	1-2-13 Chargers have too small cable (ordered)		R Cantley
7-17-09	Shop	Air Compressor	None Found		R Cantley
7-17-09	Shop	4" x 9" Grinders	None Found		R Cantley
7-17-09	Bathhouse	Water Heaters	None Found		R Cantley
7-17-09	Shop	#2 Ext Cord	Tested OK		R Cantley
7-17-09	Shop	Magnetic Hand Drills	None Found		R Cantley
7-17-09	Shop	1-2 Power box	None Found		R Cantley
Examinations of low- medium-voltage power circuit breakers (monthly)					
7-17-09	Shop	1-2-3 FANS	None Found		R Cantley
7-17-09	Shop	BANDSAW	None Found		R Cantley
7-17-09	Shop	1 Welder	Cable damaged Coated		R Cantley
7-17-09	Shop	1/2" Impact	None Found		R Cantley
7-24-09	Shop	Shop	overhead Sw down	Reported	R Cantley





EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examined
7-28-09	Shop	Shop	overhead Fan impactive	Reported	Kent
7-28-09	shop	Air Compressor	None Found		Kent
7-28-09	shop	CRANE	None Found		Kent
7-28-09	shop	4" x 9" Grinders	None Found		Kent
7-28-09	shop	Magnetic + Hand Drills	None Found		Kent
7-28-09	shop	2 EXT Cord	Tested OK		Kent
7-28-09	shop	BANDSAW	None Found		Kent
7-28-09	Bathhouse	Water heaters	None Found		Kent
Examinations of low- medium-voltage power circuit breakers (monthly).					
7-28-09	Shop	1 Welder	None Found		Kent
7-28-09	shop	1-2 Power box	None Found		Kent
7-28-09	Shop	1-2-3 FANS	None Found		Kent
7-28-09	shop	1/2" impact	None Found		Kent
8-4-09	Shop	CRANE	None Found		Kent

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Inspector
8-4-09	Shop	Shop	overhead Fan inoperative	Repaired	Rault 4-20-09
8-4-09	Shop	Air Compressor	None Found		Rault 4-20-09
8-4-09	Shop	1-2 Power box	None Found		Rault 4-20-09
8-4-09	Shop	1-2-3 Fans	None Found		Rault 4-20-09
Weekly tests of grounding devices (diodes)					
8-4-09	Shop	4" x 9" Grinders	None Found		Rault 4-20-09
8-4-09	Bathhouse	Water Heaters	None Found		Rault 4-20-09
8-4-09	Shop	Hand Magnetic Drills	None Found		Rault 4-20-09
8-4-09	Shop	2 Ext Cord	Tested OK		Rault 4-20-09
8-4-09	Shop	Bandsaw	None Found		Rault 4-20-09
8-4-09	Shop	1/2 impact	None Found		Rault 4-20-09
Monthly examinations of methane monitors					
8-14-09	Shop	Crane	None Found		Rault 4-20-09
8-14-09	Shop	Shop	overhead Fan inoperative		Rault 4-20-09

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
8-11-09	Shop	Air Compressors	None Found		Rault 4-2009
8-11-09	Shop	4" & 9" Grinders	None Found		Rault 4-2009
8-14-09	Bathhouse	Water Heaters	None Found		Rault 4-2009
8-14-09	Shop	1-2 Power box	None Found		Rault 4-2009
8-14-09	Shop	1-2-3 FANS	None Found		Rault 4-2009
8-14-09	Shop	Magnetic & Hand Drills	None Found		Rault 4-2009
8-14-09	Shop	2 EXT Cord	Tested OK		Rault 4-2009
8-14-09	Shop	1/2 impact	None Found		Rault 4-2009
Examinations of low- medium-voltage power circuit breakers (monthly)					
8-14-09	Shop	BANDSAW	None Found		Rault 4-2009
8-14-09	Shop	1 Welder	None Found		Rault 4-2009
8-21-09	Shop	Shop	overhead Fan inoperative Reported		Rault 4-2009
8-21-09	Shop	Air Compressor	None Found		Rault 4-2009
8-21-09	Shop	CRANE	None Found		Rault 4-2009

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
8-21-09	Shop	4" x 9" Grinder	None Found		Rault 4-204
8-21-09	Shop	Magnetic & Hand Drill	None Found		Rault 4-204
8-21-09	Shop	1-2-3 Fans	None Found		Rault 4-204
8-21-09	Shop	2 Ext. Cord	Tested OK		Rault 4-204
Weekly tests of grounding devices (diodes)					
8-21-09	Bath house	Water Heaters	None Found		Rault 4-204
8-21-09	Shop	1/2 impact	None Found		Rault 4-204
8-21-09	Shop	Bandsaw	None Found		Rault 4-204
8-21-09	Shop	1 Welder	None Found		Rault 4-204
8-21-09	Shop	1-2 Power box	None Found		Rault 4-204
8-28-09	Shop	Shop	overhead Fw negative	Reported	Rault 4-204
Monthly examinations of methane monitors					
8-28-09	Shop	CRANE	None Found		Rault 4-204
8-28-09	Shop	Air Compressor	None Found		Rault 4-204
8-28-09	Bathhouse	Water Heaters	None Found		Rault 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examined by
8-28-09	Shop	1-2 Power box	None Found		Kant
8-28-09	Shop	1-2-3 FANS	None Found		Kant
8-28-09	Shop	4" + 9" Grinders	None Found		Kant
8-28-09	Shop	2 Ext. Cord	Tested OK		Kant
8-28-09	Shop	BANDSAW	None Found		Kant
8-28-09	Shop	1/2 impact	None Found		Kant
8-28-09	Shop	1 Welder	None Found		Kant
8-28-09	Shop	Magnetic & Hand Drills	None Found		Kant
9-3-09	Shop	Shop	Examinations of low- medium-voltage power circuit breakers (monthly) #2 120vlt circuit grounded > Reported over head Fan inoperative		Kant
9-3-09	Shop	CRANE	None Found		Kant
9-3-09	Shop	Air Compressor	None Found		Kant
9-3-09	Shop	1-2 Power box	None Found		Kant
9-3-09	Shop	1-2-3 FANS	None Found		Kant

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-3-09	Shop	Magnetic & Hand Drills	None Found		R. Canty 4-204
9-3-09	Shop	1 Welder	None Found		R. Canty 4-204
9-3-09	Shop	1/2 impact	None Found		R. Canty 4-204
9-3-09	Bathhouse	Water heaters	None Found		R. Canty 4-204
Weekly tests of grounding devices (diodes)					
9-3-09	Shop	#2 Ext Cord	Tested OK		R. Canty 4-204
9-3-09	Shop	4" & 9" Grinders	None Found		R. Canty 4-204
9-3-09	Shop	Bandsaw	None Found		R. Canty 4-204
9-11-09	Shop	Shop	Overhead Fmw repetitive	Reported	R. Canty 4-204
9-11-09	Shop	Crane	None Found		R. Canty 4-204
9-11-09	Shop	Air Compressor	None Found		R. Canty 4-204
Monthly examinations of methane monitors					
9-11-09	Shop	4" & 9" Grinders	None Found		R. Canty 4-204
9-11-09	Shop	Bandsaw	None Found		R. Canty 4-204
9-11-09	Bathhouse	Water Heaters	None Found		R. Canty 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examined
9-11-09	Shop	1-2 Power box	None Found		R. Cat 4-2009
9-11-09	Shop	1-2-3 Fans	None Found		R. Cat 4-2009
9-11-09	Shop	1 Welder	Cable damaged	Corrected	R. Cat 4-2009
9-11-09	Shop	1/2 impact	None Found		R. Cat 4-2009
9-11-09	Shop	Magnetic & Hand Drills	None Found		R. Cat 4-2009
9-11-09	Shop	#2 Ext. Cord	Tested OK		R. Cat 4-2009
9-17-09	Shop	Shop	overhead Fan inoperative No First Aid box	Reported Connected 9-21-09 RC	R. Cat 4-2009

Examinations of low-medium-voltage power circuit breakers (monthly)

9-17-09	Shop	CRANE	None Found		R. Cat 4-2009
9-17-09	Shop	Air Compressor	None Found		R. Cat 4-2009
9-17-09	Shop	1-2 Power box	None Found		R. Cat 4-2009
9-17-09	Shop	1-2-3 Fans	None Found		R. Cat 4-2009
9-17-09	Shop	4" & 9" Grinders	None Found		R. Cat 4-2009



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-17-09	Shop	Magnetic + Hand Drill	None found		R. Canty 4-204
9-17-09	Shop	#2 Ext Cord	Tested OK		R. Canty 4-204
9-17-09	Shop	1/2 impact wrench	None found		R. Canty 4-204
9-17-09	Shop	Band saw	None found		R. Canty 4-204
Weekly tests of grounding devices (diodes)					
9-17-09	Shop	1 welder	Cable damaged	Corrected	R. Canty 4-204
9-17-09	Bathhouse	water heaters	None found		R. Canty 4-204
9-25-09	Shop	Shop	overhead Fan inoperative	Reported	R. Canty 4-204
9-25-09	Shop	Crank	None found		R. Canty 4-204
9-25-09	Shop	2 Ext Cord	Tested OK Jacket Damaged	Corrected	R. Canty 4-204
9-25-09	Shop	1-2 Power box	None found		R. Canty 4-204
Monthly examinations of methane monitors					
9-25-09	Shop	1-3 Fans 2 Fan	None found Ground Pin missing on plug	Take out of Service	R. Canty 4-204
9-25-09	Bathhouse	Water Heaters	None found		R. Canty 4-204
9-25-09	Shop	1/2 impact wrench	None found		R. Canty 4-204

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
9-25-09	Shop	Magnetic & Hand Drills	None Found		Randy
9-25-09	Shop	Bandsaw	None Found		Randy
9-25-09	Shop	4" & 9" Grinders	None Found		Randy
9-25-09	Shop	Air Compressor	None Found		Randy
9-25-09	Shop	1 Welder	Cable Damaged	Corrected	Randy
9-30-09	Shop	Shop	overhead Fan inoperative		Randy
9-30-09	Shop	CRANC	First Aid box missing out of Service PARTS ordered	Corrected 10-7-09	Randy
9-30-09	Shop	Air Compressor	None Found		Randy
Examinations of low-medium-voltage power circuit breakers (monthly)					
9-30-09	Shop	4" & 9" Grinders	None Found		Randy
9-30-09	Shop	Magnetic & Hand Drills	None Found		Randy
9-30-09	Shop	1-2 Power box	None Found		Randy
9-30-09	Shop	2 Ext. Cord	Tested OK		Randy
10-2-09	Shop	1-2-3 Fans	None Found		Randy

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-2-09	Shop	1/2 impact wrench	None found		R. Canty 4-2009
10-2-09	Shop	Bandsaw	None found		R. Canty 4-2009
10-2-09	Shop	1 welder	Cable damaged	Corrected	R. Canty 4-2009
10-2-09	Bath	Water Heaters	None found		R. Canty 4-2009
Weekly tests of grounding devices (diodes)					
10-9-09	Shop	Shop	overhead Fan inoperative	Reported	R. Canty 4-2009
10-9-09	Shop	Crane	lift inoperative	Corrected	R. Canty 4-2009
10-9-09	Shop	yearly check made by Air Compressor	Crane American	10-6-09	R. Canty 4-2009
10-9-09	Shop	1/2 impact wrench	None found		R. Canty 4-2009
10-9-09	Shop	Magnetic Hand Drills	None found		R. Canty 4-2009
10-9-09	Shop	#2 Ext Cord	Tested OK		R. Canty 4-2009
Monthly examinations of methane monitors					
10-9-09	Shop	1-2-3 Fans	None found		R. Canty 4-2009
10-9-09	Bathroom	Water Heaters	None found		R. Canty 4-2009
10-9-09	Shop	1-2 Power box	None found		R. Canty 4-2009

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Remarks
10-9-09	Shop	BANDSAW	None Found		Plan 4-204
10-9-09	Shop	4" & 9" Grinder	None Found		Plan 4-204
10-9-09	Shop	1 Welder	None Found		Plan 4-204
10-16-09	Shop	Shop	OVERHEAD Fan Inoperative NO MAT AT DISCONNECT switch	Repair by Cuddock corrected 4-765	
10-16-09	Shop	CRANE	NONE Found		W - Cuddock 4-765
10-16-09	Shop	Air compressor	NONE Found		W - Cuddock 4-765
10-16-09	Shop	3 Impact wrench	NONE Found		W - Cuddock 4-765
10-16-09	Shop	Magnetic & Hand Drills	NONE Found		W - Cuddock 4-765
Examinations of low- medium-voltage power circuit breakers (monthly)					
10-16-09	Shop	#2 EAT Cord	Tested OK		W Cuddock 4-765
10-16-09	Shop	1-2-3 Fans	NONE Found		W Cuddock 4-765
10-16-09	Bathhouse	Water Heaters	NONE Found		W Cuddock 4-765
10-16-09	Shop	1 & 2 power Box	NONE Found		W Cuddock 4-765
10-16-09	Shop	Band saw	NONE Found		W Cuddock 4-765
10-16-09	Shop	4" & 9" Grinder	NONE Found		W Cuddock 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-16-09	Shop	1 welder	NONE Found		M. Cuddock 4-765
10-23-09	Shop	Shop	OVERHEAD Fan Inoperative no mat at Heater Disconnect	Reported Corrected	M. Cuddock 4-765
10-23-09	Shop	CRANE	NONE Found		M. Cuddock 4-765
10-23-09	Shop	Air compressor	NONE Found		M. Cuddock 4-765
10-23-09	Shop	½ Input wrench <small>Weekly tests of grounding devices (diodes)</small>	NONE Found		M. Cuddock 4-765
10-23-09	Shop	magnetic & stud Drills	NONE Found		M. Cuddock 4-765
10-23-09	shop	#2 EXT cord	Tested OK		M. Cuddock 4-765
10-23-09	Shop	1-2-3 Fans	NONE Found		M. Cuddock 4-765
10-23-09	Shop	Water Heater's	NONE Found		M. Cuddock 4-765
10-23-09	Shop	1 & 2 Power Box	NONE Found		M. Cuddock 4-765
10-23-09	Shop	Band saw <small>Monthly examinations of methane monitors</small>	NONE Found		M. Cuddock 4-765
10-23-09	Shop	4" & 9" Grinders	NONE Found		M. Cuddock 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-29-09	Shop	Shop	overhead Fan down	Reported	Randy
10-29-09	Shop	Air Compressor	None Found		Randy
10-29-09	Shop	CRANE	None Found		Randy
10-29-09	Shop	4" & 9" Grinders	None Found		Randy
10-29-09	Shop	Band SAW	None Found		Randy
10-29-09	Shop	1-2 Bus box	mat missing	Corrected	Randy
10-29-09	Shop	1-2-3 Fans	None Found		Randy
10-29-09	Bathhouse	Water Heaters	None Found		Randy
Examinations of low- medium-voltage power circuit breakers (monthly)					
10-29-09	Shop	#2 Ext. Coil	Tested OK		Randy
10-29-09	Shop	1 Welder	None Found		Randy
10-29-09	Shop	Magnetic Hand Drills	None Found		Randy
10-29-09	Shop	1/2 impact wrench	None Found		Randy
11-6-09	Shop	Shop	OVERHEAD Fan Inoperative	Reported	M. Waddell
11-6-09	Shop	Air Compressor	None Found		M. Waddell

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-6-09	Shop	CRANE	none Found		M Custody 4-765
11-6-09	shop	4" & 9" Grinders	none Found		M Custody 4-765
11-6-09	shop	Bandsaw	none Found		M Custody 4-765
11-6-09	shop	1-2 Power Box	none Found		M Custody 4-765
Weekly tests of grounding devices (diodes)					
11-6-09	Shop	1-2-3 Fans	none Found		M Custody 4-765
11-6-09	Shop	Water Heaters	none Found		M Custody 4-765
11-6-09	Shop	#2 EXT Cord	Tested no Ground	Corrected.	M Custody 4-765
11-6-09	Shop	magnetic & hand Drills	none Found		M Custody 4-765
11-6-09	shop	1/2 Impact wrench	none Found		M Custody 4-765
11-6-09	shop	welder	mat missing	Corrected	M Custody 4-765
Monthly examinations of methane monitors					
11-13-09	shop	overhead Fan is Inoperative		Reported	M Custody 4-765
11-13-09	shop	Air Compressor	mat missing	Corrected	M Custody 4-765
11-13-09	shop	CRANE	CRANE Inoperative	Corrected	M Custody 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-13-09	Shop	4 & 9" Grinder	Bel wheel on 4"	Corrected	M. Caddock 4-765
11-13-09	Shop	Band saw	none Found		M. Caddock 4-765
11-13-09	Shop	1 & 2 Power Box	none Found		M. Caddock 4-765
11-13-09	Shop	1-2-3 Fans	none Found		M. Caddock 4-765
11-13-09	Shop	Water Heaters	none Found		M. Caddock 4-765
11-13-09	Shop	#2 EXT cord	Tested OK		M. Caddock 4-765
11-13-09	Shop	magnetic ch. that Pills	none Found		M. Caddock 4-765
11-13-09	Shop	1/2" Impact wrench	none Found		M. Caddock 4-765
Examinations of low- medium-voltage power circuit breakers (monthly)					
11-13-09	Shop	welder	none Found		M. Caddock 4-765
11-20-09	Shop	Shop	OVER HEAD Fan Inoperative	Reported	M. Caddock 4-765
11-20-09	Shop	Air compressor	Matt's missing	Corrected	M. Caddock 4-765
11-20-09	Shop	CRANE	none Found		M. Caddock 4-765
11-20-09	Shop	4" & 9" Grinder	Bel wheel on 9"	Corrected	M. Caddock 4-765
11-20-09	Shop	Band saw	none Found		M. Caddock 4-765



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
11-20-09	shop	1 & 2 Power Box	none Found		M Gubbins 4-765
11-20-09	shop	1-2-3 Fans	none Found		M Gubbins 4-765
11-20-09	shop	Water Heaters	none Found		M Gubbins 4-765
11-20-09	shop	#2 EXJ Coed	Tested Ok		M Gubbins 4-765
Weekly tests of grounding devices (diodes)					
11-20-09	shop	magnetic & Hand Drills	none Found		M Gubbins 4-765
11-20-09	shop	3/4" Impact wrench	none Found		M Gubbins 4-765
11-20-09	shop	welder	mat missing	Corrected	M Gubbins 4-765
12-4-09	shop	OVER Head Fan	Inoperative	Reported	M Gubbins 4-765
12-4-09	shop	Air Compressor	none Found		M Gubbins 4-765
12-4-09	shop	CRANE	none Found		M Gubbins 4-765
Monthly examinations of methane monitors					
12-4-09	shop	4" & 9" Grinders	none Found		M Gubbins 4-765
12-4-09	shop	Bark saw	none Found		M Gubbins 4-765
12-4-09	shop	1 & 2 Power Box	none Found		M Gubbins 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-4-09	Shop	1-2-3 Fans	none Found		M Waddock 4-765
12-4-09	Shop	Water Heaters	none Found		M Waddock 4-765
12-4-09	Shop	#2 EXT cord	Tested ok		M Waddock 4-765
12-4-09	Shop	Magnetic & Hand Drill	none Found		M Waddock 4-765
12-4-09	Shop	$\frac{1}{2}$ " Impact wrench	none Found		M Waddock 4-765
12-4-09	Shop	welder	none Found		M Waddock 4-765
12-11-09	Shop	OVER Head Fan 1st Box	Inoperative 1 Box missing	Reported Reported	M Waddock 4-765
12-11-09	Shop	Air compressor	none Found		M Waddock 4-765
Examinations of low- medium-voltage power circuit breakers (monthly)					
12-11-09	Shop	CRANE	none Found		M Waddock 4-765
12-11-09	Shop	4" & 9" Grinders	none Found		M Waddock 4-765
12-11-09	Shop	Band saw	none Found		M Waddock 4-765
12-11-09	Shop	1 & 2. Power Box	nut missing	corrected	M Waddock 4-765
12-11-09	Shop	1-2-3 Fans	#2 Fan nick in power cord	corrected	M Waddock 4-765
12-11-09	Shop	Water Heaters	none Found		M Waddock 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-11-09	Shop	#2 Ext cord	wire in rocks	Corrected	M Craddock 4-765
12-11-09	Shop	Magnetic & Ind. Drill	no Def. Insulation		M Craddock 4-765
12-11-09	Shop	1/2" Impact wrench	none Found		M Craddock 4-765
12-11-09	Shop	Welder	none Found		M Craddock 4-765
Weekly tests of grounding devices (diodes)					
12-18-09	Shop	OVERHEAD fan Inoperative 1st Add Boxes missing		Reported	M Craddock 4-765
12-18-09	Shop	Air Compressor	none Found		M Craddock 4-765
12-18-09	Shop	CRANE	none Found		M Craddock 4-765
12-18-09	Shop	4" & 9" Bandsaws	none Found		M Craddock 4-765
12-18-09	Shop	Bandsaw	none Found		M Craddock 4-765
12-18-09	Shop	1 & 2 Power Box	nut missing	corrected	M Craddock 4-765
Monthly examinations of methane monitors					
12-18-09	Shop	1-2-3 Fans	none Found		M Craddock 4-765
12-18-09	Shop	Water Heaters	none Found		M Craddock 4-765
12-18-09	Shop	#2 Ext cord	Tested ok		M Craddock 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-18-09	Shop	magnetic & hand drills	none Found		M. Cuthbert 4-765
12-18-09	shop	1/2" Impact wrench	none Found		M. Cuthbert 4-765
12-18-09	shop	Welder	mat missing	corrected	M. Cuthbert 4-765
12-23-09	shop	Overhead Fan Insensitive		Reported	M. Cuthbert 4-765
12-23-09	shop	#1 1st Axd Box missing Air compressor	none Found	Reported	M. Cuthbert 4-765
12-23-09	shop	CRANE	none Found		M. Cuthbert 4-765
12-23-09	shop	4" & 9" Grinders	none Found		M. Cuthbert 4-765
12-23-09	shop	Bandsaw	none Found		M. Cuthbert 4-765
Examinations of low- medium-voltage power circuit breakers (monthly)					
12-23-09	shop	1 & 2 Power Boxes	none Found		M. Cuthbert 4-765
12-23-09	shop	1-2-3 Fans	none Found		M. Cuthbert 4-765
12-23-09	shop	Water Heaters	none Found		M. Cuthbert 4-765
12-23-09	shop	#2 Ext cord	none Found		M. Cuthbert 4-765
12-23-09	shop	Magnetic & Hand Drills	none Found		M. Cuthbert 4-765
12-23-09	shop	1/2" Impact wrench	none Found		M. Cuthbert 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
12-23-09	shop	welder	nick in outer insulation on the positive lead	corrected	M Waddock 4-765
12-31-09	shop	Overhead Fan	Inoperative	Reported	M Waddock 4-765
12-31-09	shop	#1 1st Ayl Box seals Air compressor	Broken missing none Found		M Waddock 4-765
12-31-09	shop	CRANE	none Found		M Waddock 4-765
12-31-09	shop	4" & 9" Grinders	none Found		M Waddock 4-765
<small>Weekly tests of grounding devices (diodes)</small>					
12-31-09	shop	Bandsaw	cord damaged	corrected	M Waddock 4-765
12-31-09	shop	1 & 2 Power Box	none Found		M Waddock 4-765
12-31-09	shop	1-2-3 Fans	none Found		M Waddock 4-765
12-31-09	shop	water heaters	none Found		M Waddock 4-765
12-31-09	shop	#2 Box cord	Tested OK		M Waddock 4-765
<small>Monthly examinations of methane monitors</small>					
12-31-09	shop	Magnetic & Band Drills	none Found		M Waddock 4-765
12-31-09	shop	½ Impact wrench	none Found		M Waddock 4-765
12-31-09	shop	welder	none Found		M Waddock 4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner	
1-8-10	Shop	OVER HEAD Fan Inoperative Seals missing on #1 & #2	1/2" oil seals	Reported	M. L. Ladd	1-
1-8-10	Shop	Air compressor	none Found		M. L. Ladd	1-
1-8-10	Shop	CRANE	none Found		M. L. Ladd	1-
1-8-10	Shop	4" & 9" Grinders	none Found		M. L. Ladd	1-
1-8-10	Shop	Band saw	none Found		M. L. Ladd	1-
1-8-10	Shop	1 & 2 Power Box	nut missing	corrected	M. L. Ladd	1-
1-8-10	Shop	1-2-3 Fans	none Found		M. L. Ladd	1-
1-8-10	Shop	Water Heaters	none Found		M. L. Ladd	1-
<del>Examinations of low medium-voltage power circuit breakers (monthly)</del>						
1-8-10	Shop	#2 EXT. cord	Damaged	Replaced	M. L. Ladd	1-
1-8-10	Shop	Magnetic & Hand Drills	Beard Repair		M. L. Ladd	1-
1-8-10	Shop	1/2" Impact wrench	none Found		M. L. Ladd	1-
1-8-10	Shop	welder	none Found		M. L. Ladd	1-
1-15-10	Shop	OVER HEAD Fan Inoperative seals missing on #1 & #2	1st oil seal	Reported	M. L. Ladd	1-
1-15-10	Shop	Air compressor	none Found	Reported	M. L. Ladd	1-

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-15-10	Shop	CRANE	NONE Found		M. Galtsook 4-765
1-15-10	Shop	4" & 9" Grinders	NONE Found		M. Galtsook 4-765
1-15-10	Shop	Brush saw	NONE Found		M. Galtsook 4-765
1-15-10	Shop	1 & 2 Power Box	NONE Found		M. Galtsook 4-765
<del>Weekly tests of grounding devices (diodes)</del>					
1-15-10	Shop	1-2-3 Fans	NONE Found		M. Galtsook 4-765
1-15-10	Shop	Water Heaters	NONE Found		M. Galtsook 4-765
1-15-10	Shop	#2 EXT cord	NONE Found		M. Galtsook 4-765
1-15-10	Shop	Magnetic & Heat Pills	NONE Found		M. Galtsook 4-765
1-15-10	Shop	5 Impact wrench	NONE Found		M. Galtsook 4-765
1-15-10	Shop	Welder	Bad cut in Insulation on positive Electrode holder	Corrected	M. Galtsook 4-765
<del>Monthly examinations of methane monitors</del>					

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-22-10	Shop	1 Welder	None Found		R. Kelly
1-22-10	Shop	Shop	Needed Check Ok head fan down	Concited (Reported)	R. Kelly
1-22-10	shop	1/2 impact	None Found		R. Kelly
1-22-10	shop	4" x 9" Grinder	None Found		R. Kelly
1-22-10	shop	2 Ext Cord	Tested OK		R. Kelly
1-22-10	Shop	Magnetic Hand Drills	None Found		R. Kelly
1-22-10	Shop	CRAWC	None Found		R. Kelly
1-22-10	Shop	Air Compressor	None Found		R. Kelly
Examinations of low- medium-voltage power circuit breakers (monthly)					
1-22-10	Bathhouse	Water Heaters	None Found		R. Kelly
1-22-10	Shop	Bandsaw	None Found		R. Kelly
1-22-10	shop	1-2 Power box	None Found		R. Kelly
1-22-10	Shop	1-2 Fans	None Found		R. Kelly
1-30-10	shop	shop	Overheat Fan Inoperative	Reported	M. Giddoch
1-30-10	shop	Air compressor	None Found		M. Giddoch



# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-30-10	Shop	CRANE	NONE Found		M. W. Ladd 4-765
1-30-10	Shop	4" & 9" Grinders	NONE Found		M. W. Ladd 4-765
1-30-10	Shop	Band saw	NONE Found		M. W. Ladd 4-765
1-30-10	Shop	1 & 2 power Box	no missing	Corrected	M. W. Ladd 4-765
<del>Weekly tests of grounding devices (diodes)</del>					
1-30-10	Shop	1 & 2 Fans	NONE Found		M. W. Ladd 4-765
1-30-10	Shop	Water Heaters	NONE Found		M. W. Ladd 4-765
1-30-10	Shop	#2 Bat coil	Tested ok		M. W. Ladd 4-765
1-30-10	Shop	Magnetic & Steel Pkts	NONE Found		M. W. Ladd 4-765
1-30-10	Shop	5 Impact wrench	NONE Found		M. W. Ladd 4-765
1-30-10	Shop	welder	NONE Found		M. W. Ladd 4-765
<del>Monthly examinations of methane monitors</del>					

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Engineer
2-5-10	Shop	CRANE	None found		[Signature]
2-5-10	Shop	Air Compressor	None found		[Signature]
2-5-10	Shop	2-3 FANS	None found		[Signature]
2-5-10	Shop	1-2 Power box	No mat	Corrected	[Signature]
2-5-10	Shop	4" x 9" Grinders	None found		[Signature]
2-5-10	Shop	1 Welder	Cable damage	Corrected	[Signature]
2-5-10	Shop	1/2 impact	None found		[Signature]
2-5-10	Shop	Magnetic Hand Drills	None found		[Signature]
Examinations of low- medium-voltage power circuit breakers (monthly)					
2-5-10	Bath house	Water Heaters	None found		[Signature]
2-5-10	Shop	#2 Ext Cord	Tested OK		[Signature]
2-5-10	Shop	Bandsaw	None found		[Signature]
2-5-10	Shop	Shop	overhead Fan operation	Reported	[Signature]
2-10-10	Shop	OVERHEAD Fan	Inoperative	Reported	M. Whitlock
2-12-10	Shop	CRANE	Fire extinguisher missing	Corrected	M. Whitlock
			None found		4-765

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-12-10	Shop	Air compressor	nut was missing	Corrected	M. Laddock 4-765
2-12-10	Shop	#2-3 Fans	none found		M. Laddock 4-765
2-12-10	Shop	1-2 Power Box	none found		M. Laddock 4-765
2-12-10	Shop	4" & 9" Grinders	none found		M. Laddock 4-765
Weekly tests of grounding devices (diodes)					
2-12-10	Shop	welder	none found		M. Laddock 4-765
2-12-10	Shop	1/2 Impact	none found		M. Laddock 4-765
2-12-10	Shop	Magnetic & thrust drills	none found		M. Laddock 4-765
2-12-10	Bath house	water heaters	none found		M. Laddock 4-765
2-12-10	Shop	#2 Ext cord	Test ok		M. Laddock 4-765
2-12-10	Shop	Band saw	none found		M. Laddock 4-765
Monthly examinations of methane monitors					
2-19-10	Shop	Crane	None found		R. Canty 4-207
2-19-10	Shop	Air Compressor	None found		R. Canty 4-207
2-19-10	Shop	1-2 Power box	No mat	Corrected	R. Canty 4-207

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-19-10	Shop	2 Ext. Cord	Tested OK		Kathy
2-19-10	Bathhouse	Water Heaters	None Found		Kathy
2-19-10	Shop	4 1/2 in Grinder	None Found		Kathy
2-19-10	Shop	Magnetic & Hand Drill	None Found		Kathy
2-19-10	Shop	1/2 impact	None Found		Kathy
2-19-10	Shop	1 Welder	Cable Damage	Corrected	Kathy
2-19-10	Shop	Bandsaw	None Found		Kathy
2-19-10	Shop	Shop	None Found		Kathy
2-19-10	Shop	2+3 FAN	overhead FAN inoperative	Reported	Kathy
2-25-10	Shop	Air Compressor	None Found		Kathy
2-25-10	Shop	CRANE	None Found		Kathy
2-25-10	Shop	Shop	overhead FAN inoperative	Reported	Kathy
2-25-10	Bathhouse	Water Heaters	None Found		Kathy

Examinations of low- medium-voltage power circuit breakers (monthly)

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
2-25-10	Shop	Magnetic Hand Drills	None Found		Kantley
2-25-10	Shop	4" & 9" Grinders	None Found		Kantley
2-25-10	Shop	1+2 Power Box	None Found		Kantley
2-25-10	Shop	2+3 FADS	out of Service		Kantley
Weekly tests of grounding devices (diodes)					
2-25-10	Shop	1 Welder	None Found		Kantley
2-25-10	Shop	1/2 impact	None Found		Kantley
2-25-10	Shop	Bandsaw	None Found		Kantley
2-25-10	Shop	2 Ext. Cord	Tested OK		Kantley
3-5-10	Shop	CRAW	None Found		Kantley
3-5-10	Shop	Air Compressor	None Found		Kantley
Monthly examinations of methane monitors					
3-5-10	Shop	Shop	Air Cylinder test against charge (corrected)		Kantley
3-5-10	Shop	1-2 Power box	None Found		Kantley
3-5-10	Shop	#2 Ext Cord	Tested OK		Kantley

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Inspector
3-5-10	Shop	4x9" Grinders	None Found		Kant
3-5-10	Shop	Bandsaw	None Found		Kant
3-5-10	Shop	Magnetic + Hand Drills	None Found		Kant
3-5-10	Bathhouse	Water Heaters	None Found		Kant
3-5-10	2+3 Fans	out of Service			Kant
3-5-10	Shop	#1 Welder	None Found		Kant
3-11-10	Shop	Shop	None Found		Kant
3-11-10	Shop	Crane	None Found		Kant
Examinations of low- medium-voltage power circuit breakers (monthly)					
3-11-10	Shop	Air Compressor	None Found		Kant
3-11-10	Shop	1/2 impact	None Found		Kant
3-11-10	Shop	4"x9" Grinders	None Found		Kant
3-11-10	Shop	1 Welder	None Found		Kant
3-11-10	Shop	1+2 Power box	None Found		Kant
3-11-10	Bathhouse	Water Heaters	None Found		Kant

# EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Signature
3-11-10	Shop	2+3 FANS	out of Service		Randy
3-11-10	Shop	Magnetic + Hand Drills	None Found		Randy
3-11-10	Shop	BANDSAW	None Found		Randy
3-11-10	Shop	2 EXT. Cord	Tested OK		Randy
Weekly tests of grounding devices (diodes)					
3-18-10	Shop	Shop	2 overhead lights out	Corrected	Randy
3-18-10	Shop	CRACK	None Found		Randy
3-18-10	Shop	Air Compressor	None Found		Randy
3-18-10	Shop	2 EXT. Cord	Tested OK		Randy
3-18-10	Shop	1-2 Power boxes	None Found		Randy
3-18-10	Shop	2-3 FANS	out of Service		Randy
Monthly examinations of methane monitors					
3-18-10	Shop	Magnetic + Hand Drills	None Found		Randy
3-18-10	Shop	1 Welder	None Found		Randy
3-18-10	Shop	4 1/2" Grinders	None Found		Randy

# EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Remarks
3-18-10	Shop	1/2 impact wrench	Noise Sound		Ready
3-18-10	Bathhouse	Water Heaters	Noise Sound		Ready
3-18-10	Shop	BANDSAW	Noise Sound		Ready
3-25-10	Shop	Shop	Needle cleaned	Covered	Ready 4-204
3-25-10	Shop	Air compressor	Noise Sound		Ready 4-204
3-25-10	Bathhouse	Water Heaters	Noise Sound		Ready 4-204
3-25-10	Shop	2 & 3 FAN	out of Service		Ready 4-204
3-25-10	Shop	1 & 2 Power box	no mat	Covered	Ready 4-204
3-25-10	shop	4" & 9" Grinders	Noise Sound		Ready 4-204
3-25-10	Shop	BANDSAW	Noise Sound		Ready 4-204
3-25-10	Shop	1/2 impact wrench	Noise Sound		Ready 4-204
3-25-10	Shop	1 Welder	Damaged Cable	Covered	Ready 4-204
Examinations of low- medium-voltage power circuit breakers (monthly)					
3-25-10	Shop	CRANE	Noise Sound		Ready 4-204
3-25-10	Shop	2 Ext Cord	Tested OK		Ready 4-204
3-25-10	Shop	Magnetic & Hand Drills	Noise Sound		Ready 4-204