

Move Boxes

EXAMINATION OF ELECTRICAL EQUIPMENT

Company PERFORMANCE COPT CO.
Mine UBB.
Location MOON Raleigh W.V.
 Post Office County State

Re-order from
BJW Printing and
Office Supplies
P. O. Box 1309
Beckley, W. Va. 25801
Phone (304) 253-7361

Form 6—1492
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. This book is approved by the Director of The West Virginia Department of Mines and The U. S. Bureau of Mines.

8
fo
40

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3,10,07	MOUTH OF NORTH MAINS	MOVE BOX SERIAL # 16640-150-202	Ground faulted breakers. Found two monitors SPD (REPLACED)		
		Installed new E-Stop button. one breaker will not set (Tagged out of service)	No other dangerous conditions found at time of examination	Pat Vialar	4-250

Weekly tests of grounding devices (diodes)

6-30-08	MOVE BOX # 1 Located at # 8 BAK AT MOUTH OF # 7 SECTION. Need's new E-stop button and bracket welds? FOR TOP LID (Estop covered)	Pat Vialar 4-250
6-30-08	MOVE BOX # 2 located at # 106 BAK AT NORTH MAINS. No dangerous conditions found on Box.	Pat Vialar 4-250

Weekly electrical exam

Monthly examinations of methane monitors

8-5-09 Move box being used on the south side of the mine to have a 14/15 cm found shield not bolted down found bolts and bolted lid down No other dangerous conditions found at time of exam with/Drub-3752

EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10.14.09	Southside Motor Barn	#1 Move Box Ser. #1451	Top lid need Bolted Down	Put Bolts in lid	DT
		Read Ground Res. 38 ohms			
		Tested E Stop OK			
		Ground Faulted 995 Breaker using Test Button OK			
					D. W. Huggins NR2681

Examinations of low- medium-voltage power circuit breakers (monthly)

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
10-14-09	#3 Section	#2 move Box 16640-150202	2 RoHs missing in lid		
		NO lids on 480 receptacles	Cable pull out of Box	Repaired	
		Read Ground Res	38 ohms		Will Bross 345-1
10-30-09	14 BK South Side	#2 move Bolts	No Bolts in lid	Replaced Bolts	
		Ground Faulted 995V Breaker	using Test Switch	OK	
		Checked E Stop	OK		D Taraszkowy NR2681

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors