

Started 8-31-09
Ended 10-16-09

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

U1BB #1 BANDYTOWN FAN

Company PERFORMANCE COAL CO

Mine UPPER BIG BRANCH

Location BANDYTOWN BLEEDER FAN

Post Office

County

State

Reorder from
Chapman Printing
(800) 999-2471
Form # MS-021

Form 6-1491
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. **Do not** mail this book to the Bureau of Mines.

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-31-09

Time 11:20 AM

Fan BRADY TOWN BLEEDER FAN

Location BRADY TOWN

Fan Operating Properly ye

Water Gage Pressure 2.6"

Fan Signal Check (monthly) 8-31-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made 8-31-09

Remarks or changes FIRST DAY OF NEW

FAN OPERATION

Signed Paul Thompson
(examiner) called in

[Signature]
Mine Foreman Mine Manager

3700000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-1-09

Time 12:30 PM

Fan Brady Town Bleeder Fan

Location Brady town

Fan Operating Properly yes

Water Gage Pressure 2.7"

Fan Signal Check (monthly) 8-31-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed Paul Thomason
(examiner) Called In

Paul Thomason
Mine Foreman Mine Manager

33333
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-2-09

Time 10:20 AM

Fan BADBY TOWN BLEEDER FAN

Location BADBY TOWN

Fan Operating Properly YES

Water Gage Pressure 2.9"

Fan Signal Check (monthly) 8-31-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed PAUL THOMPSON
(EXAMINER)
CHIEF EN

Charles Galt
Mine Foreman Mine Manager

7906009
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-3-09

Time 9:10 AM

Fan Bardy Tower Bleeder Fan

Location Bardy Tower

Fan Operating Properly yes

Water Gage Pressure 4 1/2

Fan Signal Check (monthly) 8-31-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed PAAL THOMPSON
(examiner) called in

Paul Cook
Mine Foreman Mine Manager

396000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-4-09

Time 10:30 AM

Fan BANDY tower Bleeder Fan

Location BANDY tower

Fan Operating Properly yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 8-31-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed [Signature]
(examiner) 4250

[Signature]
Mine Foreman Mine Manager

3206000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-5-09

Time 10:00 PM

Fan Bandy town bleeder Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 4.0"

Fan Signal Check (monthly) 8-31-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made 8-31-09

Remarks or changes

Signed Paul Thompson
(examiner)

Called In

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-6-09
Time 12:12 AM

Fan Bandy town bleeder Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 4.0"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-31-09

Remarks or changes Shut down fan checked alarm & doors

Signed Paul Thompson
(examiner)
Called In

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/7/09
Time 9:30 AM

Fan BANDY TOWN BLEEDER FAN

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 4.0"

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made NONE

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made NONE

Remarks or changes NONE

Signed Paul Hyman
(examiner)
8-4031

Chris Cook
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/8/09

Time 11:30 AM

Fan BANDY TOWN Bleeder FAN

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 4.0"

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made NONE

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made NONE

Remarks or changes NONE

Signed Paul Myers
(examiner)
8-4031

[Signature]
Mine Foreman Mine Manager

3306000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-9-09

Time 2:00 PM

Called IN By Paul Thompson

Fan Bandy Town Bleeder Fan

Location Bandy Town

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) ok on 8-31-09

Previous Check Made none

Automatic Closing Doors (monthly) ok 8-31-09

Previous Examination Made none

Remarks or changes none

Took call by
Signed John Hambro NAW 3410
(examiner)

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/10/09

Time 10:00 AM

Fan UBB BANDY TOWN #1 FAN

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 4.2"

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made NONE

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made NONE

Remarks or changes NONE

Signed Paul Thym
(examiner)
8-4031

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-11-09 (Friday)
Time 1:00 Pm

Fan Bandy Town URB #1 Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) OK on 8-31-09

Previous Check Made None

Automatic Closing Doors (monthly) OK on 8-31-09

Previous Examination Made None

Remarks or changes None

Signed Colin Fowley
(examiner)
4-4310

[Signature]
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/12/09 (SAT)
Time 11:35pm

Fan URB #1 FAN BANOY TOWN

Location BANOY TOWN

Fan Operating Properly YES

Water Gage Pressure 4.2"

Fan Signal Check (monthly) OK ON 8-31-09

Previous Check Made NONE

Automatic Closing Doors (monthly) OK ON 8-31-09

Previous Examination Made NONE

Remarks or changes NONE

Signed Paul Myers
8-4031

Chris Cook
Mine Foreman Mine Manager

21111111
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/13/09 (Sunday)
Time 12:10 AM

Fan UBB #1 FAN BANDYTOWN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.2"

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made NONE

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made NONE

Remarks or changes NONE

Signed Paul Thym
(examiner)
8-4031

Paul Thym
Mine Foreman Mine Manager

390600
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-14-09
Time 1:41 PM

Fan UBB #1 Fan Bandy Town

Location Bandy Town

Fan Operating Properly YES

Water Gage Pressure 4.2"

Fan Signal Check (monthly) OK on 8-31-09

Previous Check Made none

Automatic Closing Doors (monthly) OK on 8/31/09

Previous Examination Made none

Remarks or changes none

Called in By Paul Thompson Took By
Signed John Henley
(examiner)

[Signature]
Mine Foreman Mine Manager

290000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-16-09

Time 5:30 AM

Fan UBB#1 FAN BARDY TOWN

Location Bardy Town

Fan Operating Properly Yes

Water Gage Pressure 4.3

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made none

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made none

Remarks or changes Before Fan OK

FAN IS RUNNING REPORTED BY ADAM JENKINS
at 5:30 AM Chager 26041

Greased FAN, P.T.

Signed [Signature] 1550
(examiner)
Paul Dyer

[Signature]
Mine Foreman Mine Manager

390600
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/17/09

Time 9:30 AM

Fan UBB #1 FAN, BANDYTOWN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.3"

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made NONE

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made NONE

Remarks or changes

9/17/09 4:30 AM Fan is running Eltager 26041

Signed Paul Hym
(examined) 6-4031

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/18/09

Time 11:30 AM

Fan YBB #1 FAN BANDY TOWN

Location BANDY TOWN

Fan Operating Properly Yes

Water Gage Pressure 4.3"

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made none

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made none

Remarks or changes none

Signed Paul Myers
(examiner) 8-4031

Charles Cant
Mine Foreman Mine Manager

3506022
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/19/09

Time 9:30 AM

Fan UBB #1 Fan Bandy town

Location Bandy town

Fan Operating Properly yes

Water Gage Pressure 4.3

Fan Signal Check (monthly) OK on 8/31/09

Previous Check Made none

Automatic Closing Doors (monthly) OK on 8/31/09

Previous Examination Made none

Remarks or changes None

called in by Paul Thompson
Signed Paul Thompson (Mining)

Paul Thompson
Mine Foreman Mine Manager

350000
Certificate Number

Paul Thompson
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-20-09

Time 1:15 PM

Fan VBB #1 Fan Bandytown Fan

Location Bandytown 1

Fan Operating Properly yes

Water Gage Pressure 4.5

Fan Signal Check (monthly) ok on 8-31-09

Previous Check Made None

Automatic Closing Doors (monthly) ok on 8-31-09

Previous Examination Made None

Remarks or changes _____

Called in By Paul Thompson
Signed Danny Laverty NR-2882
(examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/21/9

Time 4:40 AM

Fan UBB #1 Fan Bandy town fan

Location Bandy Town

Fan Operating Properly Yes

Water Gage Pressure 4.5

Fan Signal Check (monthly) OK on 8-31-09

Previous Check Made None

Automatic Closing Doors (monthly) OK on 8-31-09

Previous Examination Made None

Remarks or changes

Fan is running AT 4:30 AM Eltagu 26241

Signed William J. Graham 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

26241
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/22/09

Time 8:00 AM

Fan WBB #1 FAN BANDYTOWN

Location BANDYTOWN

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) OK ON 8/31/09

Previous Check Made NONE

Automatic Closing Doors (monthly) OK ON 8/31/09

Previous Examination Made NONE

Remarks or changes NONE

Signed Paul Thompson
(examiner)
8-4031

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

[Signature]
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-23-09
Time 11:50 PM

Fan UBB # 1 Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 8-31-09

Previous Check Made None

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made None

Remarks or changes Called in by Paul Thompson

Signed W. H. Deane 3752
(EXAMINER)

Paul Thompson
Mine Foreman Mine Manager

3706422
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-24-09

Time 12:49 AM

Fan UBB #1 Fan

Location Bandy Town

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 8-31-09

Previous Check Made None

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made None

Remarks or changes Called in by Paul Thompson

Signed *William J. Smith* 3-15-2
(examiner)

Paul Thompson
Mine Foreman Mine Manager

3306000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-25-09
Time 10:55 AM

Fan UBB #1 Fan

Location BANDY TOWER

Fan Operating Properly yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 8-31-09

Previous Check Made none

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made none

Remarks or changes Called In by PHIL THOMPSON

Signed Phil Thompson 4-250
(examiner)

Chris Cook
Mine Foreman Mine Manager

3300
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-26-09

Time 11:36 PM

Fan 400#1 Fan

Location Bandy Town

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 8-31-09

Previous Check Made none

Automatic Closing Doors (monthly) 8-31-09

Previous Examination Made none

Remarks or changes Called in by Paul Thompson

Signed [Signature] 8-11
(examiner)

[Signature]
Mine Foreman Mine Manager

3904000
Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-27-09

Time 1:30 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes Called in by Paul Thompson

FAN signal check ~~at~~ 7:30 AM.

Federal Inspector @ UBB verify ALARM.

(see Athen)

Signed T.E. Sheets 8-11
(examiner)

[Signature]
Mine Foreman Mine Manager

350000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/28/09

Time 4:45 PM

Fan WBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 9/27/09 ~~scribble~~

Previous Check Made ~~scribble~~ 8/31/09

Automatic Closing Doors (monthly) 9/27/09

Previous Examination Made 8/31/09

Remarks or changes NONE

Signed Paul [Signature]
(examiner)
8-4031

[Signature]
Mine Foreman Mine Manager

3906008
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9/29/09

Time 8:30 AM

Fan LIBB # 1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.5" 9/27/09

Fan Signal Check (monthly) ~~8/31/09~~ 9/27/09

Previous Check Made ~~8/31/09~~ 8/31/09

Automatic Closing Doors (monthly) ~~9/27/09~~ 9/27/09

Previous Examination Made 8/31/09

Remarks or changes none

Signed Paul J. [Signature]
(examiner)
8-4031

[Signature]
Mine Foreman Mine Manager

39 [Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-30-09

Time 3:30 P.M.

Fan U.B.B. / Fan

Location BANDY TOWN

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes Called in by Paul Thompson

Signed Virgil [Signature]
(examiner)
4249

[Signature]
Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-1-09

Time 8:55 PM

Fan UBB 1 Fan

Location Bandy Town

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes Called in By Paul Thompson

Signed John Henley NW 63540
(Examiner)

Paul Thompson
Mine Foreman Mine Manager

Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-2-09

Time 10:30 Am

Fan UBB #1 Fan

Location Bandy town

Fan Operating Properly YES

Water Gage Pressure 4.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes

Signed Chas Farley 4-431
(examiner)

Chas Farley 5900000
Mine Foreman Mine Manager Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-3-09

Time 9:30 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly yes

Water Gage Pressure 3.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed Cal Fowley / 4-431
(examiner)

Charles Cook
Mine Foreman Mine Manager

3506
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-4-09
Time 7:30 AM

Fan UBB #1 Fan

Location Bandy Town

Fan Operating Properly Yes

Water Gage Pressure 3.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes

*Called In By Paul Thompson 8403
Received By William J. Drah 3-152*

Signed _____
(examiner)

Paul Thompson
Mine Foreman Mine Manager

3306000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-5-09
Time 11:48 AM

Fan VBB #1 Fan

Location Brady Town

Fan Operating Properly Yes

Water Gage Pressure 3.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes _____

*Called in by Poyl Thompson 8-403
Received by [Signature] 5-152*

Signed _____
(examiner)

[Signature]
Mine Foreman Mine Manager

324100
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-6-09
Time 9:00 AM

Fan UBB #1 Fan

Location Bandy Town

Fan Operating Properly Yes

Water Gage Pressure 3.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-07

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-07

Remarks or changes

Called in by Paul Thompson

Signed _____ (examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10/7/09

Time 1:30 pm

Fan U8B #1 FAN

Location RANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 3.7"

Fan Signal Check (monthly) 9/27/09

Previous Check Made 8/31/09

Automatic Closing Doors (monthly) 9/27/09

Previous Examination Made 8/31/09

Remarks or changes none

Signed Paul Hyman
(examiner)
8-4031

Paul Cat
Mine Foreman Mine Manager

38000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-8-09

Time 10:30 Am

Fan UBB #1 Fan

Location Bandy four

Fan Operating Properly Yes

Water Gage Pressure 3.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes

Signed Calvin Farley
(examiner) 4431

Calvin Farley
Mine Foreman Mine Manager

3500000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-9-09
Time 11:00 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 3.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed Col Fealy
(examiner) 4431

Col Fealy
Mine Foreman Mine Manager

39062
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10/10/09

Time 11:50 pm

Fan UBB #1 FAN

Location BANNY TOWN

Fan Operating Properly YES

Water Gage Pressure 3.5"

Fan Signal Check (monthly) OK ON 9/27/09

Previous Check Made 8/3/09

Automatic Closing Doors (monthly) 9/27/09

Previous Examination Made 8/3/09

Remarks or changes Greased FAN NONE

Signed [Signature] (examiner) Sr 4031

[Signature] Mine Foreman Mine Manager

3501000 Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10/11/09

Time 12:15 Am

Fan UBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 3.5"

Fan Signal Check (monthly) OK on 9/27/09

Previous Check Made 8/31/09

Automatic Closing Doors (monthly) 9/27/09

Previous Examination Made 8/31/09

Remarks or changes none

Signed Paul Thyr
(EXAMINER)
8-4031

[Signature]
Mine Foreman Mine Manager

2302000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-12-09
Time 8:35 AM

Fan UBB # 1 FAN

Location BANDY TOWN

Fan Operating Properly yes

Water Gage Pressure 3.5"

Fan Signal Check (monthly) ok on 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes _____

Called in by Paul Thord.
Signed Paul Thord
(examiner) 4-250

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10/13/09 (TUE)

Time 11:00 AM

Fan URB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 3.5"

Fan Signal Check (monthly) OK ON 9/27/09

Previous Check Made 8/31/09

Automatic Closing Doors (monthly) 9/27/09

Previous Examination Made 8/31/09

Remarks or changes NONE

Signed Paul Myers (examiner) 8-4031

Mine Foreman Mine Manager

3501000 Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-14-09
Time 4:00 PM

Fan UBD # 1 Fan

Location Bandy town

Fan Operating Properly yes

Water Gage Pressure 3.5"

Fan Signal Check (monthly) OK on 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed Mind Vindoe
(examiner) 4250
(Checked in by PAAL Thompson)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10/15/09

Time 1:15pm

Fan LIBB #1 FAN

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 3.6"

Fan Signal Check (monthly) OK ON 9/27/09

Previous Check Made 8/31/09

Automatic Closing Doors (monthly) OK ON 9/27/09

Previous Examination Made 8/31/09

Remarks or changes NONE

Signed Paul Myers
(examiner) 8-4031

Paul Myers
Mine Foreman Mine Manager

394000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-16-09
Time 10:05 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 3.5

Fan Signal Check (monthly) OK on 9-27-09

Previous Check Made 8-31-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 8-31-09

Remarks or changes _____

Signed C. Faulk
(examiner) 4457

[Signature]
Mine Foreman Mine Manager

3301000
Certificate Number

Superintendent or Assistant