

South FAN

Started 1-14-10

Full

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Started 9-10-06

Company Performance Coal
Mine UBB
Location NAOMA Raleigh W.V.A.
Post Office County State

TO RE-ORDER
This is Form 6-1491

Quality Forms Printing
P.O. Box 861
Sophia, WV 25921
(304) 252-1363

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-14-10

Time 12:15 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 12-19-09

Previous Check Made 12-13-09

Automatic Closing Doors (monthly) 12-19-09

Previous Examination Made 12-13-09

Remarks or changes

Signed B Shrewsbury
(examiner)
8-4018

Rick Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-15-10

Time 12:30 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 12-19-09

Previous Check Made 12-13-09

Automatic Closing Doors (monthly) 12-19-09

Previous Examination Made 12-13-09

Remarks or changes

Signed D. Shrewsbury
(examiner)

Rick Foster
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-16-10

Time 12:40 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 12-19-09

Previous Check Made 12-13-09

Automatic Closing Doors (monthly) 12-19-09

Previous Examination Made 12-13-09

Remarks or changes

Signed G Shrewsbury
(examiner)

8-4018

Reed Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-17-10

Time 2:05 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Motor bearing's / Placed three rope's back on pulley's & Adjusted drive belts

Signed William J. Smith 3-152
(examiner)

Rock Foster
Mine Foreman—Mine Manager

28232
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-18-10

Time 10:15 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 18"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes _____

Signed B Shrewsbury
(examiner)

8-4018

Reck Jeter
Mine Foreman—Mine Manager

2873
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-19-10

Time 1:35 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed D Shrewsbury
(examiner)

8-4018

Bob Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-20-10

Time 5:25 AM

Fan Seath

Location Seath Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes _____

Signed [Signature]
(examiner)

[Signature]
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-21-10

Time 5:05 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed J.P. [Signature]
(examiner)

Rick Foster
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-22-10

Time 5:10 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed [Signature]
(examiner)

[Signature]
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-23-10

Time 5:00 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.8

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed [Signature] 8-11
(examiner)

Rick Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 01-24-10

Time 6:00 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.9"

Fan Signal Check (monthly) 01-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 01-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed D. Lavery NR-2882
(examiner)

Rick Zista
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-25-10

Time 6:05 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed TC Adams 9-11
(examiner)

Rick Felt
Mine Foreman—Mine Manager

2873
Certificate Number

[Signature]
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-26-10

Time 5:20AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed DE Sheets 8-11
(examiner)

Rich Jasta
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-27-10

Time 5:55 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Changed chart, greased fan, inboard 97°, outboard 124°

~~Battery dead for chart recorder~~

Signed J. E. Sharts 8-11
(examiner)

Rich Foster
Mine Foreman—Mine Manager

28232
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-28-10

Time 5:30 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0''

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed W E Sheets 8-11
(examiner)

Rick Futa
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-29-10

Time 5:00AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.1"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes _____

Signed DE White
(examiner)

Resh Ester
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent, or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-30-10

Time 4:35AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.1"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Water gauge frozen

Signed J. E. Sheets 8-11
(examiner)

Rick Foster
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 01-31-10

Time 7:55 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 01-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 01-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed D. L. [Signature] NR-2882
(examiner)

[Signature]
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-1-10

Time 5:40AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 2.0''

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed J E Sheets 8-11
(examiner)

Rick Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-2-10

Time 8:10 AM

Fan # South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.8

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Water gage Frozen

Signed V E Skeets 8-91
(examiner)

Rob Zelen
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-3-10

Time 5:25AM

Fan South

Location South Fan

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Water gauge frozen, changed chart, greased fan bearings,
inboard 97°, outboard 118°, checked audible alarm

Signed T. E. Shute 8-11
(examiner)

Rock Foster
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-4-10

Time 5:25 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed V.E. Shute 8-11
(examiner)

Paul Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-5-10

Time 3:15 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure ~~1-17-10~~ 2.0"

Fan Signal Check (monthly) ~~12-19-09~~ 1-17-10

Previous Check Made ~~1-17-10~~ 12-19-09

Automatic Closing Doors (monthly) ~~12-19-09~~ 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed W E Sheets 8-11
(examiner)

Rich Fister
Mine Foreman—Mine Manager

2873L
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/6/10

Time 5:40AM

Fan South

Location South portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes

Signed V. Bowman
(examiner)
4249

Rick Foster
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-7-10

Time 11:50 Pm

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed D Shrewsbury
(examiner)
8-4018

Rick Foster
Mine Foreman—Mine Manager

28234
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-8-10

Time 5:15 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0ⁱⁿ

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed [Signature]
(examiner)

[Signature]
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-9-10

Time 4:45 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0''

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed JC Smith 8-11
(examiner)

Rick Foster
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-10-16

Time 6:20 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Changed chart, wound clock, greased fan bearings, greased motor bearings, inboard 92°, outboard 125°

Signed [Signature] 8-11
(examiner)

[Signature]
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-11-10

Time 4:40AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0''

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed W.C. Skates 2-11
(examiner)

Rick Foster
Mine Foreman—Mine Manager

23734
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-12-10

Time 4:50 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed J C Sheets 8-11
(examiner)

Bob Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/13/10

Time 6:00AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes _____

Signed Bobby Goss
(examiner)

Rick Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/14/10

Time 10:40 Am

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes _____

Signed Paul Shyne
(examiner) 8-4037

Rick Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/15/10

Time 4:35 pm

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes _____

Signed Paul Thompson
(examiner) 8-4031

Beck Jeter
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/16/10

Time 6:35 Am

Fan South

Location South portal

Fan Operating Properly Yes

Water Gage Pressure 20"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/17/09

Remarks or changes

Signed 4-249 V. Bowman
(examiner)

Rich Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/17/10

Time 6:40 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes Changed chart greased bearings

Signed V. Bowman
(examiner)
4-249

Rich Foster
Mine Foreman—Mine Manager

29734
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/18/10

Time 5:10

Fan South

Location South portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes

Signed [Signature]
(examiner)
4-249

[Signature]
Mine Foreman—Mine Manager

29736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/19/10

Time 6:00 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes Monthly Fan check

Checked doors, ROPES, Fan Alarm

and greased motor Bearings

Dean Turley 4-138

Signed V. Brown
(examiner)
4-249

Paul Foster
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-20-10

Time 4:35 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 2-19-10

Previous Check Made 1-19-10

Automatic Closing Doors (monthly) 2-19-10

Previous Examination Made 1-19-10

Remarks or changes

Signed [Signature]
(examiner)

[Signature]
Mine Foreman—Mine Manager

23230
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/21/10

Time 10:55 AM

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 2/19/10

Previous Check Made 1/17/10

Automatic Closing Doors (monthly) 2/19/10

Previous Examination Made 1/17/10

Remarks or changes

Signed Paul Thyrer
(examiner)
24031

Rich Fisher
Mine Foreman—Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-22-10

Time 5:30 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 2-19-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-19-10

Previous Examination Made 1-17-10

Remarks or changes _____

Signed T E Sheets 8-11
(examiner)

Rick Foster Mine Foreman—Mine Manager 29236 Certificate Number _____ Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/23/10

Time 6:10 Am

Fan South

Location South portal

Fan Operating Properly Yes

Water Gage Pressure 20"

Fan Signal Check (monthly) 2/19/10

Previous Check Made 1/17/10

Automatic Closing Doors (monthly) 2/19/10

Previous Examination Made 1/17/10

Remarks or changes

Signed V. Boman
(examiner)
4-249

Rick Foster
Mine Foreman—Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-26-10

Time 4:55 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 2-19-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-19-10

Previous Examination Made 1-17-10

Remarks or changes

Signed [Signature]
(examiner)

[Signature]
Mine Foreman—Mine Manager

26736
Certificate Number

Superintendent or Assistant