

South Side Tan
Started 8-26-09
Ended 10-12-09

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Company Performance Coal Co.
Mine UBB
Location Naoma Raleigh WV
Post Office County State

Reorder from
Chapman Printing
(800) 999-2471
Form # MS-021

Form 6-1491
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. **Do not** mail this book to the Bureau of Mines.

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-26-09

Time 12:29 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes Replaced chart & greased fan bearings

IN Beard 125°

Out Beard 120°

Signed William J. Johnson 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-27-09

Time 12:15 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.6

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed Randy D. Singh
(examiner)

[Signature]
Mine Foreman Mine Manager

31222
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-28-09

Time 11:32 PM

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.7

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed [Signature] 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

39016000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-29-09
Time 9:49 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed Willie D. Smith 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-30-09

Time 11:51 PM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.9

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed Bill [Signature]
(examiner)

[Signature]
Mine Foreman Mine Manager

312008
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-31-09

Time 1:00 AM

Fan SOUTH

Location SOUTH Portal

Fan Operating Properly yes

Water Gage Pressure 1.7

Fan Signal Check (monthly) 8-09-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-09-09

Previous Examination Made 7-12-09

Remarks or changes

Signed *William Caldwell*
(examiner)

Chris Lamb
Mine Foreman Mine Manager

3901001
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-1-09

Time 7:55 AM

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.6

Fan Signal Check (monthly) 8-09-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-09-09

Previous Examination Made 7-12-09

Remarks or changes

Signed *[Signature]*
(examiner)

[Signature]
Mine Foreman Mine Manager

3300000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-2-09

Time 7:08 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.7"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed [Signature] 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-3-09

Time 5:06 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.5"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes Replaced chart & greased bearing's

In board 124°

Out board 124°

Signed W. J. Graham 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3906000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-4-09

Time 5:10 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed S Shrewsbury
(examiner) 9-4018

Robert Cook
Mine Foreman Mine Manager

3506001
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-5-09

Time 11:45 Pm

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.2"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed S. Shrewsbury 8-4018
(examiner)

[Signature]
Mine Foreman Mine Mucker

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-6-09

Time 2:28 Am

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.2

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Greased motor Bearings

Checked Self Closing Doors

Checked fan Signal

calibrated Water Gauge

Signed D Shrewsbury
(examiner) 8-4018

Calvin Cook
Mine Foreman Mine Manager

350000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-7-09

Time 11:47 PM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Drake 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-8-09
Time 12:27 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed Willie J. Durham 3-152
(examiner)

Carl Cook
Mine Foreman Mine Manager

350000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-9-09

Time 9:53 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.4

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Replaced chart & greased Fan bearings

in bond 124°

out bond 124°

Signed William J. Drosche 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

39000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-10-09

Time 12:00 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.2"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed [Signature] 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

350
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-11-09
Time 12:24 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed William J. Smith 3-152
(examiner)

John L. ...
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-12-09
Time 1:05 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.0"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Embury 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

35012000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-13-2009

Time ~~11:29~~ 11:59 am

Fan South

Location South Porter

Fan Operating Properly yes

Water Gage Pressure 1.0"

Fan Signal Check (monthly) 9-6-2009

Previous Check Made 8-9-2009

Automatic Closing Doors (monthly) 9-6-2009

Previous Examination Made 8-9-2009

Remarks or changes

Signed [Signature] 3442
(examiner)

[Signature]
Mine Foreman Mine Manager

390008
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-14-09
Time 11:05 PM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.1"

Fan Signal Check (monthly) ~~8~~ 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Doherty 3-152
(examiner)

Carl [Signature]
Mine Foreman Mine Manager

3560000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-15-09

Time 1:14 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.1"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed Will J. Smith 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-16-09
Time 12:41 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.1"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Greased Fan bearing's & Replaced chart

inboard 105°

outboard 126°

Signed William J. Bisher 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-17-09
Time 12:39 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.0"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed *William Drake* 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

330600
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-18-09

Time 12:20 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.1"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed Adson T. Saley 3-363
(examiner)

Charles Cochran
Mine Foreman Mine Manager

3560000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-19-09

Time 1:15pm

Fan South

Location South portal

Fan Operating Properly Yes

Water Gage Pressure 1.0"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed V. Brown
(examiner)
4-249

[Signature]
Mine Foreman Mine Manager

3906000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 09-20-09

Time 10:15 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.6"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed Danny Havel NR-2882
(examiner)

Arthur Cook
Mine Foreman Mine Manager

3906000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-21-09
Time 12:18 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.2

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed Will J. Davis 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

5706000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-22-09

Time 12:43 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.1"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Sroba 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3500000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-23-09
Time 12:39 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Replaced Chart & Greased Fan Bearings also

Adjusted Chart to match U-tube

IN board 125

Outboard 127

Signed William D. ... 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3506000
Certificate Number

[Signature]
Superintendent

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-24-09

Time 12:29 AM

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.1"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed Adam Farley 3-363
(examiner)

[Signature]
Mine Foreman Mine Manager

3506001
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-25-09

Time 12:19 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.0

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed Willie J. Smith 3152
(examiner)

[Signature]
Mine Foreman Mine Manager

3506000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-26-09

Time 12:30 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.1"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed Adam Frealey 3-363
(examiner)

Charles [Signature]
Mine Foreman Mine Manager

35010000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-27-09

Time 6:15 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.0

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed S Shewsbury 8-4018
(examiner)

[Signature]
Mine Foreman Mine Manager

3306000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-28-09

Time 12:08 am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure .5"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed [Signature]
(examiner)

[Signature]
Mine Foreman Mine Manager

350000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-29-09

Time 12:15 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.0

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed D Shrewsbury 8-408
(examiner)

[Signature]
Mine Foreman Mine Manager

370000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-30-09
Time 12:30AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.1"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes Replaced chart, greased fan bearings, adjusted u-tube
and adjusted recorder chart

Inboard 124°

Outboard 127°

Signed [Signature] 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3721000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-31-09

Time 12:15 PM

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.2

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed *William G. [Signature]*
(examiner)

[Signature] *390000*
Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-2-09

Time 1205

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.1

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed [Signature]
(examiner)

[Signature]
Mine Foreman Mine Manager

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-3-09

Time 7:30 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.0

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed G. Shrewsbury
(examiner)

8-4018

[Signature]
Mine Foreman Mine Manager

3506200
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-4-09

Time 4:20 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.6

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed S Shrewsbury
(examiner)

8-4018

[Signature]
Mine Foreman Mine Manager

3506000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-5-09

Time 10:53 PM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed William J. Decker 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

3901000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-6-09
Time 12:18 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed William J. Disher 3452
(examiner)

Charles Cook
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-7-09

Time 1:00 AM

Fan South Fan

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.6"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes Replaced chart, greased bearing "fan" and
cleaned intake screen.

IN Board 120°

Out Board 126°

Signed [Signature] 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-8-09

Time 12:19 am

Fan South Side

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.5"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed John A. Price #4432
(examiner)

[Signature]
Mine Foreman Mine Manager

320000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-9-09
Time 12:55 AM

Fan South Side

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-26-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-26-09

Remarks or changes _____

Signed RL Will 4-535
(examiner)

[Signature]
Mine Foreman Mine Manager

5300
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-10-09

Time 12:45 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.0"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed Adson F. Foley 3-363
(examiner)

[Signature]
Mine Foreman Mine Manager

35422
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-11-09

Time 7:45 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.0"

Fan Signal Check (monthly) 09-27-09

Previous Check Made 09-06-09

Automatic Closing Doors (monthly) 09-27-09

Previous Examination Made 09-06-09

Remarks or changes

Signed D. Laverty NR-2882
(examiner)

[Signature]
Mine Foreman Mine Manager

3506008
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-12-09

Time 12:15 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.6"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed William Drahman 3152
(examiner)

[Signature]
Mine Foreman Mine Manager

350000
Certificate Number

Superintendent or Assistant