

Started 8-12-09
North Side Fan
Ended 9-28-09

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Company Performance Coal Co.

Mine UBB

Location Naoma Raleigh WV
Post Office County State

Reorder from
Chapman Printing
(800) 999-2471
Form # MS-021

Form 6-1491
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. **Do not** mail this book to the Bureau of Mines.

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-12-09
Time 12:19 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes Greased fan bearing's & Replaced chart

In. Board 117.8°

Out Board 122.0°

Signed [Signature] 3-152
(examiner)

[Signature] 37222
Mine Foreman Mine Manager

Certificate Number

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-13-09
Time 12:19 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed Anthony J. Decker
(examiner)

[Signature]
Mine Foreman Mine Manager

3202000
Certificate Number

[Signature]
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-14-09

Time 1:58 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed Walter J. Suter 3-152
Examiner

Charles Cook
Mine Foreman Mine Manager

3906028
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-15-09

Time 12:27 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed William J. Graham 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

3706002
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-16-09
Time 11:57 PM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed *Walter D. ...* 3-152
(examiner)

...
Mine Foreman Mine Manager

3300000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-17-09
Time 12:01 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed Antoine Duchesne 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-18-09

Time 8:06 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed William J. Graham 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3901201
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-19-09
Time 12:19 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes Replaced chart & greased fan bearings

in board 124.9°

out board 110.3°

Signed Wilho J. Drexler 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

322000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-20-09
Time 11:29 PM

Fan North

Location North Portal

Fan Operating Properly 7.3" Yes

Water Gage Pressure 7.3"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed William D. Dyer 3-152
(examiner)

Charles Lamb
Mine Foreman Mine Manager

3504000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-21-09

Time 3:38

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.3"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed William J. Brubaker 3-152
(examiner)

Arthur Cal

Mine Foreman Mine Manager

3906 out

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-22-09
Time 12:07 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.011

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed William D. ... 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3906008
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-23-09

Time 6:40 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 2.0"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed J. E. Richmond
(examiner)

[Signature]
Mine Foreman Mine Manager

3906000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8.24.09

Time 5.25 am

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 7.1"

Fan Signal Check (monthly) 8.9.09

Previous Check Made 7.12.09

Automatic Closing Doors (monthly) 8.9.09

Previous Examination Made 7.12.09

Remarks or changes

Signed [Signature]
(examiner)

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-25-09

Time 12:00 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.4"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed William J. Graham 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

3906000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-26-09
Time 12:09 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.3"

Fan Signal Check (monthly) 8-7-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-7-09

Previous Examination Made 7-12-09

Remarks or changes Replaced chart & greased fan bearing's

IN Barrel 119.9°

Out Barrel 134.2°

Signed William J. Decker 3-152
(examiner)

[Signature] Mine Foreman Mine Manager 3-152 Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-27-09

Time 12:10 AM.

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.2"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed Randy H. S. J.
(examiner)

[Signature]
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-28-09
Time ~~7~~ 11:45 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.24

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed *[Signature]* 3-152
(EXAMINER)

[Signature]
Mine Foreman Mine Manager

3906008
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-29-09
Time 9:56 AM

Fan Soot North

Location Sa S. North Portal

Fan Operating Properly Yes

Water Gage Pressure 7.2"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed Walter D. Brock 3152
(examiner)

Charles Cook
Mine Foreman Mine Manager

3500007
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-30-09

Time 11:56 PM

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 7.2

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed Bill [Signature]
(examiner)

[Signature]
Mine Foreman Mine Manager

3900 001
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 8-31-09

Time 1:25 PM

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 6.6

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes STARTED EXHAUST FAN

AT BRADY TOWN

Signed *William C. [Signature]*
(examiner)

[Signature]
Mine Foreman Mine Manager

380000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-1-09

Time 8:01 AM

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 6.5

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed William O. [Signature]
(examiner)

[Signature]
Mine Foreman Mine Manager

3906000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-2-09
Time 6:49 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 6.4

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes

Signed William D. Baker 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

2906001
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-3-09

Time 5:12 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 6.3"

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes Greased Fan bearings

Signed Will J. Grah 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3111111
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-4-09

Time 5:15 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 6.3

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed S Shrewsbury
(examiner) 8-408

[Signature]
Mine Foreman Mine Manager

3901000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-5-09

Time 11:30 Pm

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 6.2

Fan Signal Check (monthly) 8-9-09

Previous Check Made 7-12-09

Automatic Closing Doors (monthly) 8-9-09

Previous Examination Made 7-12-09

Remarks or changes _____

Signed J. Shrewsbury 8-3018
(examiner)

[Signature]
Mine Foreman Mine Manager

330000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-6-09

Time 2:40 Am

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 6.2

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Greased motor Bearings

checked Self Closing Doors

checked FAN Signal

calibrated Water GAUGE

Signed S Shrewsbury
(examiner) 8-4018

[Signature]
Mine Foreman Mine Manager

2501212
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-7-09
Time 11:51 PM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Graham 3-152
(examiner)

Carole Cook
Mine Foreman Mine Manager

390025
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-8-09
Time 12:30 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed William J. Drake 3-152
(examiner)

Andy Cook
Mine Foreman Mine Manager

3500000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-9-09
Time 9:58 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Replaced dust & greased fan bearings

in board 117.0°

out board 112.4°

Signed Willie Graham 5-152
(examiner)

[Signature]
Mine Foreman Mine Manager

350000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-10-09
Time 12:07 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed *Atkins* 3-152
(examiner)

John
Mine Foreman Mine Manager

3706000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-11-09
Time 12:33 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed [Signature] 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-12-09
Time 12:52 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Drake 3-152
(examiner)

Charles Cook
Mine Foreman Mine Manager

3506008
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-13-09
Time 12:54 P.M.

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.5"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

motors Temps are pretty Good lower than normal

Signed [Signature] C#4432
(examiner)

[Signature]
Mine Foreman Mine Manager

3906000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-14-09
Time 10:45 PM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Graham 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

350000
Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-15-09
Time 12:45 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William Spahn 3-152
(examiner)

John Cook
Mine Foreman Mine Manager

3202000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-16-09
Time 12:06 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Greased fan bearings & Replaced chart

in board 97.4°

out board 105.2°

Signed William D. ... 3152
(examiner)

Carl ...
Mine Foreman Mine Manager

3900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-17-09
Time 12:22 AM

Fan North

Location North Portal

Fan Operating Properly YES

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed *William J. Graham*
(examiner)

Charles
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-18-09

Time 12:30 AM

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed Adam F. Riley 3-363
(examiner)

Adam F. Riley
Mine Foreman Mine Manager

3-363
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-19-09

Time 1:00 P.M.

Fan North

Location north portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed V. Bauman
(EXAMINER)
4-249

[Signature]
Mine Foreman Mine Manager

346001
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 09-20-09

Time 10:00 AM

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 5.2"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed Danny Laverty (examiner) NR-2882

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-21-09

Time 12:03 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed William D. Brock 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

344009
Certificate Number

[Signature]
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-22-09
Time 12:34 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Durham 3-152
(examiner)

[Signature]
Mine Foreman Mine Manager

3546000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-23-09
Time 12:25 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes Replaced Chart & Greased fan bearing's

Inboard 141.3

Outboard 100.2

Signed William Brak - 3-52
(examiner)

[Signature]
Mine Foreman Mine Manager

3506000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-24-09

Time 12:21 AM

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed Adam F. Saley 3-363
(examiner)

Charles Lamb

Mine Foreman Mine Manager

3906000

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-25-09
Time ~~12:5~~ 12:23 AM

Fan North

Location North Portal

Fan Operating Properly Yes

Water Gage Pressure 5.3"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes _____

Signed William J. Suckan 3-152
(examiner)

Charles G. ...
Mine Foreman Mine Manager

320600X
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-26-09

Time 12:39 AM

Fan North

Location North Portal

Fan Operating Properly YES

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-6-09

Previous Check Made 8-9-09

Automatic Closing Doors (monthly) 9-6-09

Previous Examination Made 8-9-09

Remarks or changes

Signed Adam Eraley 3-363
(examiner)

Chris Lamb

Mine Foreman Mine Manager

3506000

Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-27-09

Time 6:00 Am

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 5.5

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27

Previous Examination Made 9-6-09

Remarks or changes

Signed D Shrewsbury 8-4018
(examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 9-28-09

Time 12:00 am

Fan North

Location North Portal

Fan Operating Properly yes

Water Gage Pressure 5.4"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed [Signature]
(examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant