

Started 10-13-02

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Fall 11-29-09

Company Performance Coal Co.
Mine UBB
Location Norma Raleigh NC
Post Office County State

Reorder from
Chapman Printing
(800) 999-2471
Form # MS-021

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall maintain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. **Do not** mail this book to the Department of Mines.

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-13-09

Time 12:25 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed William Graham 3-152
(examiner)

John Cook
Mine Foreman Mine Manager

7900000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-14-09

Time 12:45 Am

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes Replaced Chart

Greased Bearings

Signed D Shrewsbury
(examiner)
8-4018

[Signature]
Mine Foreman Mine Manager

[Signature]
Certificate Number

[Signature]
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-15-09

Time 1145 Pm

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed S. Shewberry
(examiner)

[Signature]
Mine Foreman Mine Manager

350000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-16-09

Time 12:10 Am

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed G Shrewsbury
(examiner)
8-4018

[Signature]
Mine Foreman Mine Manager

3500000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-17-09

Time 1:10 Am

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed D. Shrewsbury
(examiner) 8-4018

[Signature]
Mine Foreman Mine Manager

2302000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-18-09

Time 7:30 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.3"

Fan Signal Check (monthly) 09-27-09

Previous Check Made 09-06-09

Automatic Closing Doors (monthly) 09-27-09

Previous Examination Made 09-06-09

Remarks or changes _____

Signed D. Lavery NR-2882
(examiner)

[Signature]
Mine Foreman Mine Manager

320000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-19-09

Time 11:45 Pm

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed G Shrewsbury
(examiner) 8-4018

Rick Peter
Mine Foreman Mine Manager

28732
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-20-09

Time 10:44 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes _____

Signed *Willy Dosh* 3-152
(examiner)

Reed Fisher
Mine Foreman Mine Manager

28234
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-21-09

Time 12:25 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Changed chart

greased bearings

Signed D Shrewsbury
(examiner)

8-4018

Rich Ford
Mine Foreman Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-22-09

Time 12:05 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed Gregory Shewsbury
(examiner) 8-4018

Rich Foster
Mine Foreman Mine Manager

28234
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-23-09

Time 12:40 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made _____

Remarks or changes _____

Signed S Shewsbury
(examiner)

8-4018

Reef Fata
Mine Foreman Mine Manager

28232
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-24-09

Time 10:55 pm

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 9-27-09

Previous Check Made 9-6-09

Automatic Closing Doors (monthly) 9-27-09

Previous Examination Made 9-6-09

Remarks or changes

Signed D Shrewsbury
(examiner)
8-4018

Rick Fisher
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-25-09

Time 5:45-09

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes Shut fan down & checked alarm

& auto closing doors - OK

greased fan motor

Kevin Lyall was here for check

Signed S Shawsby
(examiner)
8-4018

Rick Jota
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-26-09

Time 10:41 Pm

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes _____

Signed D Shrewsbury
(examiner)
8-4018

Reik Foster
Mine Foreman Mine Manager

28734
Certificate Number

[Signature]
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-27-09

Time 11:40 P.M.

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) yes 10-25-09

Previous Check Made ~~10-25-09~~ 9-27-09

Automatic Closing Doors (monthly) ~~9-27-09~~ 10-25-09

Previous Examination Made ~~10-25-09~~ 9-27-09

Remarks or changes greased bearings

check

Signed D Shrewsbury
(examiner)
8-4018

Reck Jastr
Mine Foreman Mine Manager

28730
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-28-09

Time 12:30 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes changed chart

Signed J Shrewsbury
(examiner)
8-4018

Reik Foster
Mine Foreman Mine Manager

28734
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-29-09

Time 12:45 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed W. H. Smith 3-152
(examiner)

Reep J. ...
Mine Foreman Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-30-09

Time 12:20 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed D. Shrewsbury
(examiner)
8-4018

Rick Foster
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 10-31-09

Time 6:35 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes _____

Signed D. J. [Signature] NR-2882
(Examiner)

Mine Foreman Mine Manager Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-1-09
Time 3:30 PM

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.8

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes _____

Signed John Arline N/A 43540
(examiner)

Rick Foster
Mine Foreman Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-2-09

Time 12:08 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.8

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed Walter D. Schum 3-152
(examiner)

Rich Foster
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-3-09

Time 12:55

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed D Shrewsbury
(examiner)
8-4018

Rich Foster
Mine Foreman Mine Manager

28732
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-4-09

Time 1:55 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes replaced chart

greased fan

Signed S Shrewsbury
(examiner)

8-4018

Reck Foster
Mine Foreman Mine Manager

28734
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-5-09

Time 10:50 Pm

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed G Shrewsbury
(examiner)

8-4018

Rick Foster
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-6-09

Time 12:40 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed D Shrewsbury
(examiner)

8-4018

Rick Foster
Mine Foreman Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-7-09

Time 12:22am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes _____

Signed [Signature]
(examiner)
#4432

[Signature]
Mine Foreman Mine Manager

28223
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-08-09
Time 6:33 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.5"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed D. Tereby NR-2882
(Examiner)

Rich Foster
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-9-09
Time 6:27 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 1.7"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes _____

Signed *Walter Smith* 3-152
(examiner)

Rick Foster
Mine Foreman Mine Manager

29734
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-10-09

Time 12:40 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed D Shrewsbury
(examiner)
8-4018

Rich Foster
Mine Foreman Mine Manager

28236
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-11-09

Time 12:44 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes changed chart
greased fan bearings

Signed D Shewsbury
(examiner)

Rick Foster
Mine Foreman Mine Manager

28731
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-11-09

Time 12:40 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed D Shrewsbury
(examiner)
8-4018

Rick Zehn
Mine Foreman Mine Manager

2873
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-13-09

Time 11:45 PM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes _____

Signed D Shrewsbury
(examiner)
8-9018

Rick Foster
Mine Foreman Mine Manager

2873
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-14-09

Time 11:35 Pm

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 10-25-09

Previous Check Made 9-27-09

Automatic Closing Doors (monthly) 10-25-09

Previous Examination Made 9-27-09

Remarks or changes

Signed D Shrewsbury
(examiner)
8-4018

Rick Foster
Mine Foreman Mine Manager

28231
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-15-09

Time 550 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes

Shut fan down, checked alarm
+ auto closing doors. Reased motor.

Signed S Shrewsbury
(examiner)
8-4018

Rick Foster
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-16-09

Time 2:25 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes

Signed G Shrewsbury
(examiner)
8-4018

Rick Foster
Mine Foreman Mine Manager

28731
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-17-09

Time 1:10 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes

Signed D Shrewsbury
(examiner)
8-4018

Rich Foster
Mine Foreman Mine Manager

28730
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-18-09

Time 12:12 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes changed chart

greased fan

Signed B Shrewsbury
(examiner)

Rick Fita
Mine Foreman Mine Manager

2873
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-19-09
Time 12:37 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 0.1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes

Signed Walter J. [Signature] 3-152
(examiner)

Rick Foster
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11/20/09

Time 12:50 Am

Fan South

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes _____

Signed D Shrewsbury
(examiner)
8-4018

[Signature]
Mine Foreman Mine Manager

5844
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11/21/09

Time ~~10:15 pm~~ 10:15 pm

Fan SOUTH

Location South Portal

Fan Operating Properly YES

Water Gage Pressure 1.8"

Fan Signal Check (monthly) OK ON 11/15/09

Previous Check Made 10/25/09

Automatic Closing Doors (monthly) 11/15/09

Previous Examination Made 10/25/09

Remarks or changes NONE

Signed Paul Hymowitz
(examining)
8-4031

[Signature]
Mine Foreman Mine Manager

720011
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11/22/09

Time 3:30 AM

Fan South

Location South Portal

Fan Operating Properly Yes

Water Gage Pressure 4.8"

Fan Signal Check (monthly) OK on 11/15/09

Previous Check Made 10/25/09

Automatic Closing Doors (monthly) 11/15/09

Previous Examination Made 10/25/09

Remarks or changes none

Signed Paul Myers
(examiner)
84031

Chris Cook
Mine Foreman Mine Manager

3506000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-23-09

Time 7:15 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes _____

Signed D. Lavery NR-2882
(Examiner)

[Signature]
Mine Foreman Mine Manager

3811
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-24-09
Time 6:00 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes _____

Signed D. Kavala NR-2882
(examiner)

[Signature]
Mine Foreman Mine Manager

2700
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-25-09
Time 9:45 AM

Fan South 9

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.9"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes _____

Signed *Neil Wilson*
(examiner) 4250

Calvin Wood
Mine Foreman Mine Manger

390600
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-26-09

Time 5:40 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes

Signed D. Lamb NR-288
(examiner)

Arthur Lamb
Mine Foreman Mine Manager

3706
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-27-04

Time 5:38 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes

Signed D. Lavery NR-2882
(examiner)

[Signature]
Mine Foreman Mine Manager

390000
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-28-09
Time 7:35 AM

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.8"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes change Intk Pim For

Recording chart.

Signed Paul Neuber
(EXAMINER) 4-250

Paul Neuber
Mine Foreman Mine Manager

28736
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 11-29-09

Time 6:00 Am

Fan South

Location South Portal

Fan Operating Properly yes

Water Gage Pressure 1.9"

Fan Signal Check (monthly) 11-15-09

Previous Check Made 10-25-09

Automatic Closing Doors (monthly) 11-15-09

Previous Examination Made 10-25-09

Remarks or changes

Signed D. Laverty NR-2882
(examiner)

Reck Fosta
Mine Foreman Mine Manager

23736
Certificate Number

Superintendent or Assistant