

SURFACE

AW
5-25-10-13

EXAMINATION OF ELECTRICAL EQUIPMENT

Company PERFORMANCE COAL CO.
Mine ABB
Location ELLIS PORTAC
Post Office County State

Re-order from
BJW Printing and
Office Supplies
P. O. Box 1309
Beckley, W. Va. 25801
Phone (304) 253-7361

Form 6—1492
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. This book is approved by the Director of The West Virginia Department of Mines and The U. S. Bureau of Mines.

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
1-23-10	Ellis	Office's & Bath House	None	None	Phil Wick
1-23-10	Ellis	8798-1000-296 KVA Box	None	None	Phil Wick 4-250
1-23-10	Ellis	Move Box	No bolts in lid	Installed bolts	
		move box	Needs new restraining clamp (ordered)		
		Removed cat head, move box is out of service			Phil Wick 4250
					Tony Moore 33359

Weekly tests of grounding devices (diodes)

1-30-10	ELLIS	Punch out			
1-30-10		Office's & Bath House	None	None	Phil Wick 4-250
1-30-10	Ellis	8798-1000-296 KVA Box	None	None	Phil Wick 4-250
2-6-10		Ellis Punch out			
2-6-10		Office's & Bath House	None	None	Phil Wick 4-250
2-6-10	Ellis	KVA 8798-1000-296	None	None	Phil Wick 4-250
2-13-10		Ellis Punch out			
2-13-10		Office's & Bath House	None	None	Phil Wick 4-250
2-13-10	Ellis	KVA 8798-1000-296	None	None	Phil Wick 4-250

Monthly examinations of methane monitors

2-20-10		Ellis Punch out			
2-13-10		Office's & Bath House	None	None	Phil Wick 4-250
2-13-10	Ellis	KVA 8798-1000-296	None	None	Phil Wick 4-250

EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-26-10	ELLIS PORTAL				
	OFFICE & BATH HOUSE		none	none	Pat Miller 4-250
	ELLIS KVA	8798-1000-296	none	none	Pat Miller 4-250
3-6-10	ELLIS PORTAL				
3-6-10	BATH HOUSE AND OFFICE		none	none	Pat Miller 4-250
3-6-10	ELLIS KVA	8798-1000-296	none	none	Pat Miller 4-250
3-15-10	ELLIS PORTAL				
3-15-10	BATH HOUSE AND OFFICE		none	none	Pat Miller 4-250
3-15-10	ELLIS KVA	8798-1000-296	none	none	Pat Miller 4-250
3-19-10	28128-120-608	move box	Found 99.5 receptacle DAMAGED, (DANGERED OFF) E-stop works, a round FAULTED BREAKERS, ALL BOLTS IN TIGHT AREA. No other dangerous conditions found at time of examination.		Pat Miller 4-250
Examinations of low-medium-voltage power circuit breakers (monthly)					
3-25-10	ELLIS PORTAL				Pat Miller 4-250
3-25-10	BATH HOUSE AND OFFICE		none	none	Pat Miller 4-250
3-25-10	ELLIS KVA	8798-1000-296	none	none	Pat Miller 4-250
3-25-10	move box	28128-120-608	none	none	Pat Miller 4-250
3-30-10	move box	28128-120-608	none	none	Pat Miller
	we did have to charge 030-3 monitor to get Pilot Light 4-				
3-31-10	ELLIS PORTAL				
	BATH HOUSE AND OFFICE		none	none	Pat Miller 4-250
	ELLIS KVA	8798-1000-296	none	none	Pat Miller 4-250

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
4-17-10	Ellis Portal	offices and bathhouse	breaker panel for Raides are not labeled breaker for Radio power transform has been knocked out and tagged. Fire exstigisher outside of water heater room had been discharged. Replaced fire e xstingisher		Virgil Bowman 4-249
	Ellis KVA box	not in service			

Weekly tests of grounding devices (diodes)

Monthly examinations of methane monitors