

UBB#1 FAN BANGTOWN  
STARTED 1/18/10 —

# DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Company PERFORMANCE COAL CO.  
Mine UBB  
Location NAOMA RALEIGH WV  
Post Office County State

Reorder from  
Chapman Printing  
(800) 999-2471  
Form # MS-021

Form 6-1491  
(March 1970)

Budget Bureau No. 42-R1589  
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. **Do not** mail this book to the Bureau of Mines.

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1/18/10  
Time 4:00pm

Fan UBB #1 FAN

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 4.0" - 4.2"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes none

Signed Paul Hym  
(examiner) 8-4031

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-19-10  
Time 12:00 PM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.1"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

-----  
-----  
-----  
-----  
-----

Signed Ch. Farley  
(examiner)  
4-431

Ray Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1/20/10

Time 4:10 pm

Fan UBB #1 FAN

Location BANDY TOWN

Fan Operating Properly YES

Water Gage Pressure 4.2"

Fan Signal Check (monthly) OK ON 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes NONE

-----  
-----  
-----  
-----  
-----  
-----  
-----

Signed Paul Thym  
(examiner)

8-4031

Tung Moore  
Mine Foreman Mine Manager

3359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-21-10  
Time 12:00 Pm

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 3.9"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Cal Faulk  
(examiner)  
4-431

Fred Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

\_\_\_\_\_  
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-22-10

Time 11:30 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

Signed Alb Fawley  
(examiner) 4-431

Fred Moore  
Mine Foreman Mine Manager

80359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-23-10

Time 11:30 PM

Fan UTBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Cal Fuchs  
(examiner) 4-471

Tony Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant



DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-24-10  
Time 12:30 AM

Fan UBB #1 Fan

Location Bardlytown

Fan Operating Properly Yes

Water Gage Pressure 4.8"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed Ch. Fairly  
(examiner)  
4-431

Tony Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-25-10

Time 12:00 pm

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Ch. Faulk  
(examiner)  
4-431

Tony Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

\_\_\_\_\_  
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-26-10

Time 12:00 PM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.1'

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

Signed Cal Fuchs  
(examiner)  
4-431

Tony Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-27-10  
Time 11:30 AM

Fan UBTB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.9"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Cal Foubly  
(examiner) 4-431

Troy Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-28-10

Time 11:38 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.3'

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed *John Fung*  
(examiner)  
4-431

*Fung Moore*  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-29-10  
Time 1:00 PM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.1"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan & Motor

-----  
-----  
-----  
-----  
-----

Signed Ch. Farley  
(examiner)  
4-431

Tony Adams  
Mine Foreman Mine Manager

33389  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1-30-10  
Time 9:15 AM

Fan USB #1 Fan  
Location Bandytown  
Fan Operating Properly Yes  
Water Gage Pressure 4.1"  
Fan Signal Check (monthly) 1-17-10  
Previous Check Made 12-19-09  
Automatic Closing Doors (monthly) 1-17-10  
Previous Examination Made 12-19-09  
Remarks or changes

Signed Ch. Farley  
(examiner)  
4-431

Fred Moore  
Mine Foreman Mine Manager

33389  
Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 1/31/10  
Time 10:AM

Fan NBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.1"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes NONE

-----  
-----  
-----  
-----  
-----  
-----

Signed Paul Nym  
(examiner)  
8-4031

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant



DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-1-10

Time 12:30 PM

Fan UBB # 1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed Cal Farley  
(examiner)  
4-431

Tony Moore  
Mine Foreman Mine Manager

33309  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-2-10  
Time 11:45 AM

Fan URB # 1 Fan

Location Bandy town

Fan Operating Properly Yes

Water Gage Pressure 4.1"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

Signed Ch Family  
(examiner) 4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-3-10

Time 11:00 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

-----

-----

-----

-----

-----

-----

-----

-----

Signed Al Farley  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

35309  
Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-4-10  
Time 10:30 AM

Fan UBB # 1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Cale Fauley  
(examiner)  
4-431

Tony Moore  
Mine Foreman Mine Manager

3339  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-5-10  
Time 10:00 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.0"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

Signed Cal Foutz  
(examiner) 4-431

Tony Moore  
Mine Foreman Mine Manager

3359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-6-10  
Time 10:30 Am

Fan UBB # 1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.1"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Al Farley  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/7/10

Time 5:05 pm

Fan 4BB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/09

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Paul Hym  
(examiner) 8-4031

T. Moore  
Mine Foreman Mine Manager

35399  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-8-10

Time 9:30 Am

Fan UTB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed Ch. Faulk  
(examiner)  
9-431

T. Moore  
Mine Foreman Mine Manager

33309  
Certificate Number

Superintendent or Assistant



DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-9-10

Time 10:45 Am

Fan UBB #1 Fan

Location Barelytown

Fan Operating Properly Yes

Water Gage Pressure 4.1"

Fan Signal Check (monthly) 1-17-18

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-18

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

Signed Cal Farley  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-10-10

Time 10:30 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed [Signature] (examiner) 4-431

[Signature] Mine Foreman Mine Manager

33359 Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-11-10

Time 10:30 AM

Fan UBB # 1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed Ch. Fuchs  
(examiner)  
4-431

Tung W. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-12-16  
Time 11:30 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan + Motor

Signed [Signature]  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/13/10

Time 12:35 AM

Fan NBB #1 FAN

Location BANDYTOWN

Fan Operating Properly yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1/17/10

Previous Check Made 12/19/10

Automatic Closing Doors (monthly) 1/17/10

Previous Examination Made 12/19/10

Remarks or changes

Signed Paul Hynes  
(examiner) 8-4031

Tony Moore  
Mine Foreman Mine Manager

39359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/14/10  
Time 4:30 pm

Fan UBB #1 FAN

Location BANDYTOWN

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) OK on 1/17/10

Previous Check Made 12/19/10

Automatic Closing Doors (monthly) OK on 1/17/10

Previous Examination Made 12/19/10

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Paul Moore  
(examiner) 5-4031

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

\_\_\_\_\_  
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/15/10

Time 11:10 AM

Fan UBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.0"

Fan Signal Check (monthly) OK ON 1/17/10

Previous Check Made 12/19/10

Automatic Closing Doors (monthly) OK ON 1/17/10

Previous Examination Made 12/19/10

Remarks or changes

Signed Paul Hays  
(examiner) 8-4031

T. Moore  
Mine Foreman Mine Manager

35359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-16-10  
Time 11:00 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.4"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

Signed Ch. Fambly  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant



DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-17-10

Time 1:15 Pm

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Al Fealy  
(examiner) 4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-18-10

Time 11:00 AM

Fan UBB # 1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.4"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed Al Farley  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-19-10

Time 12:00 Pm

Fan UBB #1 Fan

Location Bandy low

Fan Operating Properly Yes

Water Gage Pressure 4.4'

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes Greased Fan

Signed Ch Farley  
(examiner) 4-431

Tony Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-20-10  
Time 9:00 Am

Fan USB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 1-17-10

Previous Check Made 12-19-09

Automatic Closing Doors (monthly) 1-17-10

Previous Examination Made 12-19-09

Remarks or changes

Signed Cal Farley  
(examiner) 4-431

Troy Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/21/10

Time 12:15pm

Fan 4BB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.2"

Fan Signal Check (monthly) 2/21/10

Previous Check Made 1/17/10

Automatic Closing Doors (monthly) 2/21/10

Previous Examination Made 2/27/10

Remarks or changes FAN SIGNAL BATT. CHARGER

NOT WORKING, REPAIRED

Signed Paul Dym  
(examiner)  
8-4031

T. Moore  
Mine Foreman Mine Manager

35357  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-22-10  
Time 10:00 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.3'

Fan Signal Check (monthly) 2-21-10

Previous Check Made 12-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes

Signed Cal Farley  
(examiner) 4-431

Terry Moore  
Mine Foreman Mine Manager

33389  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-23-10  
Time 11:00 Am

Fan UBB #1 Fan

Location Bandy low

Fan Operating Properly Yes

Water Gage Pressure 4.5"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes Greased Fan

Signed Cal Foubly  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-24-10  
Time 12:00 Pm

Fan U13B-#1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.3"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Cal Fowley  
(examiner) 443

Tony More  
Mine Foreman Mine Manager

3335  
Certificate Number

Superintendent or Assistant



DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-25-10

Time 11:50 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.1"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes

-----  
-----  
-----  
-----  
-----

Signed Ch Farley  
(examiner) 4-431

T. Moore  
Mine Foreman Mine Manager

3359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2-26-10  
Time 11:00 Am

Fan LIBB # 1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.4"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes Greased Fan + Motor

Signed Carl Farley  
(examiner)  
4-431

Fung Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/27/10

Time 11:50pm

Fan WBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.4"

Fan Signal Check (monthly) 2/21/10

Previous Check Made 1/12/10

Automatic Closing Doors (monthly) 2/21/10

Previous Examination Made 1/12/10

Remarks or changes

Signed Paul Hym  
(examiner)

8-4031

Tung W. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 2/28/10

Time 12:15 AM

Fan NBB #1 FAN

Location BANDYTOWN

Fan Operating Properly YES

Water Gage Pressure 4.4"

Fan Signal Check (monthly) 2/21/10

Previous Check Made 1/17/10

Automatic Closing Doors (monthly) 2/21/10

Previous Examination Made 1/17/10

Remarks or changes BLUE PENNANT ROAD VERY SLICK.

HAD ENVIRONMENTAL CREW SCRAPE + SALT.

Signed Paul Thym (examiner) 8-4031

Tony Moore Mine Foreman Mine Manager

33307 Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-1-10

Time 9:00 Am

Fan UBB #1 Fan

Location Bandytow ~

Fan Operating Properly Yes

Water Gage Pressure 4.3'

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed Ch. Faulk  
(examiner) 4-4/31

T. Moore  
Mine Foreman Mine Manager

39359  
Certificate Number

\_\_\_\_\_  
Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-2-10  
Time 12:00 Pm

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.0

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes Greased Fan

Signed Ch Farley  
(examiner) 4431

T. M. ...  
Mine Foreman Mine Manager

33389  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-3-10

Time 10:30 Am

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.0"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes

Signed Ch Fauly  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-4-10  
Time 11:30 Am

Fan WBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 4.9"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes

Signed *Ch. Fench*  
(examiner)  
4-431

*T. Moore*  
Mine Foreman Mine Manager

33399  
Certificate Number

Superintendent or Assistant



DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-5-10  
Time 9:30 Am

Fan UBB #1 Fan

Location Bandy four

Fan Operating Properly Yes

Water Gage Pressure 4.9"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes Overasped Fan

Signed Ch Fealy  
(examiner)  
4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DAILY AND MONTHLY EXAMINATION OF VENTILATION EQUIPMENT

Date 3-6-18

Time 11:30 AM

Fan UBB #1 Fan

Location Bandytown

Fan Operating Properly Yes

Water Gage Pressure 5.0"

Fan Signal Check (monthly) 2-21-10

Previous Check Made 1-17-10

Automatic Closing Doors (monthly) 2-21-10

Previous Examination Made 1-17-10

Remarks or changes

-----  
-----  
-----  
-----  
-----

Signed Ch Fuchs  
(examiner) 4-431

T. Moore  
Mine Foreman Mine Manager

33359  
Certificate Number

Superintendent or Assistant

DATE 3/7/10  
Time 10:05pm

FAN WBB #1 FAN  
BANDYTOWN LOCATION

FAN IS OPERATING CORRECTLY

WATER PSI: 5.0"

FAN SIGNAL CHECK 2/21/10

PREVIOUS CHECK 1/17/10

AUTO CLOSE DOORS 2/21/10

PREVIOUS CHECK 1/17/10

COMMENTS

AIR COMPRESSOR DOWN. RPR RUNNING @ 9:00pm

Signed

Paul Thym  
8-4031

Super

MINE FOREMAN

3-8-10  
9:30 AM

UBB #1 Fan

Bandy town

Fan Working - Yes  
Water Press. 4.9"

Ch. Fowler  
4-431

Air

