



BENSHAW Inc.

ADVANCED CONTROLS & DRIVES

The potentially affected product manufacturing date and serial number can be obtained by reading the Benshaw Product label located on the starter door and/or on the starter chassis. Note that affected units will have a Serial number prefixed with S2001 through A2006. See figure 1. The Micro II circuit board part number can be identified by locating the board part number as indicated in figure 2.



BENSHAW

ADVANCED CONTROLS & DRIVES

Serial: S200901225-1-1

Part No.: RB2-3-S-125-480-H-4X-CBOP

Largest HP: 125

Largest Amps: 156

Total Amps: 156.520

Voltage: 480

Phase: 3

Frequency: 60

EnclosureType : 4X


Control Voltage: 120

Short Circuit Current: 10 kA
rms symmetrical Amps, 480 V
maximum.

Figure 1

7.1 DRAWINGS

RediStart Micro II Computer Card Diagram



116

Board Part Number Location

Figure 2