

Reprinted with permission from NFPA 70-1968, the National Electrical Code®, Copyright© 1967, National Fire Protection Association, Quincy, MA 02269. This reprinted material is not the complete and official position of the National Fire Protection Association, on the referenced subject which is represented only by the standard in its entirety.

National Electrical Code® and NEC® are registered trademarks of the National Fire Protection Association, Inc., Quincy, MA 02269.

INDEX

AC and DC Conductors in Same Enclosures, 300-3(a)

AC-DC, General-Use Snap Switches

Definitions, Switches,
Art. 100

Marking, 380-15

Motors, 430-83, Ex. 1

Ratings, Type loads, 380-14

Signs, 600-2(b)

AC-DC Resistance Conversion,
Table 9, Chap. 9

AC Metal-Clad Cable, (see
Metal-Clad Cable and
Art. 334)

AC Systems

Conductor to be grounded,
250-25

Grounding Connections for,
250-23

Grounding of, 250-5

In same metallic enclosures,
300-20

Access and Working Space,
Electrical Equipment

Over 600 volts, 710-D

Not over 600 volts, 110-16

Accessible, Readily Accessible

Definitions, Art. 100

Ground connections,
250-112(a)

Junction, pull, and outlet
boxes, 370-19

Sealing fittings (see also
Hazardous locations)

Splices and taps in
auxiliary
gutters, 374-8(a)

Splices and taps in
wireways,
362-6

Structural raceways, 357-9

Transformers and vaults,
450-2

Transformers, signs, outline
lighting, 600-32(e)

Unfinished attics, roof
spaces, knob-and-tube
wiring, 324-8(b)

Atmospheres (see Hazardous
Locations)

Aerial Cable, Art. 342 (see
Nonmetallic Extensions)

Air Conditioning Units, Room,
422-F

Branch-circuit requirements,
422-42

Definition and nameplate
marking, 430-53(d)

Disconnecting means, 422-43

Grounding, 422-41

Aircraft Hangars, Art. 513

Air Plenums, Wiring in, 300-22

Airport Runways, Underground
Conductors, buried, 710-
3(b),
Ex. 2

Alarm, Signal, Remote-Control,
Low-energy, Low-Voltage
Circuits, Art. 725 (see also
Hazardous Locations)

Alarms, Fire and Burglar,
Art. 800

Alternators, (Generators)
Art. 445

Aluminum Conductors (see also
Conductors)

In concrete and earth,
300-5(b) (see also Rigid
Metal Conduit)

Aluminum Sheathed Cable (Type
ALS), Art. 331

Construction, 331-C

General, 331-A

Installation requirements,
331-B

Aluminum Siding, 250-44(d)
(Note)

Ampacities

Bus-bars, copper, aluminum,
in auxiliary gutters, 374-
6

Conductors, Tables 310-12
thru 310-15

Crane and hoist conductors,
Table 610-14(a)

Fixture Wires, Table 402-4

Flexible Cords, Table
400-9(b)

Anesthetics, Flammable,
Art. 517 (see also Hazardous
Locations)

Antenna Discharge Systems,
810-20

Antenna Systems, Radio-
Television, Art. 810

Community TV & Radio
Distribution Systems,
Art. 820

Appliance(s) (see also Motors,
Art. 430), Art. 442

Branch-circuit calculations,
220-3

Branch circuits,
definitions,
Art. 100

Branch circuits for, 210-24

Control and protection, 422-

D

Cords, (see Cords, Flexible)

Definition, Art. 100

Disconnecting means, 422-20,
422-26

Feeder calculations for,
220-4

Fixed, Definition, Art. 100

Grounding, fixed and
portable, 250-E, 550-9,
551-9

Hazardous locations, (see
Hazardous Locations)

Household cooking appliances
Demand loads for, Table
220-5

Installation, 422-C

Load calculations, 220-3,
220-4, Table 220-5

Marking, 422-E

Mobile Homes, in, 550-5(b-
c),

550-7

Motor-operated, load, 210-23

Overcurrent protection,
single, 210-20(b)

Overcurrent protection,
general, 422-27

Portable, definition,
Art. 100

Stationary, definition,
Art. 100

Terminals, identification,
200-10(e-f)

Travel Trailers, in,
551-5(b), 551-7

Approval, Approved

Definition, Art. 100

Equipment and Materials,
90-7, 90-8, 110-2, 500-1,
500-2

Arc Lamps

General, 410-51

Portable

Motion Picture Studios,
530-17

State Equipment, 520-61

Arcing Parts, Enclosure of
(see

also Enclosures)

General, 110-18

Motors, 430-14(b)

Arc Welder(s), Art. 630

Arc-Welder Motors, 630-C

Ampacities of Conductors,

Table 430-22 (a-Exception)

Nameplate Marking, 430-7(a)

Arenas, Art. 520

Emergency Lighting, Systems
for, Art. 700

Armored Cable, Art. 334 (see
Metal-clad Cable)

Armories, Art. 520

Emergency Lighting Systems
for, Art. 700

Arresters, Lightning, Art. 280

(see also Antenna Discharge
Systems, 810-20)

Askarel

Definition, Art. 100

Transformers, 450-23

Assembly Halls, Art. 520

Emergency Lighting, Art. 700

Atmospheric Groups (see
Hazardous Locations)

Attachment Plugs (Caps) (see
also Hazardous Locations)

Definition, Art. 100

Flexible Cord, on, 400-16

Grounding Type, 410-55

Attics

Knob and Tube, 324-8

Metal-Clad Cable, 334-13

Nonmetallic Sheathed Cable,
336-9

Open Wiring, 320-13

Auditoriums, Art. 520

Emergency Lighting, Art. 700

Automatic, Definition, Art.
100

Autotransformers

Ballast, Electric Discharge
Lighting Systems, 410-76
Branch Circuits, 200-4
Motor Starting, 430-82(b)

Auxiliary Gutters, Art. 374

Ampacities, bare and
insulated conductors, 374-
6
Clearance, bare live parts,
374-7
Construction, installation,
374-9
Covers, 374-4
Elevator uses, 620-35
Extension beyond equipment,
374-2
Number of conductors, 374-5
Sound recording, similar
equipment, 640-4
Splices, taps, 374-8
Supports, 374-3

Auxiliary Source

Emergency Systems, 700-11

Ballasts, Electric Discharge

Lamps, 410-74 (a), 410-75
Protection, in fluorescent
fixtures, 410-71 (e)

Bare Conductor(s)

Ampacities, Note 4, Tables
310-12 thru 310-15
Contact conductors, cranes
and hoists, 610-C
Definition, Art. 100
Dimensions and resistance,
Table 8, Chap. 9
Feeders, Art. 328
Sizing conduits for, 346-6
Underground ducts, conduits,
grounded neutral,
230-30(a), Exc. 2

Basement (Cellars)

Metal-clad cable, 334-12(c)
Nonmetallic sheathed cable,
336-8

Batteries, Storage (see
Storage
Batteries)

Battery Charging Equipment

(see also Hazardous
Locations)

Bell Circuits, Art. 725

Bends (see Wiring system
involved)

Block, City, Town, Village,
Definition, 800-2, 820-3(b)

Boat Harbor Wiring, Art. 555
Branch Circuit, Feeder

- Calculations, 555-2
- Branch Circuits, 555-2(a)
- Feeder, Services, 555-2(b)

Boat Harbor Wiring, (continued)
Clearances, Over Water, 555-4

- Grounding, 555-6
- Receptacles, 555-5
- Voltage Drop, 555-1

Bonding, 250-G

- Grounding-type receptacles, 250-74
- Hazardous locations (see Hazardous Locations)
- Jumpers, 250-79
- Loosely jointed raceways, 250-77
- Service raceway, flexible metal conduit, 230-63(c)

Borders, Proscenium

Sidelights,
Theaters, Assembly Halls, 520-44

Bored Holes Through Studs, Joists, 300-8(a)

Bowling Alleys, Art. 520

- Emergency Lighting Systems, Art. 700

Boxes, Outlet, Switch, Pull, and Junction, Art. 370 (see also Hazardous Locations, Junction Boxes)

- Accessibility, 370-19
- Concealed, 370-14
- Conductors, number in box, 370-6
- Construction specifications, 370-C
- Covers, 370-15, 370-18(c), 370-21
- Cutout
 - Definition, Art. 100
 - Installation, Art. 373
- Damp locations, 370-5
- Depth, 370-14
- Exposed extensions, 370-12
- Gas pipes, fastened to, 370-16
- Grounding, 250-E, 250-114, 300-9
- Insulating (see nonmetallic)

- Junction, pull, size, 370-18(a)
- Lighting outlets, 370-17, 410-C, 410-16
- Metallic, 370-4
- Nonmetallic, 324-9, 336-12, 370-3, 370-7 (c), 370-23
- Portable, in theaters, 520-62

Boxes, (continued)

- Remote Control, signal circuits, 725-42(a-2)
- Repairing plaster around, 370-11
- Round, 370-2
- Secured, 300-11, 370-13
- Snap switches over 300 volts not ganged, 380-8
- Unused openings, closed, 370-8
- Vertical raceway runs, 300-19
- Wall, 370-10
- Wet locations, 370-5
- Where required, 300-15

Branch Circuits, Art. 210, 220

- Busways, as branch circuits
 - Length, 364-13
 - Overcurrent protection, 364-11
 - Rating, 364-12
- Calculation of loads, 220-2, Part B, Chap. 9
- Definition, Art. 100
- General provisions, 210-A
- Individual, definition, Art. 100
- Infra-red lamps, 422-15
- Maximum load, 210-23
- Mobile homes, 550-5
- Motor, on individual branch circuit, 430-B
- Multiwire, definition, Art. 100
- Outside and feeders, Art. 730
- Overcurrent protection, 210-20, 240-5
- Permissible loads, 210-24
- Table of requirements for, Table 210-25
- Taps from, 210-19(c), 210-25,

240-5, Ex. 3
Through fixtures
Travel trailers, 551-5
Two or more outlets on,
210-24
Voltage, permitted rating,
210-6
Voltage drop, 210-6(c)
X-ray equipment, 660-3, 660-
5

Branches from Busways, 364-7
Breaker, Circuit (see Circuit
Breakers)

Building, Definition, Art. 100

Building Wire (see Conductors)

Bulk Storage Plants, Art. 515
(see Hazardous Locations)

Burglar Alarm Systems, Art.
800

Bushing

Generators, 445-9

Insulating, Lampholders,
Attached to flexible cord,
410-24

Motors, 430-13

Outlet boxes and fittings,
370-22

Rigid Metal Conduit, 346-8

Use in lieu of box or
terminal fitting, 300-
16(b)

Busways, Art. 364

Branch circuits, 364-11

Branches from, 364-7

Dead ends closed, 364-5

Extension thru walls and
floors, 364-4

Length, as branch circuits,
364-13

Marking, 364-14

Overcurrent protection,
364-8, 364-9, 364-12

Reduction in size, 364-10

Support, 364-3

Use, 364-2

Cabinets and Cutout Boxes,
Art. 373

Construction specifications,
373-B

Damp, wet locations, 373-2

Definitions, Art. 100

Deflection of conductors,
373-6

Insulation at bushings,
373-6(b)

In walls, 373-3

Switch enclosures, no
splices, taps, 373-8

Unused openings, 373-4

Wiring space, 373-9

Cablebus, Art. 365
 Conductors, 365-3
 Ampacity, 365-3(b)
 Number, 365-3(c)
 Overcurrent Protection, 365-5
 Size, 365-3(c)
 Supports, 365-3(d)
 Terminations, 365-8
 Types, 365-3(a)
 Definition, 365-1
 Fittings, 365-7
 Grounding, 365-9
 Marking, 365-10
 Support, 365-6
 Conductor, 365-3(d)
 Use, 365-2
Cable(s) (see also Heating Cable)
 Armored AC, Art. 334
 Border Lights, Theaters, Assembly Halls, 520-44(b)
 Communication, Remote-control, Signal Circuits, 725-7
 Continuous, outlet to outlet,
 fitting to fitting, 300-12
 Metal-clad, Art. 334
 Mineral Insulated-Metal Sheathed, Art. 330
 NM, NMC, Art. 342
 Nonmetallic Sheathed, Art. 336
 Nonmetallic Extension, Art. 342
 Secured, 300-11, 370-7(b), (c)
 Service
 Definition, Art. 100
 Entrance, Art. 338
 Splices in Boxes, 300-15
 Through studs, joists, rafters, 300-8
 Underground, 230-D, 300-7, 310-6
 Underground Feeder and Branch
 Circuit, Art. 339
 Underplaster Extensions, Art. 344
Cable End Fittings, changing from cable to knob and tube,

300-16(a)
Cable Trays (see Continuous Rigid Cable Supports)
Cages and Shielding,
 Protective, Heat Generating Equipment, 665-27
Calculations (see Loads)
Canopies
 Boxes and Fittings, 370-15
 Lighting Fixtures,
 Conductors, Space for, 410-10
 Cover
 At boxes, 410-12
 Combustible Finishes, Covering required between
 Canopy and Box, 410-13
 Live parts exposed, 410-3
Caps (see Attachment Plug)
Capacitors, Art. 460 (see also Hazardous Locations)
 Connections at Services, 230-73
 Draining Charge, 460-6
 Induction, Dielectric Heating, 665-26
 X-ray Equip., 660-16
Capacity, Interrupting,
 General, 110-9
Cartridge Fuses, 240-F
 Disconnection, 240-18
Cellars (see Basement)
Cellular Concrete Floor Raceways, Art. 358
 Connection to Cabinets, 358-4
 Definition, 358-1
 Discontinued Outlets, 358-11
 Header Ducts, 358-3
 Inserts, 358-7
 Junction Boxes, 358-5
 Markers, 358-6
 Number of Conductors, 358-9
 Size of Conductors, 358-8
 Splices, 358-10
 Use, 358-2
Cellular Metal Floor Raceways, Art. 356
 Connection to Cabinets, 356-11
 Discontinued Outlets, 356-7

- Definition, 356-1
- General, 356-12
- Inserts, 356-10
- Junction Boxes, 356-9
- Markers, 356-8
- Number of Conductors, 356-5
- Size of Conductors, 356-4
- Cellular Metal Floor Raceways,**
(continued)
- Use, 356-2
- Churches** (see Public
Assemblies)
- Cinder Fill**
Metal conduits and
electrical
 metallic tubing, in or
 under, 346-3, 348-1
- Circuit(s)**
Branch (see Branch Circuits)
- Burglar Alarm, Art. 800
- Central Station, Art. 800
- Communication, Art. 800
 Definition, Art. 100
- Control, Definition, 430-71
- Fire Alarm, Art. 800
- Grounding, Art. 250
- Impedance, 110-10
- Less than 50 Volts, Art. 720
 Grounding, 250-8
- More than 600 Volts, Art.
710
 Services, 230-L
- Motor, Art. 430-B
- Power, Signal, Remote-
 control, Low Energy,
 Art. 725
- Remote-control, Motors,
 Controllers, 430-F
- Signal Circuits, Art. 725
- Telegraph, Art. 800
- Telephone, Art. 800
- Theaters, Assembly Halls,
 etc., Loads, 520-41
- Unidentified, 200-5
- Circuit Breakers,** Art. 240
(see
 also Hazardous Locations)
- Accessibility and Grouping,
 380-8
- Circuits Over 600 Volts,
 230-106, 710-21
- Definition, Art. 100
- Disconnection of Grounded
 Conductors, 380-1
- Enclosures, 380-3
- General, 110-9, 240-H
- Overcurrent Protection
 Generators, 445-4
- Motors, 430-57, 430-58
- Transformers, 450-3
- Panelboards, 384-B
- Rating, Motor Branch
 Circuits, 430-57

Circuit Breakers, (continued)
Rating, Nonadjustable Trip,
240-5(a) Ex. No. 1,
240-25(e)
Service Overcurrent
Protection, 230-90
Services, Disconnecting
Means, 230-70
Over 600 Volts, 230-106
Setting Adjustable Trip,
240-5(a), Exc. No. 2
Switches, Use as, 380-11
Wet Locations, in, 380-4
Circuit **Directory**,
panelboards,
110-22
Clamp, Ground, 250-116, 250-
117
Class 1 and 2 Circuits,
Remote-
Control, Low-Energy Power,
Signal Circuits, Art. 725
Class I, Class II, Class III
Locations (see Hazardous
Locations)
Cleaning and Dyeing Plants,
Hazardous Liquids in, 500-4,
Art. 501
Clean Surfaces, grounding
connections, 250-118
Clearance(s) (see also
Enclosures, Isolation, and
Space)
Antennas, 810-13, 810-18,
810-54
Community Antenna Systems,
Art. 820
Conductors, Open, Outside
Branch Circuits and
Feeders, 730-18, 730-19
Elevators, Dumbwaiters,
Escalators and Moving Walk
Panels, 620-72
Lighting Fixtures, Flush,
Recessed, 410-64, 410-
74(b)
Live Parts
Bare Conductors, Auxiliary
Gutters, 374-7
Circuits Over 600 Volts,
710-D
Switchboards, Panelboards,
384-7, 384-8

Climbing Space
Line Conductors on Poles,
730-14(e)

Clock Outlets, Connection to
Branch circuits in
dwellings,
220-3(b)

Clothes Closets, Light
Fixtures, 410-8

Clothing Manufacturing Plants,
500-6, Art. 503 (Hazardous
Locations)

Code

Arrangement, 90-3
Definitions, 90-4, Art. 100,
110-3
Enforcement, 90-7
Examination of Equipment for
Safety, 90-8
Interpretation, 90-6,
Appendix
Purpose, 90-1
Revisions, 90-10
Rules, 90-5, 110-3
Scope, 90-2
Wiring Planning, 90-9

Collectors, Cranes and Hoists,
610-22

Color Code

Branch Circuits, 210-5
Grounding conductor, 210-5,
250-57(b), 400-14
Switchboards and
Panelboards,
384-25

Combustible Dusts (see
Hazardous Locations),
Art. 502

**Common Main Grounding
Conductor**, 250-53

Common Grounding Electrode,
250-54

Common Neutral

Feeders, 215-5
Outside Wiring, 730-7

Communication Circuits,

Art. 800
Definition, Art. 100
General, 800-A
Grounding, 800-E
Cable Sheath, 800-31(a)
Protector Ground, 800-
31(b)
Electrode, 800-31(b-5)
Electrode Connection,
800-31(b-6)

Insulation, 800-31(b-1)
Physical Damage,
800-31(b-4)

Communication Circuits,

(continued)

- Run in Straight Line,
800-31(b-3)
- Size, 800-31(b-2)
- Outside Overhead Conductors,
800-C
- Circuits Requiring
Protection, 800-11(c)
- Entering Building,
800-11(c-4)
- Insulation Cables,
800-11(c-2)
- Insulation, Single,
Paired,
800-11(c-1)
- On Buildings, 800-11(c-3)
- Lightning Protection, 800-12
- On Poles, 800-11(a)
- Attachment to Cross Arms,
800-11(a-2)
- Climbing Space, 800-11(a-
- 3)
- Relative Location, Other
Conductors, 800-11(a-1)
- Protection, 800-B
- Installation, Conductors,
800-3
- Separation, 800-3(a)
- Open Conductors,
800-3(a-1)
- Raceways, Boxes,
800-3(a-2)
- Shafts, 800-3(a-3)
- Vertical Runs, 800-3(b)
- Protective Devices, 800-2
- Hazardous Locations,
800-2(b)
- Location, 800-2(a)
- Omission of Fuses, 800-
- 2(d)
- Protector Requirements,
800-2(c)
- Underground Circuits, 800-D
- Circuits, 800-21
- Relative to other
Conductors, 800-21(a)
- Underground Block
Distribution, 800-21(b)
- Communication Systems, Chap. 8**
- Community Antenna Television**
and Radio Distribution
Systems, Art. 820

General, 820-A, 820-F

Material, 820-2

Prevention, Fire Spread,
820-10

Community Antenna Television and Radio Distribution Systems, (continued)

- Scope 820-1
- Grounding, 820-E
- Cable
- Electrode, Electrode
Connection,
820-8(a-6,7)
- Insulation, 820-8(a-1)
- Protection, 820-8(a-5)
- Straight Line, 820-8(a-
- 4)
- Size, 820-8(a-3)
- Equipment, 820-9
- Installation, 820-C
- Entering Buildings, 820-5
- Inside Buildings
- Light and Power, 820-
- 6(a)
- Other Conductors,
820-6(e)
- Raceways and Boxes,
820-6(b)
- Shafts, 820-6(c)
- Vertical, 820-6(d)
- Outside Buildings
- Between Buildings,
820-4(d)
- Lead-in Conductors,
820-4(b)
- Light and Power
- Conductors, 820-4(e-1)
- Lightning Conductors,
820-4(e-3)
- On Poles, 820-4(a)
- Other Communication
Systems, 820-4(e-2)
- Over Roofs, 820-4(c)
- Protection, 820-B
- Block Distribution,
820-3(b)
- Shield, Coaxial Cable
- Grounding, 820-3
- Protective Devices,
820-3(a)
- Underground Circuits, 820-D
- Coaxial Cable, 820-7

Light and Power
Conductors,
820-7(a)

Compressors, Refrigeration
(see
Refrigeration Compressor
Motors and controls)

Concealed
Definition, Art. 100
Knob-and-Tube, Art. 324

Concentric Knockouts, Bonding
Jumpers, Service, 250-72(d)

Concrete
Encased electrodes, 250-
83(a)
Metal raceways and equipment
in, 300-5(b)

Conductor Fill, Maximum
permitted
Auxiliary gutters, 374-5,
374-8
Cellular concrete floor
raceways, 358-9
Cellular metal floor
raceways, 356-5
Continuous rigid cable
supports (cable trays),
318-6, Table 318-6(a)
Electrical metallic tubing,
384-6
Flexible Metal conduit,
350-1, 350-3, Table 350-3
Liquidtight flexible metal
conduit, 351-4
Rigid metal conduits, 346-6
Rigid nonmetallic conduits,
347-11
Structural raceways, 357-6
Surface metal raceways, 352-

4
Wireways, 362-5, 362-6
Conductors (see also Cords,
Flexible; and Fixture Wires)
Aluminum, Ampacities of,
Tables 310-14, 310-15
Aluminum, Properties of,
Table 8, Chap. 9
Ampacities, 310-11, Tables
310-12 thru 310-15
Motors, 430-B
Raceway (More than three
in) Note 8, Tables 310-

thru 310-15
Amplifier Circuits, 640-5
Application, 310-2, Table
310-2(a)
Bare, Definition, Art. 100
Boxes and Fittings,
Junction,
370-6, 370-7
Branch Circuits, Art. 210
Buried, 310-6
Busways, Art. 364
Cabinets and Cutout Boxes,
373-5, 373-6
Capacitor Circuits, 460-8

Conductors (continued)

Cellular Concrete Floor
 Raceways, Art. 358
 Cellular Metal Floor
 Raceways, Art. 356
 Circuit,
 Less than 50 Volts,
 Art. 720
 Power, Signal, Remote-
 Control, Low-energy,
 Art. 725
 Over 600 Volts, Art. 710
 Combinations, Table 3,
 Chap. 9
 Computations of, Examples,
 Chap. 9, Part B
 Concealed Knob-and-Tube,
 Art. 324
 Conduit or Tubing, Number
 in,
 346-6, Table 350-3,
 Tables 1, 1A, Chap. 9
 Construction, General, 310-2
 Copper, Ampacities, Tables
 310-12, 310-13
 Copper, Properties, Table 8,
 Chap. 9
 Cords, Flexible, Art. 400
 Corrosive conditions, 310-7
 Covered, Definition, Art.
 100
 Cranes and Hoists, 610-B,
 610-C, 610-31, 610-41
 Different Systems, 300-3,
 725-16
 Dimension of
 Asbestos-Varnished-Cambric
 Insulated, Table 7, Chap.
 9
 Lead-covered, Table 6,
 Chap. 9
 Rubber-covered and Thermo-
 plastic-covered, Table
 5,
 Chap. 9
 Electrical Metallic Tubing,
 Art. 348
 Elevators, Dumbwaiters,
 Escalators, and Moving
 Walks, 620-B, 620-C, 620-D
 Enclosure, Grounding, 250-1,
 250-D
 Feeder, Bare, Art. 328

Fixture Wires, Art. 402
 Flame-Retardant Braid, Over
 600 volts, 710-4
 Flexible Metal Conduit,
 Art. 350

Conductors (continued)

Gages, General Provisions,
 110-6
 General Provisions, 110-7
 Generators, Size, 445-5
 Grounded
 Alternating Current
 Systems, 250-23, 250-25,
 Identification, 200-6,
 200-7
 Overcurrent Protection,
 230-90(b)
 Service Disconnection,
 230-70
 Overcurrent Protection,
 230-90(b)
 Size, Change in, 240-13
 Switches, Disconnection,
 380-1
 Use and Identification,
 Art. 200
 Grounding, 250-J
 Connections, 250-K
 Induction and Dielectric
 Heating Equipment
 Capacity of Supply, 665-6
 Power Supply for
 Therapeutic Equipment,
 665-30(b)
 Inserting into raceways,
 300-18
 Insulating materials, 310-3
 Insulation, Art. 310
 Fixtures, Flush, Recessed,
 Hazardous Locations,
 Class I Installations,
 501-13
 Motion Picture Projectors,
 540-14
 Resistors and Reactors,
 470-7
 Theaters, Assembly Halls,
 etc., 520-42
 Insulation at bushings, No.
 4
 and Larger, 373-6(b)
 Lighting Fixtures, 410-E

Lightning Rods, Spacing
from,
250-34
Liquid-Tight Flexible
Metallic Conduit, Art. 351
Metal Enclosures, Spacing
from Lightning Rods, 250-
34
Metal-clad Cable, Art. 334

Conductors (continued)
Mineral Insulated-Metal
Sheathed Cable, Art. 330
Minimum size, 310-8
Motion Picture Projectors,
Sizes, 540-13
Motor Circuits, 430-B
Multioutlet Assembly,
Art. 353
Nonmetallic Sheathed Cable,
Art. 336
Nonmetallic Extensions,
Art. 342
Number of, in
Auxiliary Gutters, 374-5
Cellular Concrete Floor
Raceways, 358-9
Cellular Metal Floor
Raceways, 356-5
Continuous Rigid Cable
Supports (Cable Trays)
318-6, Table 318-6(a)
Electrical Metallic
Tubing,
348-6
Elevators, 620-32, 620-33
General Installations,
300-17
Metal Conduit, 346-6
Remote Control Circuits,
725-15
Rigid Flexible Metal
Conduit, Table 350-3
Rigid Nonmetallic Conduit,
347-11
Signs and Outline
Lighting,
600-21(d)
Sound Recording, 640-3
Structural Raceways, 357-6
Surface Metal, 352-4
Surface Metal Raceways,
352-4
Theaters, Assembly Halls,
520-5
Underfloor Raceways, 354-5
Wireways, 362-5
Organs, 650-4, 650-5
Outlet Boxes, Temp. Limits,
410-11
Outside Wiring, Art. 730
Over 600 Volts, Art. 710
Overcurrent Protection,

Art. 240 and Note 10 to
Tables 310-12 thru 310-15

Conductors (continued)

Properties of, Table 8,
Chap. 9
Raceways, Number of
Conductors in (see
Conductors, Number of, in)
Radio and Television
Antenna Distribution
Systems, Art. 820
Antenna Systems, 810-B,
810-C
Grounding, 810-58 thru
810-60
Transmitting Stations,
810-70
Railway, Power and Light
from, General Provisions,
110-19
Remote Control and Signal
Circuits, Art. 725
Rigid Metal Conduit, Art.
346
Selection of, Examples,
Chap. 9, Part B
Service (see Service Cable
and Service Conductors)
Service-Entrance,
Definition,
Art. 100
Service-Entrance, Art 338
Signs and Outline Lighting,
Installation, 600-21,
600-31
Simplified Wiring Tables,
Tables 310-20, 310-21,
Sections 310-20, 310-21
Sizes of
Asbestos-Varnished-Cambric
Insulated, Table 7,
Chap. 9
Bare Conductor Feeders,
328-2
Cellular Concrete Floor
Raceway, 358-8
Cellular Metal Floor
Raceway, 356-4
Flexible Metal Conduit,
Table 350-3
Lead-covered, Table 6,
Chap. 9
Liquid-tight Flexible
Metal
Conduit, 351-4

Mineral Insulated-Metal
 Sheathed Cable, 330-
 11(a)
 Rubber Covered, Table 6,
 Chap. 9
Conductors (continued)
 Services, 230-B, 230-23,
 230-31, 230-42,
 230-101(a)
 Signs and Outline
 Lighting,
 600-21(b), 600-31(b)
 Structural Raceways,
 Art. 357-8
 Surface Metal Raceways,
 352-3
 Thermoplastic-covered,
 Table 5, Chap. 9
 Underfloor Raceways, 354-4
 Wireways, 362-4
 Sound Recording and Similar
 Equipment, 640-3 thru
 640-7, 640-9(b)
 Storage Batteries, 480-7(c)
 Stranded, 310-9
 Support of, in vertical
 raceways, 300-19
 Surface Metal Raceway,
 Art. 352
 Switchboards and
 Panelboards,
 384-3, 384-9
 Temperature Limitations of,
 310-4
 Theaters, Assembly Halls,
 Portable Stage Equipment,
 520-68
 Underfloor Raceway, Art. 354
 Underground Feeder and
 Branch
 Circuit Cable, Art. 339
 Underplaster Extensions,
 Art. 344
 Ungrounded, Overcurrent
 Protection, 240-11
 Ungrounded, Services,
 230-90(a)
 Welders, Electric
 Capacity of Supply, 630-
 11,
 630-31
 Overcurrent Protection,
 630-12(b), 630-32(b)

 Wet Locations, 310-5
 Wireways, Art. 362
 Wiring, General, Art. 310
 X-ray Equipment, 660-3, 660-
 7
Conduit Nipples, Note Table 1,
 Chap. 9
Conduit, Rigid Metal, Art. 346

Conduits

- Circuits, Mechanical
 - Protection of Remote control, 725-17
- Conductors, Number in, Tables 1, 1A, 2 and 3, Chap. 9
- Dimensions, Table 4, Chap. 9
- Electrical metallic tubing, Art. 348
- Flexible, Grounding, Services, 230-63(c)
- Flexible Metal, Art. 350
- Liquid-tight Flexible Metal, Art. 351
- Metallic, grounding runs 25 ft., 250-33
- Outside Wiring, 730-10
- Rigid Metal, Art. 346
- Rigid nonmetallic, Art. 347

Connections

- Aluminum, copper conductors, 110-14
- Cabinets and Extensions
 - Cellular Metal Floor
 - Raceways, 356-11
- Grounding conductor, 250-K
- Knife switches, 380-7
- Terminals, General
 - Provisions, 110-14

Connectors

- Boxes, 370-7
- Cable, Theaters, and Assembly
 - Halls, 520-67
- Electrical metallic tubing, 348-8, 348-14(c)
- Metal-clad cable, 334-5
- Pressure (Solderless),
 - Definition, Art. 100
- Rigid metallic conduit, 346-9
- Rigid nonmetallic conduit, 347-6

Constant-Potential Generators, Art. 445

- Overcurrent protection for, 445-4(a)

Construction Specifications

- (see listed in Articles covered)

Continuity

- Electrical, metal raceways and cables, 250-75, 250-76,
 - service equipment, 250-71, 250-72
- Grounding, metal boxes, grounding-type
- receptacles, 250-74, 250-114
- Mechanical, raceways and cables, 300-12;
- conductors, 300-13

Continuous Duty, Definition, Art. 100

Continuous Load

- Applications, 210-23(b), 220-2, 384-16(c)
- Definitions, Art. 100

Continuous Rigid Cable

- Supports, Art. 318**
- Ampacity, 318-6
- Construction, 318-3
- Definition, 318-1
- Extension Through Walls, 318-4(g)
- Grounding, 318-5
- Installation, 318-4
- Spacing of Cables, Table 318-6(a)
- Use, 318-2

Control (see also Hazardous Locations)

- Panels, Clearance around, Elevators, 620-72
- Remote
 - Induction and Dielectric Heating Equipment, 665-

12

Low-Energy Power and Signal

- Circuits, Art. 725
- Overcurrent Protection, 240-5 Ex. 5
- X-ray Equipment, 660-B

Control Centers

- Guarding live parts, 110-17
- Headroom, 110-16(f)
- Illumination at, 110-16(e)
- Working spaces, 110-16

Controller(s) (see also Hazardous Locations)

Cases, Grounding, 250-43 (b)
Definition, Art. 100
Motor, Art. 430-G

Controllers (continued)
Resistors and Reactors
Conductor Insulation, 470-7
Incandescent Lamps as Resistors, 470-8
Welders, Electric, 630-21
Convenience Outlet, (see Receptacles)
Conversion Table, DC to AC conductor resistance, Table 9, Chap. 9
Cooking Unit, Counter-Mounted, Definition, Art. 100 (see also Ranges) (see also Ovens)
Copper Conductors (see Conductors, Copper)
Cords (see also Heater Cords) (see also Hazardous Locations)
Flexible Cords, Art. 400
Ampacities, Table 400-9(b)
Lampholders, Insulating Bushings, 410-24
Lighting Fixtures, 410-14
Motion-Picture Projectors, 540-15
Overcurrent Protection, 240-5, 400-9
Power and Signal Circuits, Remote-control, Low-energy, 725-13
Prohibited uses, 400-4
Pull at joints and terminals, 400-10
Sound Recording, Similar Equipment, Grouping Conductors, 640-7
Splices and Taps prohibited, 400-5
Types, Table 400-11
Tinsel, minimum size, 400-7
Overcurrent Protection, 400-9
Uses, 400-3
Corrosion, Protection, metal equipment, 300-5
Corrosive Conditions
Conductor Insulation, 310-7
General, 110-11

Couplings

Electrical metallic tubing,
348-8

Rigid metal conduit, 346-9

Rigid nonmetallic conduit,
347-6

Running threads at, 346-9(b)

Cove Lighting, Space for, 410-9**Covers**

Auxiliary Gutters, 374-4

Boxes and Fittings, 370-15

Switches, Flush Snap, 380-9

Cranes(s), Art. 610

Conductors, 610-B, 610-C

Control, 610-D

Flexible Cords, 400-3

Grounding, 250-7, 250-43,
610-F

Hazardous Locations, 503-13

Motors and Controllers,

Disconnecting Means,

430-112

Overcurrent Protection, 610-

E**Cross-Sectional Areas,**

Conductors, Table 5, 6, 7,
8,

Chap. 9

Conduits, Table 4, Chap. 9

Current-Carrying Capacities

(see Ampacities)

Current Limiting Devices (see

Circuit Breakers and Fuses)

Curtain Motors, Theaters,

Halls, etc., 520-48

Cutout

Bases (see Fuseholders)

Box, Definition, Art. 100

Boxes and Cabinets, Art. 373

Thermal (see Thermal Cutout)

Cutting Tables, Motion

Picture,

530-D

Damp Location, Definition,

Art. 100

Damp or Wet Locations

Boxes and Fittings, 370-5

Cabinets and Cutout Boxes,
373-2

General, 110-11

Lampholders, 410-43

Lighting Fixtures, 410-4

Open Wiring, 320-14

Overcurrent Protection,

Enclosure, 240-17

Panelboards, 384-17

Receptacles, 410-54

Damp or Wet Locations

(continued)

Rosettes, 410-58

Damper (Flue), Control, Fixed
Stage Equipment, 520-49

Dance Halls, Art. 520

Data Processing Systems,

Art. 645

Circuits and Interconnecting
Cables, 645-2

Disconnecting Means

General Building Areas,
645-3(b)

Processing Rooms, 645-3(a)

Grounding, 645-4

Marking, 645-5

Dead Ends

Busways, 364-5

Wireways, 362-9

Dead Front, Stage
Switchboards,

520-21

Definitions

90-4, Art. 100

Deflection of Conductors

Auxiliary gutters, 374-9(e)

Cabinets and cutout boxes,
373-6

Deicing and Snow Melting

Installations, 424-G

Complete units required,
424-73

General rules, 424-71

Grounding, 424-79

Installation of heating
cables, units, panels,
424-75

Installation of nonheating
leads, 424-76

Junction Boxes, 424-78

Marking of units, 424-77

Nonheating leads factory
assembled, 424-74

Test, 424-80

Use, 424-72

Delta-Connected, 4-Wire,
3-Phase Supply, Identifying
high leg, 200-6(c)

Demand Factor (see also
Load(s)), Definition,
Art. 100

Demand Loads for Household
Cooking Appliances,

Table 220-5

Depth of Boxes, Boxes and Fittings, 370-14
Detached Buildings, Oil-insulated transformers in, 450-24(d)
Detearing Equipment, Electrostatic, 516-4
Deteriorating Agencies, General, 110-11
Device, Definition, Art. 100
Diagrams
 Feeders, 215-6
 Motor and Feeder and Branch Circuits, 430-1(a)
Dielectric Heat Generating Equipment Art. 664 (see Inductive and dielectric Heat Generating Equip.)
Differential Protection
 Motors over 600 volts, 430-124(c)
 Swimming pool lighting circuits, 680-4(g-2)
Different Systems, Conductors, in same enclosure, 300-23, 725-16
Dimensions
 Conductors, Tables 5 thru 7, Chap. 9
 Conduit and Tubing, Percent Area, Table 4, Chap. 9
Dimmers, Stage Switchboards, 520-25, 520-53(e)
Dip Tanks, Paint, Art. 516
Direct Burial
 Rigid nonmetallic conduit, 24 in., 347-2(a); Bulk-storage plants, 515-5(a); service stations, 514-8
 Underground feeder and branch circuit cable, not less than 18 in. when unprotected, 339-3(c)
 Underground service cable, 230-32(a), 310-6
DC Resistance Conversion to AC Resistance, Table 9, Chap. 9
DC Systems, Grounding, 250-3, 250-4, 250-22

Disconnecting Means
 Appliances, 422-D
 Capacitors, 460-8(c)
 Cranes, 610-D
 Definition, Art. 100
 Elevators, 620-51
 Fuses and Thermal Cutouts, 240-18
 Induction and Dielectric Heating Equipment, 665-8
 Mobile Homes, 550-4
 Motor and Controllers, 430-H, 430-126
 Services, 230-J
 Connections, Ahead of, 230-73
 Over 600 Volts, 230-103
 Signs, 600-2
 Travel Trailers, 551-4
 Welders, Resistance, 630-33
 X-ray Equipment, 600-4, 660-14
Discontinued Outlets
 Cellular Concrete Floor Raceways, 358-11
 Cellular Metal Floor Raceways, 356-7
 Underfloor Raceways, 354-7
Dissimilar Metals, 110-14, 250-116, 346-1, 348-1
Door(s), Transformer vaults, 450-43
Double Insulated, Appliances and Tools, 250-45
Double-Pole, Switched Lampholders, 410-46
Drainage
 Capacitor charge, 460-6
 Equipment, 501-5(d)
 Oil-insulated outdoor transformers, 450-25
 Oil-insulated lightning arresters, 280-22
 Raceways, 230-101(g)
 Transformer vaults, for, 450-46
Dressing Rooms
 Motion Picture Studios, 530-C
 Theaters, Assembly Halls, etc., 520-F

Drip Loops, Conductors
Entering
Buildings, 230-49
Service heads, 230-51
Drip Pans, Generators, 445-3
Driveways
Clearance of conductors,
730-18(a)
Clearance of service drop,
230-26
Protection of service-
entrance cables, 230-46
Drop, Service, Definition,
Art. 100
Drop, Voltage, 210-6(c), 215-3
Dry Location, Definition,
Art. 100 (see damp or wet
locations)
Dryers, Clothes
Grounding, 250-60
Demand factors, Table 220-6
Dry-Type Transformers, 450-21
Dual-Voltage Motor, Locked
rotor rating, 430-7(b-3)
Duct(s)
Air Handling, 300-21, 300-22
Bare grounded neutral
underground, 230-30(a),
Ex. 2
Sealing at building from
underground system, 230-33
Underground services,
230-32(a)
Ventilating, 300-21, 300-22
Wiring in, 300-22
Duct Heaters
Installation of, 424-F
Dumbwaiters (see Elevators),
Art. 620
Dusts (see Hazardous
Locations)
Dust-Ignition-Proof, 502-1
Dustproof, Definition, Art.
100
Dust-tight, Definition,
Art. 100
Duty, Type, Definition,
Art. 100
Duty Cycle (Welding), 630-31

Dwellings (see also
Appliances,
Boxes, Branch Circuits,
Fixtures, Grounding, and
similar general
categories)
Branch Circuit Voltages,
210-6(b)
Clothes Dryers, Demand
Factors, Table 220-6
Farm, services, 220-4(m)
Feeder Load, Calculations
for, 220-4, 220-7, Exc. 1,
and 4, Part B, Chap. 9
Lighting Loads for, Table
220-2(a)
Panelboards as services,
384-16(a), 384-3(c)
Ranges, Demand Load,
Table 220-5
Receptacle Circuits
Required,
220-3(b)
Receptacle Outlets Required,
210-22(b)
**Elbows, Metallic, Protection
from Corrosion,** 300-5
Electric Discharge Lighting
Connection to Fixtures,
410-14
More than 1000 Volts, 410-Q
1000 Volts or less, 410-P
Signs and Outline Lighting,
Art. 600
Wiring, Equipment, 410-P,
410-Q
Electric Welders (see Welders)
Electrical Metallic Tubing,
Art. 348
Bends, How Made, 348-9
Bends, Number in one run,
348-10
Connectors and couplings,
348-8
Construction Specifications,
348-B
Minimum and maximum sizes,
348-5
Number of Conductors in,
348-6
Reaming of, 348-11
Supports for, 348-12
Threads on, 348-7

Uses permitted for, 348-1
Wet Locations, in, 348-4

Electrode, Grounding

Common, to be Used to Ground
Conductor Enclosures and
Equipment, 250-54
Concrete encased, 250-83(a)
Gas Piping as, 250-82(b)
Made (wire in concrete
footing, driven Pipe, Rod,
or Buried Plate), 250-83
Metal Frame of Building as,
250-82(a)
Metallic Water Piping
System,
250-81
Railway tracks, 250-85
Resistance to Ground of,
250-84

Electrostatic Equipment,
Spraying and Detearing,
Paint, 516-4

Elevators, Dumbwaiters, Escalators, and Moving Walks,

Art. 620
Cables, 620-E
Conductors, 620-B, 620-C,
620-D
Control, 620-F
Grounding, 250-43(c), 620-J
Machine Room 620-H
Overcurrent Protection, 620-

G

Overspeed Equipment, 620-K

Emergency Systems, Art. 700

(see also Stand-By Power
Generation Systems,
Art. 750
Circuits, 700-C
Connection at Services,
230-73, 230-74
Control, 700-D
Overcurrent Protection,
700-E, 700-21
Power, Supply, 700-B
Service Disconnecting Means,
230-74
Service-drop Conductors,
230-2, Exc. 2
Unit Equipment, 700-F

Enamel, Coating of

Electrical Metallic Tubing,
348-1

General Equipment, Indoor
Use

Only 300-5(a)

Metal Boxes, 370-5

Metal Cabinets, 373-10(a)

Removing, for grounding
connections, 250-75

Rigid Metal Conduit, 346-1

Enclosed, Definition, Art. 100

Enclosure(s) (see also
Hazardous Locations)

Arcing Parts, General, 110-
18

Cabinets, Cutout Boxes,
Space, 373-7, 373-9, 373-
11

Cranes Hoists, Resistors,
610-2

Elevators, Dumbwaiters,
Escalators, Moving Walks
Live Parts, 620-3

Machine, Controller, 620-H

Induction and Dielectric
Heating, 665-22

Installations over 600 Volts,
710-31

Mercury-Vapor Lamp Aux.
Equip., 410-50

Overcurrent Protection, 240-

C

Panelboards, 384-18

Radio Equip., 810-71(a)

Signs, Outline Lighting,
600-8, 600-34(g)(h)

Switches, 380-3

Grounding, 380-12

Energy-Limiting, Class 2

Control and Signal Circuits,
725-31

Enforcement, Code, 90-7

Equipment (see also separately
listed items)

Definitions, Art. 100

Examination of, 90-8, 110-4

Grounding, 250-E

Installation, General

Provisions, Art. 110

Less than 50 Volts, Art. 720

More than 600 Volts, Art.

710

Mounting of, 110-13

Sealable, Definition,
Art. 100

Service, Definition, Art.
100

Escalators (see Elevators),
Art. 620
**Examination of Equipment for
Safety**, 90-8
Examples (Computations)
Chap. 9, Part B
Exciter(s)
Leads in same enclosure as
motor, control, relay, and
ammeter Conductors,
300-3(e)
Overcurrent Protection for,
when used with constant
potential AC Generators,
445-4(a)
Exhaust Ducts, Wiring in,
300-22
Exits, Emergency Lighting for,
Art. 700
Explosive Atmospheres, Gases,
Liquids, Dusts, Ignitable
Fibers, Lints and Flyings
(see Hazardous Locations)
Explosion-Proof, Definition,
Art. 100 (see also Hazardous
Locations)
Exposed (see also Enclosure)
Extensions, Boxes, and
Fittings, 370-12
Live Parts, Definition,
Art. 100
General, 110-16
Wiring Methods, Definition,
Art. 100
Extension(s)
Auxiliary Gutters, Beyond
Equipment, 374-2
Boxes and Fittings, Exposed,
370-12
Cellular Concrete Floor
Raceways, 358-4
Cellular Metal Floor
Raceways, Connection to
Cabinets, 356-11
Nonmetallic, Art. 342
Underfloor Raceways, 354-15
Underplaster, Art. 344
Wireways, From Wireways,
Through Walls, 362-8,
362-10
Externally Operable,
Definition, Art. 100

**Face Plates, Switches,
Receptacles, to Grounding**,
410-95(a)
Minimum Thickness for, 380-
9,
410-52(b)
Factors, Multiplying
Converting DC Resistance to
AC resistance, Table 9,
Chap. 9
**Farm Buildings, Feeder
Calculations**, 220-4(1)
Feeder(s), Art. 215, Art. 220
Bare Conductor, Art. 328
Calculation of Loads, 220-4,
220-7, Part B, Chap. 9
Definition, Art. 100
Farm Buildings, for, 220-
4(1)
Grounding Means, 215-7
Motor, Art. 430-B
Outside Branch Circuits,
Art. 730
Overcurrent Protection
Motor, 430-E
Supply Stations, 240-9
Taps in Inaccessible
Locations, Motors, 430-59
Taps, 10 ft. and 25 ft.,
240-15 Excs. 5 and 6
**Ferrous Metals, Protection
from
corrosion**, 300-5
**Festoon Lighting, Outside
Wiring**, 730-6, 730-13
Supports, outside Circuits,
730-13
**Festoons, Portable Stage
Equipment**, 520-65
Fiber Bushings, AC Cable Ends
334-10(b)
**Fibers, Lint, Flyings,
Ignitable** (see Hazardous
Locations), Art. 503
Film(s), Motion Picture
Projectors, Art. 540
Projectors, Marking, 540-34
Storage, 530-E, 540-22
Viewing, Cutting, Patching
Tables, 530-41
Finishing Processes, Art. 516
Fire Alarms
Circuits, Art. 800

Connections at Services,
230-73, 230-94(d)

Fire Pump(s)

Connections at Services,
230-73, 230-94(b)
Emergency Power Supply,
Art. 700
Motors, Overcurrent
Protection, 430-31
Remote-control Circuits,
430-72
Service Drops, 230-2

Fire-Stopped Partitions, 300-
21

Firewall(s)

Dividing Buildings,
Definition of Building,
Art. 100
Wiring Through, 300-21

Fitting(s) (see also Wiring
Types)

Boxes and, Art. 370
Definition, Art. 100

**Fixed Electric Space Heating
Equipment,** Art. 424

Cables and Panels 424-E
Area Restrictions, 424-38
Clearances, Wiring
Ceilings, 424-36
Other Objects, Openings,
424-39
Walls, 424-37
Construction, 424-34
Finish, Ceilings, 424-42
Installation
Cables, 424-44
General, 424-48
Nonheating Leads, 424-43
Marking
Cables, 424-35(a)
Panels, 424-35(b)
Panels
Complete Units, 424-47
General, 424-46
Splices, 424-40
Tests, 424-45
Control and Protection, 424-

C

Controllers, 424-21
Disconnecting Means,
424-19, 424-21, 424-22
Location, 424-20
Indicating, 424-22
Motor Driven Equip.,
424-19(c), 430-H

Overcurrent Protection,
424-23

**Fixed Electric Space Heating
Equipment** (continued)

Duct Heaters, 424-F
Air Flow, 424-59
Approval, 424-58
Condensation, 424-62
Disconnecting means,
Location, 424-65
Elevated Inlet
Temperature,
424-60
Fan Circuit Interlock,
424-63
General, 424-57
Installation, 464-61,
464-66
Limit Controls, 464-64
General, 424-A
Branch Circuits
Requirements, 424-3 (a)
Sizing, 424-3 (b)
Installation, 424-B
Conductors, 424-11
General 424-9
Grounding, 424-14
Location
Exposed to Physical
Damage, 424-12- (G)
Wet Areas, 424-12 (b)
Spacing, Combustible
Materials, 424-13
Special Types, 424-10
Marking, 424-D
Heating Elements, 424-29
Name Plate, 424-28
Outdoor De-Icing and Snow
Melting, 424-G
Complete Units 424-73
General, 424-71
Grounding, 424-79
Installation
Cables, Units, Panels,
424-75
Nonheating Leads, 424-76
Junction Boxes, 424-78
Marking, 424-77
Tests, 424-80
Panels, 424-E
Fixed Equipment, Grounding,
250-42 through 250-44,
250-57, 250-58
Fixture Stud, Construction,
410-34

Fixture Wires, Art. 402
 Ampacities, Table 402-4
 Types, Table 402-6
Fixtures (see Lighting
 Fixtures)
Flame-Retardant Braid,
 Conductors, More than 600
 Volts, 710-4
Flammable Anesthetics, Art.
517
 (see also Hazardous
 Locations)
Flammable Gases and Vapors
 (see
 Hazardous Locations)
Flammable Liquids (see
 Hazardous Locations)
Flashers, Time Switches,
 Similar Devices, 380-5
Flatirons, Smoothing, 422-13
 Signals required, 422-12
 Stands for, 422-11
 Temperature-limiting means
 required, 422-8
Flexible Cords (see Cords,
 Flexible), Art. 400
Flexible Metal Conduit,
 Art. 350
 Minimum size, 350-3
 Supports, 350-4
 Use, 350-2
Floors, Receptacles, 410-53
Flue-damper Control, Fixed
 Stage Equipment, 520-49
Fluorescent Lighting Fixtures
 Auxiliary equipment, remote
 from, 410-75
 Ballast protection required,
 410-71(e)
 Connection of, 410-14
 Load calculations
 Ampere ratings, ballasts
 210-23(b)
 Branch circuits, 210-24
 Raceways, 410-26
 Snap Switches for, 380-14(c)
 Special provisions, 1000
 Volts or less, 410-P
 Special provisions, 1000
 Volts or less, 410-Q
Fluoroscopic Equipment,
 Art. 660
Footlights, Theaters, Assembly
 Halls, etc. 520-43

Forming Shells, Underwater
Swimming Pool Lighting
Fixtures, 680-4

Full-load Current, Motors

Alternating Current

Single Phase, Table 430-
148

Three Phase, Table 430-150

Two Phase, Table 430-149

Direct Current, Table 430-
147

Fundamental Rules, 90-5

Furnace, Circuits, Grounding,
Transformers, Installation,
450-24(c)

Fuseholders

Cartridge Fuses, 240-F

Link Fuses, 240-G

Over 600 Volts, 710-21(b)

Plug Fuses, 240-E

Rating, Motor Controllers,
430-90

Type S, 240-22

Fuses, Art. 240 (see also

Hazardous Locations)

Cartridge, 240-F

Disconnecting Means, 240-18

Enclosures, 240-C

General, 240-6

Generators, Constant-

Potential, 445-4(a)

Group installation of
motors,

430-53(c)

In parallel, 240-14

Link, 240-G

Location, 240-19(a), 240-16

Marking, 240-20(c),

240-22(i), 240-23(c),

240-24(f)

Motor-Running Overcurrent

Protection, 430-C

Motor Branch Circuit

protection, 430-D

Plug, Edison-base Type,

Classification and

Marking,

240-E

Potential (Voltage)

Transformers, 450-3(c)

Ratings, 240-6

Services Over 600 Volts,

230-106(c)

Shielding, 240-19
Spaces in Cabinets and
Cutout
Boxes, 373-11(a)

Fuses, (continued)

Time-delay plug-type in
residential occupancies,
240-4

Time-lag, not in control
circuits, 240-5, Exc. 5

Type S, 240-22

373-6 (b)

Number of, in Raceways,
300-17

Supporting, Vertical
Raceways, 300-19

Expansion Joints, Raceways,
300-19

Garage(s)

Commercial, Art. 511

Definition, Art. 100

Elevators, Dumbwaiters,
Escalators, Moving Walks,
in, 620-52

Grounding, Fixed Equip.,
250-43

Residential, Art. 512

Gases (see Hazardous
Locations)

Gas Pipe

As Grounding Electrode,
250-82 (b)

Grounding Conductor, Point
of

Attachment, 250-112 (b)

Gasoline Bulk-Storage Plants,

Art. 515 (see also Hazardous
Locations)

**Gasoline Dispensing and
Service**

Stations, Art. 514 (see also
Hazardous Locations)

Conductor Insulations where
exposed to gasoline, 501-

13

Gages, Conductor, General,
110-6

**General Provisions,
Installation of Wiring and
Equipment,** Art. 110

**General Requirements for
Wiring**

Methods, Art. 300

Boxes or Fittings, Each
Outlet, 300-15

Changing Raceway, Cable to
Open Wiring, 300-16 (a)

Conductors

Different Systems, 300-3
Inserting in Raceways,
300-18

Insulating Bushings, for
Raceways No. 4 or
Larger,

General Requirements for Grounded, Definition, Art. 100
Wiring

Methods, (continued)

Exhaust and Ventilating

Ducts, Wiring 300-22

Free Length of Wire at

Outlets, 300-14

Grounding Metal Enclosures,
300-9

Induced Currents in Metal
Enclosures, 300-20

Mechanical and Electrical
Continuity, Conductors,
Raceways, Cables, 300-10,
300-12, 300-13

Protection Against
Corrosion, 300-5

Physical Damage, 300-4

Prevention of Fire Spread,
300-21

Sealing, Raceways, Change in
Temperature, 300-6(a)

Secured in Place, Wiring and
Equipment, 300-11

Temporary Wiring, 300-23

Through Studs, Joists,
Rafters, 300-8

Underground Runs, 300-7

Voltage Limitations, 300-2

Generator(s), Art. 445

Balancer Sets, 445-4

Bushings, 445-9

Conductor Sizes, 445-5

Drip Pans, 445-3

Emergency Systems, 700-8

Grounding, 250-43, 445-8

Guards for Attendants, 445-7

Location, 445-1

Marking, 445-2

Overcurrent Protection, 445-

4

Protection of Live Parts,
445-6

Set, Emergency System, 700-8

Stand-by Power, Art. 750

**Goosenecks, Service Cables,
Forming and Connecting to
Service-Drops 230-51**

Ground

Clamps, 250-116

Definition, Art. 100

Voltage to, Definition,
Art. 100

Grounded, Effectively,
 Communication System,
 Definition, 800-2(d) (4)
Grounded Conductor (see also
 Conductors)
 Definition, Art. 100
Grounded System, Polarity
 Identification, 200-6
Grounding, Art. 250
 AC Systems, 250-5, 250-23,
 250-25
 Air Conditioning Units,
 422-41, 250-45
 Antenna (see Grounding,
Radio
 and TV)
 Appliances, 422-16
 Bonding, 250-G
 Capacitors, 460-10
 Circuits, 250-A, 250-B
 Less than 50 Volts, 720-10
 Clothes Washers, Dryers,
 250-45, 250-60
 Conductor(s), 250-J
 Connections, 250-K, 250-
113
 Definition, Art. 100
 Enclosures, 250-D
 Installation, 250-92
 Sizes, 250-95
 Connections, Location, 250-
C,
 250-K
 Continuity, 250-75
 Control Circuits, Class 1,
 725-21; Class 2, 725-44
 Controls, Radio Equipment,
 810-71(b)
 Cranes and Hoists, 610-51
 Deicing, Snow Melting
 Systems, 424-79
 Dish Washing, 250-45
 DC Systems, 250-3, 250-4,
 250-22
 Electrodes, 250-H
 Elevators, 620-J
 Enclosures, Metal, Wiring
 Methods, 300-9
 Equipment, Cord Connected,
 250-45
 Fixed Equipment, 250-42,
 250-43
 Fixtures, Lampholders, etc.,

410-R
Freezers, 250-45
Generators, 445-8

Grounding, (continued)

Hazardous Locations, 501-16,
502-16, 503-17
Induction and Dielectric
Heating Equipment, 665-D
Instrument Transformers,
Relays, etc., 250-L
Isolated Systems, 250-26
Lightning Arresters, 250-M
Location of Connections,
250-C, 250-K
Metal Faceplates 8 ft.
Vertically or 5 ft.
Horizontally from Grounded
Surfaces, 410-95(a)
Metal Enclosures for
Conductors, 250-33
Metal Siding, 250-44
Methods, 250-F
Mobile Homes, 550-9
More than 600 Volts Between
Conductors, 710-6, 710-7
Motion Picture Studios,
530-20, 530-66
Motors and Controllers, 430-
L
Nonelectrical Equipment,
250-44
Organs, 650-3
Portable Equipment, 250-45
Radio and Television, 810-
15,
810-21 thru 810-29, 810-58
thru 810-60, 810-71
Ranges and Similar
Appliances, 250-60
Receptacles, 250-74, 410-55
(see also Hazardous
Locations)
Bonding at Boxes, 250-74,
250-114
Branch Circuits must
Include Grounding
Conductor for, 210-7
Connections to Circuits of
Two or More Outlets,
Minimum and Maximum
Ratings of, 210-21(b)
Design of, 410-55
Grounding-Type, 210-7,
250-74, 410-55
Minimum Rating of,
410-52(a)

When Required, for New
Work

and as Replacements,
210-21(b)

Grounding, (continued)

Refrigerators, 250-45
Services, 230-63
Signs and Outline Lighting,
600-5
Sound Recording Equip.,
640-4(b), Exc. 4
Swimming Pools, 680-7
Switchboard Frames, 384-12
Switches, 380-12
Systems and Circuits, 250-A,
250-B
Theaters, Assembly Halls,
etc., 520-81
Tools, Motor Operated, 250-
45
Transformers, 450-8
Travel Trailers, 551-9
X-ray Equipment, 660-E

Grounding Type Attachment

Plugs, Design of, and Use
with Movable, Self-
restoring-
type Grounding Members,
410-55

**Grouping, Switches, Circuit
Breakers, 380-8**

**Group Installation, Motors,
430-53**

Guarded, Definition, Art. 100

Guarding, Guards (see also
Enclosures and Live Parts)
Circuit Breaker Handles,
240-19(b)
Elevators, Dumbwaiters,
Escalators, Moving Walks,
620-71
Generators, 445-7
Handlamps, Portable, 410-37
Lamps
Motion-Picture Projectors,
540-16
Theaters, Assembly Halls,
Dressing Rooms, etc.,
520-44, 520-47, 520-61,
520-65, 520-71, 520-72
Live Parts, General
Provisions, 110-17
Motion Picture Studios,

530-15, 530-64
 Motors, Motor Controllers,
 Live Parts, 430-K
 Motors, Portable, 430-143
 Over 600 Volts, 710-5,
 710-34
 Transformers, 450-7

Gutters, Auxiliary (see
 Auxiliary Gutters)
Handlamps, Portable, 410-37
Hangars, Aircraft, Art. 513
Hazardous Areas (see Hazardous
 Locations), Art. 500
Hazardous Atmospheres, Art.
 500
 Class I Locations, 500-4
 Class II Locations, 500-5
 Class III Locations, 500-6
 Specific Occupancies, 500-3
 Special Precautions and
 Groups A-G, 500-2
Hazardous Locations, Art. 500,
 TIA 146
 Aircraft Hangars, Art. 513
 Anesthetics, Flammable,
 Art. 517
 Bulk Storage Plants, Art.
 515
 Dusts, Explosive, Art. 502
 Fibers, Flyings, Lint,
 Highly
 Combustible Materials,
 Art. 503
 Finishing Processes, Art.
 516
 Garages, Commercial, Art.
 511
 Garages, Residential,
 Art. 512
 Gases, Flammable, Art. 500,
 501
 Gasoline Service Stations,
 Art. 514
 Group Designations,
 Art. 500-2
 Liquids, Flammable, Art.
 500,
 501
 Tentative Interim Amendment,
 p. 70-465
 Vapors, Flammable, Art. 500,
 501

**Hazardous Location(s), Class
 I,**
 Art. 501, TIA 146 (Flammable
 Gases and Liquids)
 Bonding, 501-16(b), (d), (e)
 Circuit Breakers and Fuses,
 501-6
 Conductor Insulation 501-13
 Control Transformers and
 Resistors, 501-7
 Drainage of Equipment,
 501-5(d)
 Flexible Cords, 501-11
 Fuses and Circuit Breakers,
 501-6
 General, 501-1

**Hazardous Location(s),
Class I, (continued)**
Grounding, 501-16
Lighting Fixtures, 501-9
Lightning Protection,
501-16(c)
Live Parts, 501-15
Meters, Instruments, and
Relays, 501-3
Motor Controllers, 501-6
Motors and Generators, 501-8
Receptacles and Attachment
Plugs, 501-12
Sealing Fittings and
Compound, 501-5(c)
Signal, Alarm, Remote-
control, and Communication
Systems, 501-14
Switches, 501-6
Tentative Interim Amendment,
p. 70-465
Transformers and Capacitors,
501-2
Utilization Equipment, 501-
10
Wiring Methods, 501-4

**Hazardous Location(s),
Class II, Art. 502 (Dusts)**
Bonding, 502-16(b), (d), (e)
Circuit Breakers and Fuses,
502-6
Control Transformers,
Resistors, 502-7
Dusts, 502
Flexible Cords, 502-12
Fuses and Circuit Breakers,
502-6
General, 502-1
Grounding, 502-16
Lighting Fixtures, 502-11
Lightning Protection,
502-16(c)
Live Parts, 502-15
Motor Controllers, 502-6
Motors and Generators, 502-8
Receptacles and Attachment
Plugs, 502-13
Sealing, 502-5
Signal, Alarm, Remote-
control, and Intercom
Systems, 502-14
Surge Protection, 502-3
Switches, 502-6

Transformers and Capacitors,
502-2
**Hazardous Location(s),
Class II, (continued)**
Utilization Equipment, 502-
10

Ventilating Piping, 502-9
Wiring Methods, 502-4
**Hazardous Location(s),
Class III, Art. 503 (Fibers,
Flyings, Lint)**
Circuit Breakers and Fuses,
503-4
Control Transformers,
Resistors, 503-5
Electric Cranes and Hoists,
503-13
Electric Trucks, 503-14
Flexible Cords, 503-10
Fuses and Circuit Breakers,
503-4
General, 503-1
Grounding, 503-17
Lighting Fixtures, 503-9
Live Parts, 503-16
Motor Controllers, 503-4
Motors and Generators, 503-6
Receptacles and Attachment
Plugs, 503-11
Signal, Alarm, Remote-
Control
and Intercom Systems,
503-12
Storage-Battery Charging,
503-15
Switches, 503-4
Transformers and Capacitors,
503-2
Utilization Equipment, 503-8
Ventilating Piping, 503-7
Wiring Methods, 503-3

Header (s)
Cellular Metal Floor
Raceways, 356-1, 356-2,
356-5, 356-6
Cellular Concrete Floor
Raceways, 358-1, 358-2,
358-3, 358-6, 358-7
Structural Raceways,
357-1(b), 357-5, 357-7
Header Duct(s), Art. 358
Heat Generating Equipment,
Art. 665

Heater Cords, Table 400-11,
422-8(a)
Heater Elements, Marking,
422-31

Heating Appliances

Calculations, Art. 220
Grounding, 250E
Installation, 422C
Marking, 422E
Overcurrent Protection, 422D

Heating Cables, Art. 424

Heating, Fixed Electric Space,
Art. 424

Heavy-Duty Lampholders

Branch Circuits, 210-24,
Table 210-25
Definition, 210-8
Unit Loads, 220-2(b)

Hermetic Type Refrigeration

Compressors (see
Refrigeration)

Hoists and Cranes, Art. 610

Disconnecting Means - Motors
and Controllers, 430-112,
610-D

Flexible Cords, 400-3

Hoistway, Definition, Art. 100

Hood, Metal

Theaters, Assembly Halls,
etc., 520-24

Hospitals

Anesthetizing Locations in,
Art. 517

Emergency Light and Power
Systems, Art. 700

Hotels

Emergency Light and Power
Systems, Art. 700

Identification

Flexible Cords

Grounded Conductor, 400-13
Grounding Conductor, 400-

14

Grounded Conductors, Art.
200

Identified, Definition,
Art. 100

Immersion Heaters, Portable
Types, 422-9

Incandescent Lamps (see also
Hazardous Locations)
Guards

Aircraft Hangars, 513-5(a)
Garages, 511-6(b), (c)
Projection Booths, 540-16
Theater Dressing Rooms,
520-72

Medium-base Lampholders,
410-49

Incandescent Lamps (continued)
Mogul-base Lampholders,
410-49

Resistors, 470-8

Snap Switches for, 380-14(b)

Independent

Emergency Lighting Supply,
700-15(a)

Emergency Power Supply,
700-15(b)

Supports, Services, Over
Buildings, 230-25

Wiring, Emergency Circuits,
700-17

X-ray Control, 660-14

Individual Branch Circuit(s)

Definition, under Branch
Circuit, Art. 100

May Supply Any Load, 210-24

Overcurrent Protection,
Single Appliance, 210-
20(b)

Induced Currents, Metal

Enclosures, 300-20

Induction and Dielectric

Heating, Art. 665

Guarding and Grounding, 665-
D

Output, 665-9, 665-10, 665-
18

Power Supply, 665-B, 665-C

Therapeutic, 665-E

Inductive Loads

Switches, Types, Ratings,
Lighting Fixtures,
380-14(c)

Motors, 430-83, 430-109

Signs, 600-2(b)

Infrared Lamp Industrial

Heating Appliances

Branch Circuits, 210-24(d)

General Rules, 422-15

Overcurrent Protection,
422-27(c)

Inserting Conductors in

Raceways, 300-18

Inserts

Cellular Concrete Floor

Raceways, 358-7

Cellular Metal Floor

Raceways, 356-10

Underfloor Raceways, 354-14

In Sight From

Motors, Motor Controllers,
430-4
Signs, 600-2(a)

Institutions, Emergency
Lighting, Art. 700
Instrument Transformers,
Grounding, 250-L
Instruments, Meters, Relays
Grounding, 250L
Hazardous Locations, Class
1,
501-3
Insulating Joints, Fixtures on
Metal, Metal Lath, Ceilings,
Walls, 410-93
Insulating Links, Metal Pull
Chains, Lighting Fixtures,
410-95(b)
Insulation
Conductor, Art. 310
General, 310-2, 310-3
Hazardous Locations,
Class I Installations,
501-13
Motion-Picture Projectors,
540-14
Theaters, Assembly Halls,
etc., 520-42
Double, 250-45
Fixture Wire, 402-3,
Table 402-6
Flexible Cords, Table 400-
11,
400-C
Appliances, 422-3
Over 300 Volts, 400-8
Resistance, General, 110-20
Heating Cables, 424-E
Service Conductors, 230-4,
230-22, 230-30, 230-40
Splices and Joints, 110-15
Insulators, Open Wiring,
Art. 320
Intercommunication Systems,
Art. 800 (see also Hazardous
Locations)
Intermittent Duty, Definition,
Art. 100
Interpretation(s), 90-6,
Official, How to Obtain,
Part D, Appendix
Interruption **Capacity**,
General,
110-9
Intrinsically Safe Equipment,
Hazardous Locations, 500-1

Introduction, Art. 90
Irons, Smoothing, 422-13

Isolated

Definition, Art. 100
Systems, Grounding, 250-26

Isolation by Elevation

Circuits over 600 Volts,
710-11

Joints (see also Splices and
Taps)

Grounding Conductor,
250-91(a)
Insulation, Fixtures, 410-93
Insulation of, 110-15
Strain at, Fixtures, 400-10
Wrenchtight, Conduit
Grounding Conductor,
250-91(b)

Joists

Boxes on, 370-13(b)
Concealed Knob and Tube
Work,
Attics, Roof Spaces, 324-8
Holes through or Notches in,
300-8
Metal-clad Cable
Exposed, 334-12
In Accessible Attics,
334-13
Nonmetallic Sheathed Cable,
in Basements, 336-8
Open Wiring, Crossing, 320-
12

Jumpers, Bonding

Conduit Joints, Hazardous
Locations, 500-1
Expansion Joints,
Telescoping
Sections of Raceways,
250-77
Grounding-Type Receptacles,
250-74
Material, Size and
Attachment, 250-79
Service Equipment, 250-72

Junction Boxes (see also Boxes
and Pull Boxes)

Accessibility, 370-19
Cellular Concrete Floor
Raceways, 358-5
Cellular Metal Floor
Raceways, 356-9
Covers, 370-15, 370-18(c)
Deicing and Snow Melting
Cables, 424-78

Motor Controllers and
Disconnects not used for,
430-10

Junction Boxes (continued)
Nonheating Cable Leads,
424-43
Separation, from Motors,
430-145 (b)
Size,
Conductors No. 6 and
Larger, 370-18
Conductors No. 6 and
Smaller, 370-6
Construction
Specifications, 370-C
Swimming Pools, 680-5
Supports, 370-13
Switch Enclosures not for,
373-8
Underfloor Raceways, 354-13
**Keying, Induction and
Dielectric Heating
Equipment,**
665-20
Knife Switches
Connection, 380-7
Construction Specifications,
380-B
Enclosures, 380-3
Position, 380-6
Ratings, 380-13
Knob and Tube Work, Art. 324
Knockout(s)
Bonding Service Equipment,
240-72 (d)
Openings to be Closed, 370-
7,
370-8
Labels
Cords, Flexible, 400-12
Warning, Heat Generating
Equip., 665-25
Lacquers and Paints
Application, Art. 516
Atmospheres, 500-2, 500-4,
Art. 501
Lamp(s) (Lighting Fixtures),
Art. 410 (see also Hazardous
Locations)
Arc (see Arc Lamps)
Electric Discharge, 410-P,
410-Q
Fluorescent, Art. 410
Guards (see Guarding and
Guards)
Handlamps (see Handlamps)

Incandescent, Art. 410
 Bases for, 410-49
 As Resistors, 470-8
Lamp(s) (Lighting Fixtures),
 (continued)
 Infra-Red (see Infra-Red
 Lamps)
 Mercury-Vapor, Enclosure of
 Resistor and Regulators,
 410-50
 Motion-Picture Projectors
 Nonprofessional Type,
 540-33
 Professional Type, 540-14,
 540-16
 Motion-Picture Studios, in
 Film Storage Vaults, 530-
 51
 Stages, 530-16, 430-17
 Viewing, Cutting Tables,
 53-41
 Outdoor, Location, 730-26
 Portable
 Flexible Cords for, 400-3
 Motion-Picture Studios,
 in,
 530-16, 530-17
 Show-Windows, 400-6
 Theaters, Assembly Halls
 Border and Proscenium,
 520-44
 Dressing Rooms, 520-72
 Festoons, 520-65
 Footlights, 520-43
 Scene Docks, in, 520-47
 Stage Docks, in, 520-47
 Stage, Arc, 520-61
 Switchboards, Pilot
 Lights,
 520-53
 Wattage Marking, Flush and
 Recessed Fixtures, 410-68
Lampholders
 Branch Circuits Supplying
 15-20 amps, Medium-Base,
 210-24(a)
 30-50 amps, Heavy-Duty,
 210-24(b), (c), (d)
 Circuits Less Than 50V, for,
 720-5
 Construction, 410-H
 Damp or Wet Locations, 410-
 4,
 410-43
 Double-Pole Switched, 410-42
 Heavy-Duty,
 Defined, 210-8
 Unit Loads, 220-2(b)
 Infra-red Lamps, 422-15
 Outdoor Lighting, 730-25

Lampholders (continued)

520-63

Pendant

Not in Clothes Closets,
410-8

Not in Theater Dressing
Rooms, 520-71

Screw-shell Types for Lamps
only, 410-41

Signs and Outline Lighting,
600-22

Unswitched Over Highly
Combustible Material, 410-

6

Laundry Outlets, Dwellings

210-22(b), 220-3(b)

Length(s)

Busways used as Branch
Circuits, 364-13

Free Conductors at Outlets
and Switches, 300-14,
424-43, 424-76

Nonmetallic Flexible Tubing
with Open Wiring, 320-7

Nonmetallic Rigid Conduit,
347-16(a), (b)

Pull and Junction Boxes,
370-18(a) (1)

Rigid Metal Conduit,
346-14(a)

Space Heating Cable
Nonheating Leads, 424-43

Taps,

Cooking Appliances,
210-19(c), Exc. 5

Feeders, 10-ft. Rule,
240-15, Exc. 5; 25-ft.
Rule, 240-15, Exc. 6

Individual Lampholders or
Fixtures, 210-19(c),
Exc. 2(a)

Individual Outlets,
210-19(c), Exc. 2(b)

Motor Feeders, 25-ft.

Rule,

430-59

Light(s) (see also Lamps and
Lighting)

Border, Cables for,
Theaters,
520-44(b)

From Railway Conductors,
110-19

Scenery, Theaters, Halls,

Lighting

Branch Circuit(s),
Calculation of Load, 220-2
Emergency, Art. 700
Feeders, Calculation of
Load,
220-4
Fixtures (see Lighting
Fixtures)
Outlet, Def., Art. 100
Lighting Fixtures, Art. 410
(see also Hazardous
Locations)
Autotransformers, Ballasts
Supplying Fluorescent
Fixtures, 410-76
Supplying Circuits, 200-4
Auxiliary Equipment, 410-75
Boxes, Canopies, Pans, 410-C
Branch Circuits,
Sizes, 210-23, 210-24
Unit Loads, 220-2(a), (b)
Voltages, 210-6, 410-73
Clothes Closets, 410-8
Combustible Material, Near,
410-5
Connection,
Fluorescent, 410-14
General, 410-25
Construction of, 410-F, 410-
N
Corrosive (see Damp, etc.)
Coves, Adequate Space
Damp, Wet, or Corrosive
Locations, 410-4, 410-43
Electric Discharge Lighting
Systems 1000 V or less,
410-P;
Systems over 1000 V, 410-Q
Voltage-Dwelling
Occupancies, 410-73
Fluorescent, 410-P, 410-Q
Autotransformers in
Ballasts, 410-76
Ballast Protection,
410-71(e)
Connection, 410-14
Flush, 410-M
Grounding, 410-R
Live Parts, 410-3
Location, 410-B
Motion-Picture Studios,
Art. 530

Lighting Fixtures (continued)

Outdoor (see Damp, etc.)
Overcurrent Protection,
Wires
and Cords, 240-5, Exc. 3
Polarization, 410-27
Raceways, 410-26
Recessed, 410-M
Show Windows, 410-7
Supports, 410-D
Swimming Pools, 680-4
Theaters and Assembly Halls,
Art. 520
Wet (see Damp, etc.)
Wiring, 410-E
Lightning Arresters (see also
Lightning Protection and
Rods), Art. 280
Antenna Discharge Systems,
810-20
Connections at Services,
230-73
Grounding, 250-M
Industrial Stations, 280-A
Radio and Television
Equipment
Receiving Stations
(Antenna
Discharge Units), 810-20
Transmitting Stations,
810-57
Services Over 600 Volts,
230-107
Lightning Protection (see also
Lightning Arresters and
Rods)
As a Ground, 250-86
Spacing from Conductor
Enclosures and Equipment,
250-34, 250-46
Lint, Flyings (see Hazardous
Locations)
**Liquid-Tight Flexible Metal
Conduit**, Art. 351
Live Parts (see also
Enclosures, Guarding)
Appliances, Disconnecting
Means, 422-D
Capacitors, Guarding, 460-11
Generators, Protection, 445-
6
Guarding, General, 110-17
Hazardous Locations, 501-15,

502-15, 503-16
Lamp Terminals, Lampholders,
410-80

Lighting Fixtures,
Lampholders, Lamps,
Receptacles, Rosettes,
410-3
Lighting Systems, Electric
Discharge, 1000 Volts or
less, 410-P, Over 1000
Volts, 410-Q
Motors and Motor
Controllers,
430-K
Transformers, Guarding, 450-
7

Load(s)

Appliances, Household
Cooking, Demand Table,
220-5
Branch Circuits,
Calculations, Art. 220;
Part B, Chap. 9
Mobile Homes, 550-11
Branch Circuits, Maximum,
210-23, Table 210-25
Branch Circuits,
Permissible,
210-24, Table 210-25
Clothes Dryers, Demand,
Table
220-6
Feeders, Calculations,
Art. 220; Part B, Chap. 9
Mobile Homes, 550-11
Motors, Conductors, 430-B
Stage Equipment, Circuit
Loads, Theaters, Assembly
Halls, 520-41

Location(s)

Capacitors, 460-2
Cranes and Hoist
Disconnecting Means, 610-D
Definition, Art. 100
Electric Discharge Lighting
Transformers (over 1000
Volts), 410-84
Elevator Motor Disconnecting
Means, 620-51(b)
Foreign Pipes, Accessories,
Transformer Vaults, 450-47
Generators, 445-1
Grounding Connections at
Electrodes, 250-112
Hazardous (see Hazardous
Locations)
Junction Boxes, 370-19

Lamps Outdoors, 730-26
Lighting Fixtures, 410-B

Location(s) (continued)

Lighting Arresters,
Indoors, 280-21
Outdoors, 280-22
Mobile Home Disconnecting
Means and Branch-Circuit
Protective Equipment, 550-

4

Motion-Picture Projection
Equipment, 540-17

Motors, 430-14

Motor Disconnecting Means,
430-H

Motor Feeder Taps, 430-59

Overcurrent Devices, 240-B

Protection Devices for
Communication Circuits,
800-2(a)

Resistors and Reactors, 470-

1

Service Heads, 230-51

Service Overcurrent
Protection, 230-91, 92, 93

Splices and Taps, Auxiliary
Gutters, 374-8(a)

Sign Switches, 600-2(a)

Swimming Pool Junction Boxes
and Transformer

Enclosures,

680-5

Switchboards, 384-4, 384-6

System Ground Connection,
250-52

Transformers and Vaults,
450-2

Travel Trailer Disconnecting
Means and Branch-Circuit
Protective Equipment, 551-

4

Ventilation Openings for
Transformer Vaults,
450-45(a)

Wet (see Wet Locations)

Locked-Rotor, Motor Current

Code Letters, 430-7

Conversion Table, 430-151

Refrigeration Compressors,
430-83, Exc. 3, 430-110

**Locknuts, Double Where
Required**

Over 250 Volts to Ground,
250-76(b)

Wholly Insulated Bushings

Used, 373-6(b)
Low-Energy Power Circuit,
Art. 725 Definition, Art.
100
Low-Energy, Remote-control,
Low-Voltage Power and Signal
Circuits, Art. 725
Lugs
Connection to Terminals,
General, 110-14
Solderless Type at
Electrodes, 250-115;
Connection of Service
Conductors, 230-72
Made Electrodes (see
Electrodes, also Grounding)
Markings (see articles on
wiring and equip. involved)
Mechanical Execution of Work,
110-12
Mercury-Vapor Lamps,
Enclosures
for, 410-50
Metal-Clad Cable, MC and AC
Series, Art. 334
Accessible Attics, Type AC
Cable in, 334-13
Anti-Short Bushings, at
Ends,
334-10(b)
Bends, 334-9
Conductors
Type AC, 334-5(b)
Type MC, 334-5(a)
Construction
Type AC, 334-4(b)
Type MC, 334-4(a)
Definition, 334-1
Exposed Work, 334-12
Marking, 334-3
Supports, 334-8
Through Studs, Joists, and
Rafters, 300-8
Uses
Type AC, 334-6(b)
Type MC, 334-6(a)
Voltages, 334-2
Metal-Enclosed Switchgear,
230-101(h), 230-106
Metal Frame of Building
Grounding Electrode,
240-82(a)
Resistance to Ground, 250-84

Metal Hood, Stage Switchboard,
520-24
Metal Working Machine Tools,
Art. 670
Conductors, Supplying, 670-4
Definition, 670-2
Nameplate Data, 670-3
Metal Siding, Grounding of,
250-44

Metallic Outlet Boxes (see
 Boxes)
Metallic Raceways (see
 Raceways)
Metals, Dissimilar, 346-1,
 348-1
Meter(s)
 Cases, Grounding, 250-123,
 250-124
 Connection and Location at
 Services, 230-73, 230-94
 Grounding to Circuit
 Conductor, 250-61
 Hazardous Locations, Class
 I,
 501-3
Mineral Insulated-Metal
 Sheathed Cable, Art. 330
 Bends, 330-7
 Construction Specifications,
 330-C
 Definition and Description,
 330-1
 Fittings, 330-9
 Insulation and Resistance,
 330-10
 Supports, 330-4
 Terminating Seals, 330-8
 Through Studs, Joists, etc.,
 330-5, 300-8
 Use, 330-2
 Wet Locations, 330-6,
 300-5(c)
Mobile Homes, Art. 550
 Appliances, 550-7(a)
 Branch Circuits, 550-5
 Branch-Circuit Protective
 Equipment, 550-4(b)
 Calculations of Loads, 550-
 11
 Definition, 550-2
 Disconnecting Means, 550-
 4(a)
 Grounding, 550-9
 Insulated Neutral Required,
 550-9(a)
 Lighting Fixtures, 550-7(b)
 Nameplates, 550-4(c)
 Power Supplies, 550-3
 Receptacle Outlets, Types,
 Where Required, 550-6
 Testing, 550-10
 Wiring Methods and

Materials,
 550-8
Mogul Lampholders, 410-49
Monorails, 610-1

Motion-Picture

Projectors, Art. 540, 520-2
Grounding, 250-43

Studios, Art. 530

Theaters, Assembly Halls,
etc., Art. 520

Motor(s), Art. 430

Air Conditioning Units, 422-

F

Appliances, Motor Driven,
Art. 422

Branch Circuits, 430-B

Combination Loads, 430-25,
430-63

Continuous Duty, 430-22

Intermittent Duty, 430-22

Single Motor, 430-22

Taps, 430-53, 430-58

Two or More, 430-24

Wound Rotor Secondary,
430-23

Capacitor

Circuits, 460-8, 460-9

Rating, 460-7

Circuits, 430-B

Code Letters, Table 430-7(b)

Coded and Noncoded, Setting
of Branch Circuit Devices,
Tables 430-152, 430-153

Combined Overcurrent

Protection (Starting and
Running) 430-54

Combustible Material, 430-14

Conductor(s), 430-B

Control Circuits, 430-F

Controllers, 430-G

Hazardous Locations, 501-

6,

502-6, 503-4

Current Full Load

Alternating Current

Single Phase, Table
430-148

Three Phase, Table
430-150

Two Phase, Table 430-149

Direct Current, Table
430-147

Curtain, Theaters, Assembly
Halls, 520-48

Disconnecting Means, 430-H

Disconnects and Controllers
not as Junction Boxes,

430-10

Fault Protection, 430-D,
430-E

Motor(s) (continued)

Feeder demand Factor, 430-26

Feeders, Calculation of
Load,

220-4

Fuseholder, Size of, 430-56

General, 430-A

Grounding, 250-D, 430-L

Grouped, 430-24, 42, 53, 87, 112

Guarding, 430-133

Hazardous Locations, 501-8,
502-8, 503-6

In Sight from, Defined

Rule for Disconnects, 430-

4

Liquids, Protection from,
430-11 (see also Hazardous
Locations)

Live Parts, Protection,
430-133

Location, 430-14

Maintenance and Ventilation,
430-14

Marking, 430-7; Terminals,
430-9

Metal Working Machine Tools,
Art. 670

Multispeed,

Branch Circuits, 430-22(a)

Locked Rotor Code Letters,
430-7(b) (1)

Marking, 430-7

Running Protection,

430-32(a) (1),

430-31(c) (1)

Over 600 Volts, 430-J

Overcurrent (Overload)

Protection, 430-C

Overheating, Dust,

Accumulations, 430-16

Part Winding Described, 430-

3

Projectors, Motion-Picture,
540-12

Restarting, Automatic, 430-

43

Sealed (hermetic-type)

Refrigerator Compressor

Described, 430-6(b)

Short Circuit Protection,

430-D, 430-E
 Starting, Shunting, 430-35
 Terminal Housings, Size,
 430-12
 Three Running Overcurrent
 Units when Required
 (Unattended, etc.), Table
 430-37
Motor(s) (continued)
 Ventilation and Maintenance,
 430-14
 Welders, Arc. Motor-
 Generator, 630-C
 Wiring Diagram, Branch
 Circuit, 430-1(a)
 Wiring Space, 430-10
Motor-Circuit Switch,
 Definition, Art. 100
Motor-Generator Arc Welders,
 630-C
Mounting of Equipment, 110-13,
 300-11
Moving Walks (see Elevators),
 Art. 620
Multioutlet Assembly, Art. 353
 Calculation of Load, 220-2
 Definition, Art. 100
Multiple Conductors
 (Conductors
 in Parallel), 310-10
Multiple Fuses (Fuses in
Parallel), 240-14
Multispeed Motors
 Branch Circuits, 430-22(a)
 Locked-Rotor Code Letters,
 430-7(b)
 Marking, 430-7
 Running Protection,
 430-32(a), 430-32(c)
Nameplate (see articles on
 wiring and equip. involved)
Neat Installation, 110-12
Neutral
 Bare, where Permitted,
 230-30(a), Exc. 1, Exc. 2,
 230-40(a) Exc.
 Bonding to Service
 Equipment,
 250-72(a)
 Common Feeder, 215-5
 Feeder Load, 220-4(d)
 Equipment, Grounding to,
 250-61
 Grounding of, for AC
 systems,
 250-5, 250-25, 250-26; for
 DC, 250-3, 250-4, 250-22
 Identification, Art. 200
 Ranges and Dryers,
 Grounding,
 250-60
 Switchboards, Connections,
 384-3(b)
 Uninsulated, where
 Permitted,
 230-30, 338-3(b)
Night Clubs, Art. 520
Nipples, Conduit, Fill
 Permitted, Note Preceding
 Table 1, Chap. 9
Nonautomatic, Definition,
 Art. 100
Nonelectrical Equipment,
 Grounding, 250-44
Nongrounding-Type Receptacles,
 Replacements, 210-21(b)
Nonmetallic Boxes (see Boxes)
 Covers for, 370-15(a)
 Ungrounded Metallic
 Fixtures,
 Lampholders, Faceplates
 within reach of grounded
 surfaces, 410-95(a)
Nonmetallic Extensions
 Description, 342-1
 Fittings, 342-6
 Installation
 As Aerial Cable, 342-7(b)
 As Surface Extensions,
 342-7(a)
 Permitted Uses, 342-3
 Prohibited Uses, 342-4
 Splices and Taps, 342-5
Nonmetallic Rigid Conduit (see
 Rigid Nonmetallic Conduit)
Nonmetallic Sheathed Cable,
 Art. 336
 Accessible Attics, 336-9,
 334-13
 Bends, 336-10
 Construction
 Type NM, 336-2(a)
 Type NMC, 336-2(b)
 Definition, 336-1
 Exposed Work, 336-6
 Insulating Devices, 336-11

Marking, 336-2(c)
Supports, 336-5
Through Studs, Joists,
Rafters, 300-8, 336-7
Unfinished Basements, 336-8
Uses, 336-3
Nontamperable (see
Tamperability)
Occupancy, Lighting Loads,
Table 220-2(a)
Official Interpretations,
Obtaining, Part D, Appendix
Openings in Equipment to be
Closed, 370-8, 373-4

Open Wiring on Insulators,
Art. 320
Accessible Attics, 320-13,
324-8
Conductor Separation, 320-6
Conductor Types Permitted,
320-4
Definition, 320-1
Drip Loops, 320-14
Flexible Nonmetallic Tubing,
320-7
Passing through Walls and
Floors, 320-9
Separation from Metal Work,
320-10
Separation from Piping,
320-11
Supports, 320-5
Switches, 320-15
Tie Wires, 320-8
Use, 320-2
Operable, Externally,
Definition, Art. 100
Operating Rooms, Hospital,
Art. 517
Emergency Light and Power,
Art. 700
Organs, Art. 650
Electronic, 640-1
Outlet(s)
Boxes (see Boxes, Outlet)
Definition, Art. 100
Devices, Branch Circuits,
210-21
Discontinued,
Cellular Concrete Floor
Raceways, 358-11
Cellular Metal Floor
Raceways, 356-7
Underfloor Raceways, 354-7
Lighting, Definition,
Art. 100
Multioutlet Assembly,
Art. 343
Receptacle, Definition,
Art. 100
Outlet, Switch, and Junction
Boxes and Fittings, (see
Boxes)
Outline Lighting, Art. 600
Definition, Art. 100
Grounding, Conductor Size,
250-97

Output Circuits

Amplifiers, 640-5
Heat Generating Equip.,
665-9, 665-10

Outside Branch Circuits and Feeders, Art. 730

Calculation of Load
Branch Circuits, 730-3(a)
Feeders, 730-3(b)
Circuit Entrances and Exits,
Buildings, 730-11
Conductors,
Clearance from buildings,
730-19
From Ground, 730-18
Covering, 730-4
Size, 730-5, 730-6
Disconnection, 730-8
Festoon Supports, 730-13
Lighting Equipment on Poles,
730-7
Mechanical Protection, 730-

20

Outdoor Lighting Equipment,
730-25, 730-26
Overcurrent Protection, 730-

9

Spacing, Open Conductors,
730-14
Supports
Festoons, 730-13
Open Conductors, 730-12
Over Buildings, 730-15
Wiring on Buildings, 730-10

Ovens, Wall-Mounted (see also Cooking Units) (see also Ranges)

Branch Circuits, 210-19,
210-24
Connections, 422-17
Definition, Art. 100
Demand Loads, Table 220-5
Grounding, 250-57, 250-60

Overcurrent Protection,

Art. 240
Appliances, 422-27
Busways, 364-8 thru 364-12
Capacitors, 460-8(b)
Circuit-Breakers, 240-H
Circuits
Branch, 210-20
Capacitor, 460-8, 460-9
Less than 50 Volts, 720-8

Overcurrent Protection

(continued)

Remote-control and Signal
Class 1 Systems, 725-18,
725-19
Class 2 Systems, 725-32,
725-41, -42
Low-Voltage Power, 725-22
Cords, Flexible and Tinsel,
400-9
Cranes and Hoists, 610-E
Current-Limiting Defined,
240-27
Disconnecting and Guarding,
240-D
Elevators, Dumbwaiters,
Escalators, and Moving
Walks, 620-G
Emergency Systems, 700-E
Enclosures, 240-C
Feeder Taps, 240-15
Fixture Wires, 402-5
Fuses and Fuseholders, 240-
E,
240-F, 240-G, 240-H
Generators, 445-4
Grounded Conductor, not in,
240-012
Heat Generating Equipment,
665-7
Induction and Dielectric
Heating Equipment, 665-7,
665-15
Installation, 240-A
Location, 240-B
Mobile Homes, 550-4
Motion-Picture Studios,
530-18, 530-63
Motors, Motor Circuits,
Controllers
Branch Circuits, 430-D
Capacitors, 460-8
Control Circuits, 430-72
Cutouts and Relays,
Thermal, 430-40
Overloads, 430-C
Over 600 Volts, 430-123,
430-124
Multiple Fuses and Circuit
Breakers in Parallel,
240-14
Organs, 650-6

Overcurrent Protection

(continued)

Outside Branch Circuits and
Feeders, 730-9

Over 600 Volts, 710-C

Panelboards, 384-15, 384-16

Paralleled Fuses and Circuit
Breakers 240-14

Remote-Control, 240-5,
Exc. 5, Art. 725

Services

Entrances Conductor, 230-K

Over 600 Volts, 230-106

Single Appliance, 210-20(b)

Sound Recording Equipment,
640-10

Supplementary, 240-30

Switchboards, 384-2

Theaters, Assembly Halls,

Stage Switchboards, 520-

23,

520-25, 420-52, 520-53,
520-62

Time Delay, Residential

Occupancies 240-4

Transformers, 450-3, 450-5

Travel Trailers, 551-4(b)

Vertical Position,

Enclosures, 240-17(c)

Welders

Resistance, 630-32

Transformer, 630-12

X-Ray Equipment, 660-5

Over 600 Volts, General,

Art. 710

Braid-Covered Insulated

Conductors, Open Runs,
710-4

Circuit Conductors, 710-32

Circuit Interrupting Devices

Circuit Breakers, 710-

21(c)

Fuseholders and Fuses,
720-21(b)

Load Interrupters,
710-21(c)

Elevation of Unguarded Live
Parts, 710-34(f)

Enclosure for Electrical
Installations, 710-31

Grounding, 710-7

Grounding of Shielding Tape,
710-6

Headroom above Working
Spaces, 710-34(e)

Over 600 Volts (continued)

Illumination of Working
Spaces, 710-34 (d)

Indoor Installations, 710-10

Isolating Means, 710-22

Metal-enclosed Equipment,
710-12

Moisture, Mechanical
Protection, Metal-sheathed
Cables, 710-8

Outdoor Installations, 710-
11

Shielding, Rubber-Insulated
Conductors, 710-5

Wiring Methods, 710-3

Pan(s)

Drip (see Drip Pans)

Fixture, 410-13

**Panelboard(s), Art. 384 (see
also Hazardous Locations)**

Damp and Wet Locations,
384-17

Enclosures, 384-18

General, 384-13

Lighting and Appliance

Branch-Circuit,

Definition, 384-14

Number of Overcurrent

Devices, 384-15

Overcurrent Protection,
384-16

Overcurrent Protection,
384-16

Relative Arrangement of
Switches and Fuses, 384-19

Service Equipment, 384-
16(a),

384-3(c), 230-H, 230-K

Support for bus-Bars, 384-3

Part-Winding Motors

Code Letter Markings,
430-7(b) (5)

Paralleled

Conductors, 310-10

Circuit Breakers and Fuses,
240-14

**Patching Tables, Motion
Picture, 530-D**

Pendants

Clothes Closets, 410-8(b)

Dressing Rooms, 520-71

Flexible Cords, 400-3

Pendant Conductors, Lamps,

410-22

Periodic Duty, Definition,
Art. 100

Permission, Special,
Definition, Art. 100

Person, Qualified, Definition,
Art. 100

Phase Protection, Elevators,
620-53

Pipe Electrodes, 250-83(c)

Place of Public Assembly,
Art. 520

Plate Electrodes, 250-83(b)

**Plugging Boxes, Motion-Picture
Studios, 530-14**

Polarity Identification

Conductors, 310-2(f)

Systems and Circuits,
Art. 200

Polarization

Lighting Fixtures, Wiring,
410-27

Poles

Climbing Space, Conductors,
730-14

Conductors, Mechanical,
Protection, 230-32(b),
730-20

Portable

Appliance(s), Art. 422

Definition, Art. 100

Equipment

Appliance(s), Tool(s),
Double Insulation, 250-

45

Grounding, 250-45, 250-59

Grounding Conductor Size,
Table 250-95

Handlamps, Construction,
410-37

Lamps (see Lamps)

Stage Equipment, 520-E

Switchboards, Theaters,
Halls, etc., 520-D

Wiring, Motion Picture
Studios, 530-16

Positive-Pressure Ventilation,
500-1, 500-4(b)

Power, Emergency Systems,
Art. 700

Power Factor Correction,
Capacitors, 460-7

Power Supply, Mobile Homes,

550-3
Power Supply, Travel Trailers,
 551-3
Prefabricated Buildings,
 Art. 390
Pressure Connector,
 Definition,
 Art. 100
Pressure, Positive,
Ventilation, 500-1, 500-4(b)
Prevention of Fire Spread
Through Fire Partitions,
 300-21
Projectors, Motion Picture,
 Art. 540
Protection
 Combustible Material,
 Appliances, 422-10
 Corrosion,
 Aluminum-Sheathed Cable,
 331-2
 Conductors, 310-7
 Electrical Metallic
 Tubing,
 348-1
 General Equipment, 300-5
 MI Cable, 330-2
 Rigid Metal Conduit, 346-1
 Underfloor Raceways, 354-2
 Liquids, Motors, 430-11
 Live Parts, 110-17, 445-6,
 450-7(c), (d)
 Motor-Running Overcurrent,
 430-C
 Overcurrent (see Overcurrent
 Protection)
 Physical Damage (Injury),
 Busways, 364-2
 Capacitors, 460-3
 Conductors, 460-3
 Electrical Metallic
 Tubing,
 348-1
 Liquid-tight Flexible
 Metal
 Conduit, 351-2(b)
 Metal-Clad Cable, 334-6,
 334-12(c), 334-13
 Multioutlet Assembly, 353-
 2
 Nonmetallic Sheathed
 Cable,
 336-6(b)

Open Wiring, 320-7, 320-12
 Overcurrent Devices,
 240-16(b)
 Resistors and Reactors,
 470-1
 Rigid Nonmetallic Conduit,
 347-3(a)
 Space Heating Systems,
 424-13
 Surface Metal Raceways,
 352-1
 Transformers, 450-7(a)
Protection (continued)
 Physical Damage (continued)
 UF Cable, 339-3(c)
 Wireways, 362-2
Protection Devices (see
 Circuit
 Breakers; Fuses; Overcurrent
 Protection; Thermal Cutout)
Protective Equipment (see
 Guarding and Guards)
Public Address Systems,
 Art. 640
 Emergency Power Supply,
 Art. 700
Public Assembly Places,
 Art. 520
 Emergency Lighting Systems,
 Art. 700
Pull Boxes (see also Boxes and
 Junction Boxes)
 Accessibility, 370-19
 Construction Specifications,
 370-C
 Sizes, No. 6 and Larger
 Conductors, 370-18
 Sizes, No. 6 and Smaller
 Conductors, 370-6
Qualified Person, Definition,
 Art. 100
Raceway(s)
 Bonding, 230-63, 250-G
 Busways, Art. 364
 Cellular Concrete Floor,
 Art. 358
 Cellular Metal Floor,
 Art. 356
 Conductors in Service, 230-
 43
 Continuity
 Electrical, 300-10
 Mechanical, 300-12

Definition, Art. 100
Electrical Metallic Tubing,
Art. 348
Emergency Circuits,
Independent, 700-17
Expansion Joints, 300-6(b),
347-9
Fixtures as Raceways, 410-26
Flexible Metal Conduit,
Art. 350
Grounding, 230-63(b), 250-D
Short sections, 250-56
Induced Currents, 300-20
Inserting Conductor, 300-18

Raceway(s) (continued)
Insulation Bushings, 300-16,
373-6(b)
Liquidtight Metal Conduit,
Art. 351
Metal-Trough, Sound
Recording, 640-4
Number of Conductors, 300-17
Rigid Metal Conduit, Art.
346
Secured, 300-11
Service (see Service
Raceways)
Signal and Power Circuits,
Low-Energy
Different Systems, 725-16
Separation of other
Conductors, 725-42
Sizes, 725-13
Storage Battery Rooms, 480-7
Structural Raceways, Art.
357
Supporting Conductors,
Vertical, 300-19
Temperatures, 300-6
Underfloor, Art. 354
Underground, Cable Under
Building, 300-7
Wireways, Art. 362
Wiring, Outside, 730-23
Radiographic Equipment,
660-12(a)
Radio, Television Equipment,
Art. 810
Radio, Television Distribution
Equip., Art. 820
Railway
Conductors, Power and Light,
110-19
Track, As a Ground, 250-85
Raintight, Definition, Art.
100
Ranges, 422-17, 422-23
Branch Circuits
Calculation of Load,
Table 220-5
Conductors, 210-19
Maximum Load, 210-23
Feeders, Calculation of
Load,
220-4
Grounding Method, 250-60
Loads, Demand, Table 220-5

Receptacles, 210-21(b) (see
also Cooking Units) (see
also Ovens)

Reactors (see Resistors and
Reactors)

Readily Accessible,
Definition,
Art. 100

Reaming, Ends of Rigid Metal
Conduits, 346-7

**Receptacle (Convenience
Outlet),** Def., Art. 100

Receptacle Outlet, Definition,
Art. 100

Receptacles, 410-K
Branch Circuits, 210-21,
210-22
Disconnecting Means, 422-22
Faceplates, 410-52(b)
Grounding Type, 250-74,
410-55
Hazardous Locations, 501-12,
502-13, 503-11
Less Than 50 Volts, 720-6,
720-7
Minimum Ratings, 410-52(a)
Mobile Homes, 550-6
Nongrounding types,
Replacements, 210-21(b)
Outlets, Where Required,
Dwellings, 210-22(b)
Terminals, Identification,
200-10
Theaters, Halls, etc., 520-
23
520-45
Travel Trailers, 551-6

Recessed Lighting Fixtures

As raceways, 410-26
Clearances, 410-64
Construction, 410-N
Temperatures, 410-63
Wiring, 410-64

Recording Systems, Art. 640

**Refrigeration Compressor
Motors**

and Controls, 430-6, 430-7,
430-83, 430-110(b), (d)
Definition, Art. 100

**Regulators, Mercury Vapor
Lamps,** 410-50

Relays
Reverse-Current,

Transformers, 450-5(b)
Thermal, Motor Overcurrent
Protection, 430-40

**Remote-Control, Low-Energy
Power, and Signal Circuits**

Provisions, 110-20
Welders, 630-D

Class 1 System

Circuit Beyond Building,
725-20

Conductors

Different Systems, 725-

16

Insulation, 725-14

Number in Raceways,
725-15

Overcurrent Protection,
725-18

Size, 725-13

Grounding, 725-21

Location, Overcurrent
Devices, 725-19

Mechanical Protection,
725-17

Wiring Methods, 725-11

Class 2 System

Installation, 725-E

Limits, Voltage and
Current, 725-31

Overcurrent Protection,
Mounting, 725-32

Transformer Leads, 725-34

Transformer Rating, 725-33

Classifications

Class 1, 725-3(a)

Class 2, 725-3(b)

Communication Cables, 725-7

Low-energy Power Circuits,
Defined, 725-4

Low-Voltage Power Circuits,
Defined, 725-5

Overcurrent Protection,
725-22

Transformer Ratings, 725-

23

Motors, 430-F

Safety-Control Devices, 725-

6

Rigid Metal Conduit, Art. 346

Residential Occupancies (see
Dwellings)

Resistance

Conductors, Copper,
Aluminum,

Table 8, Chap. 9

Conversion Factors, Table 9,
Chap. 9

Insulation, General

Resistance-to-Ground,

Electrodes, 250-84

Resistors and Reactors,

Art. 470

Combustible Material, on,
near, 470-3

Conductor Insulation, 470-7

Contacts, Fixed, Movable,
470-4

Incandescent Lamps as
Resistors, 470-8

Location, 470-1

Mounting, 470-6

Reactor Materials, 470-5

Space Separation, 470-2

Rheostats, Construction

Specifications, 430-82(c)

Rigid Metal Conduit, Art. 346

Bends

How Made, 346-10

Number, 346-11

Bushings, 346-8

Cinder Fill, 346-3

Construction Specifications,
346-B

Couplings and Connectors,
346-9

Expansion Joints, 300-6(b)

Minimum Size, 346-5

Number of Conductors,

New Work, 346-6(a)

Nipples, Note Table 1,
Chap. 9

Rewiring, 346-6(b)

Reaming Ends, 346-7

Supports, 346-12, Table
346-12

Use, 346-1

Wet Locations, 346-4

Rigid Nonmetallic Conduit,

Art. 347

Bends

How Made, 347-13

Number, 347-14

Boxes and Fittings, 370-4,
370-7(c)

Bushings, 347-12

Construction Specifications,
347-16

Description, 347-1

Expansion Joints, 347-9,
300-6(b)

Joints, 347-6

Minimum Size, 347-10

Rigid Metal Conduit
(continued)

Number of Conductors,

New Work, 347-11(a)

Rewiring, 347-11(b)

Supports, 347-8, Table 347-8

Trimming Ends, 347-5

Use permitted, 347-2

Use prohibited, 347-3

Rod Electrodes, 250-83(c)

Room Air Conditioner

Branch Circuits, 422-42

Defined, 430-53(d)

Grounding, 422-41

Nameplate Rating, Branch
Circuit Requirements,
430-53(d)

Rosettes, 410-L

Overcurrent Protection,
240-17(d)

**Running Protection, Motors and
Conductors,** 430-C

Running Threads, 346-9(b)

Screw-Shells

Identification, Polarity,
200-8, 410-27

Terminals, 200-10

Lampholders, 410-G

Sealable

Equipment,

Definition,

Art. 100

Sealed

Hermetic-Type

Compressor

Controller Rating, 430-83,
Exc. 3

Described, 430-2, Art. 100

Nameplate, 430-7(c)

Running Protection, 430-C

Size of Conductor, 430-6(b)

Sealing, Conduit Systems (see
also Hazardous Locations)

Temperature Changes, 300-
6(a)

Underground Services, 230-33

Secondary Ties, Transformers,
450-5

Service(s), Art. 230

Definition, Art. 100

Emergency Systems, 700-9

Farm, 220-4(m)

Insulation, Size, 230-B

Lateral, Def., Art. 100

Number, 230-2
Over 600V, 230-L
Supply to Building Through
 Another, 230-3
Underground, 230-D

Service Cables, Art. 338
 Buildings, 230-50
 Definition, Art. 100
 Installation, Art. 338
 Mechanical Protection, 230-46

 Service Head, 230-51
 Terminating, Service
 Equipment, 230-53
 Underground, 230-D, 310-6

Service Drops

 Clearance, Over Roofs, from
 Ground, Building Openings,
 230-24
 Connections, Service Head,
 230-51
 Definition, Art. 100
 Means of Attachment, 230-27
 Minimum Size, 230-23
 Number, 230-2, 230-21
 Point of Attachment, 230-26
 Supports Over Buildings,
 230-25
 Termination, 230-24, 230-26,
 230-51

Service Entrance Cable,

 Art. 338
 Definition, 338-1
 Installation Methods, 338-4
 Marking, 338-5
 Use

 Buried Conductors, 310-6
 Branch Circuits or
Feeder, 338-3
 Service-Entrance
 Conductors, 338-2,
 Art. 230

Service-Entrance Conductors,

 230-E
 Definition, Art. 100
 Disconnecting Means, 230-J
 Insulation, 230-40
 Mechanical Protection, 230-46

 Outside of Building, 230-45
 Over 600V, 230-L
 Overcurrent Protection,
 230-90, 230-106
 Size, 230-41
 Service Head, 230-51
 Splices, 230-42
 Underground, 230-D

Wiring Methods, 230-44

**Service Entrance Equipment
(Disconnecting Means and
Overcurrent Protection)**

Definition, Art. 100

Disconnecting Means, 230-J

Approved Type, 230-70(c)

Connections ahead of,
230-73

Connections to Terminals,
230-72

Disconnection of Grounded
Conductor, 230-70(i)

Externally Operable,
230-70(e)

Indicating, 230-70(b)

Location, 230-70(b)

Multiple Occupancy
Buildings, 230-70(b)

Over 600V, 230-103

Rating, 230-71

Safeguard, Emergency
Supply, 230-74

Simultaneous Openings,
230-70(h)

Six Switch Rule, 230-70(g)

Two or More Buildings,
Single Management, 230-

76

Grounding, Bonding,
Guarding,

230-H, 250-71, 250-72

Overcurrent Protection, 230-

K

Location, 230-91, 230-92

Over 600V, 230-106

Relative Location, 230-94

Specific Circuits, 230-93

Two or More Buildings,
Single Management,

230-90(c)

Undergrounded Conductors,
230-90(a)

Panelboards, as, 384-B

Service Raceways

Arranged to Drain,
Raintight,

230-52, 230-101(g)

Conductors, Others permitted
in, 230-43

Definition, Art. 100

Grounding and Bonding,
230-63(b) (c), 250-71,
250-72

Service Head, 230-51

Terminating at Service
Equipment, 230-53
Underground, 230-D

Service Stations, Gasoline
(see
Hazardous Locations)
Shielding (see Guarding and
Guards)
Short-Time Duty, Definition,
Art. 100
Show Cases, Wall Cases,
410-23(c)
Show Window(s)
Cords, Flexible, 400-6
Definition, Art. 100
Lighting Fixtures, 410-7
Branch Circuits, 220-2
Feeders, 220-4
Receptacles, Floor, 410-53
Signs, Outline Lighting,
600-34(e)
Sidelights, Borders and
Proscenium, 520-44
Sign(s)
Electric, Definition,
Art. 100
Discharge, Lighting,
Electric, 410-P, 410-Q
Grounding, 250-43(f)
Outline Lighting, Art. 600
Size of Conductors (see
Conductors)
Signal Circuit(s)
Definition, Art. 100
Installation Requirements,
Art. 725
Smoothing Irons, 422-13
Snap Switches
Accessibility, Grouping,
380-8
Definition, Art. 100 under
Switches
Motors, 430-83, 430-109
Panelboards, 384-16, 384-19
Ratings
Inductive Loads, 380-14(c)
Noninductive Loads,
380-14(a)
Tungsten-Filament Loads,
380-14
Residential Garages,
Outbuildings, Supply
Conductors, 230-76
Signs, 600-2
Solderless (Pressure)
Connector, Definition,

Art. 100

Sound Recording

Equipment, Art. 640
Motion Picture Projectors,
540-50
Theaters, Assembly Halls,
etc., 520-3

Space

Cabinets, Cutout Boxes,
373-7, 373-9, 373-11
Lightning Rods, Conductor
Enclosures, Equipment,
250-34, 250-46
Outside Branch Circuits,
Feeders, 730-14
Over 600 Volts, Separation,
230-101, 710-33
Service Entrance Conductors,
230-47, 230-48
Working Space About
Electrical Equip., 110-16

Space Heating, Fixed Indoor,
424-13, 424-39

**Spacing Between Bare Metal
Parts,** Table 384-26

Special **Permission,**
Definition,
Art. 100

Splices and Taps

Antennas, 810-14
Auxiliary Gutters, 374-8
Bare-Conductor Feeders, 328-

3

Cable Heating, 424-40
Cellular Concrete Floor
Raceways, 358-10
Cellular Metal Floor
Raceways, 356-6
Concealed Knob and Tube,
324-11
Continuous Rigid Cable
Supports, 318-4(j)
Deicing, Snow-Melting, 424-

73

Fixtures, 410-25
Flexible Cords, 400-5
General Provisions, 110-15
Hazardous Locations, 501-5,
502-4, 503-3
Nonmetallic Extensions, 342-

5

Open Wiring, 320-5(a-2)
Space Heating Cables, 424-40
Structural Raceways, 357-7

Underfloor Raceways, 354-6
Wireways, 362-6

Stage Equipment

Fixed, Theaters, Assembly
Halls, etc., 520-C
Portable, Theaters, Halls,
etc., 520-E

Stage Motion Picture, 530-B

Switchboard, 520-B, 520-D

Stand-By Power Generation

Systems, Art. 750 (see also
Emergency Systems, Art. 700)

Approval, 750-3

Capacity, 750-6

Control and Transfer, 750-7

Generator, 750-5

Protection, 750-8

Tests, 750-4

Wiring, 750-9

Steel Siding (see Metal
Siding)

Storage Batteries, Art. 480

Aircraft Hangars, 513-9

Battery Rooms, 480-7

Emergency Systems, 700-7

Garages, 511-7

Insulation

Over 250V, 480-5

Not over 250V, 480-4

Racks and Trays, 480-6

Sound Recording Equipment,
640-9, 640-10

Structural Raceways, Art. 357

Definitions, 357-1

Installation, 357-A

Construction, 357-B

Use, 357-2

Substations, Motion Picture

Studios, 530-F

Supply Stations, Overcurrent

Protection, Feeders, 240-9

Support(s) (see Articles on
wiring and equip. involved)

Suppressors, Radio Noise, 810-4

Surface Metal Raceway, Art. 352

Surge Protection, 502-3 (see
also Lightning Protection)

Swimming Pools, Art. 680

Approval of Equipment, 680-2

Attachment-Plug Receptacles,
Location, 680-6

Forming Shell, Definition,
680-4(d)

Grounding, Bonding, 680-7,
 680-8
 Junction Boxes, Transformer
 Enclosures, 680-5
Swimming Pools (continued)
 Overhead Wiring, Clearances,
 680-9
 Underwater Lighting
 Fixtures,
 680-4
Switch(es), Art. 380 (see also
 Hazardous Locations)
 Accessibility and Grouping,
 380-8
 AC General Use Snap Switch,
 Def., Art. 100
 AC-DC Snap Switch, Def.,
 Art. 100
 Appliances, 422-24
 Disconnecting Means
 Appliances, 422-D
 Motors, Controllers, 430-
 86
 430-H
 Services, 230-70
 Emergency Systems, 700-D
 Foot
 Heat Generating Equipment,
 665-12(b)
 X-ray Equipment, 660-13
 General Use, Art. 380
 Definition, Art. 100
 Identification, 110-22
 Isolating
 Definition, Art. 100
 Lightning Arresters, 280-
 25
 Motors Over 50 HP,
 430-109(d)
 Services Over 600 Volts,
 230-104
 Knife, Art. 380
 Limit
 Cranes and Hoists, 610-34
 Elevators, 620-51
 Manually Operable, Art. 380,
 430-86
 Motor Controllers, 430-G
 Definition, 430-81(a)
 Motor Circuit, Definition,
 Art. 100
 Panelboards, 384-16(b),
 384-19
 Service, 230-J
 Signs, Outline Lighting,
 600-2, 600-35
 Snap, Art. 380
 Theaters, Assembly Halls,
 Dressing Rooms, etc.,
 520-73

Switch(es) (continued)
 Time, Connection, 230-73,
 230-94
 Unit, Appliances, 422-24
Switchboard(s), Art. 384
 Clearances
 Back of, 384-8, 110-16
 From Ceiling, 384-7
 Conductor Covering, 384-9
 Construction Specifications,
 384-C
 Easily Ignitable Materials,
 Near, 384-6
 Grounding Frames, 384-11
 Grounding Instruments, 384-
 12
 Guarding Live Parts, 100-17
 Illumination, 110-16(e)
 Location, 384-4
 Portable, Theater Stages,
 520-D
 Support, bus-bars,
 conductors, 384-3
 Wet Locations, 384-5
 Working Spaces about, 110-16
Switchgear, Metal-Enclosed,
 230-101(h), 230-106

Tables

Ampacities
 Crane and Hoist Motor
 Conductors, Table
 610-14(a)
 Fixture Wire, Table 402-4
 Flexible Cord, Table
 400-9(b)
 General Conductors,
 Aluminum, in Raceways or
 Cables, Table 310-14
 Aluminum, Single
 Conductor in Free Air,
 Table 310-15
 Copper, in Raceways or
 Cables, Table 310-12
 Copper, Single Conductor
 in free air, Table
 310-13
 Correction Factors, Note
 15 to Tables 310-12
 thru 310-15
 Simplified Wiring, Table
 310-21
 Ambient Temperatures
 for, Table 310-20(c)

Wound-rotor Secondaries,
 Table 430-23(c)

Tables

Bare Metal Parts, Spacings
 Between (Switchboards and
 Panelboards) Table 384-26
 Branch-Circuit Requirements,
 Table 210-25
 Calculation of Feeder Loads
 by Occupancies, Table
 220-4(a)
 Cooking Appliances
 Commercial, 220-6(a)
 Household, 220-5
 Conductor(s)
 Application, Table 310-
 2(a)
 Deflection, Min. Bending
 Space, in Cabinets,
 Cutout Boxes, Table
 373-6(a)
 Dimensions
 Asbestos, Varnished
 Cambric, Table 7,
 Chap. 9
 Lead-covered, Table 6,
 Chap. 9
 Rubber, Thermoplastic-
 Covered, Table 5,
 Chap. 9
 DC to AC (60 Cycle)
 Resistance Conversion,
 Table 9, Chap. 9
 Fixture Wires, Types,
 Table 402-6
 Flexible Cords, Types,
 Table 400-11
 Grounding, Size,
 For grounded Systems,
 Table 250-94 (a)
 For grounding Interior
 Equipment, Table 250-
 95
 For ungrounded Systems,
 250-94(b)
 Insulations, Table 310-
 2(b)
 Number in Box,
 Cu., in. Dimensions for
 Combinations, Table
 370-6(b)
 Deep Boxes, Table
 370-6(a-1)
 Shallow Boxes, Table

370-6 (a-2)

Tables (continued)

Over 600V to 5000V

Asbestos and Varnished
Cambric, Single-
Conductors, Table

310-2(i) (4)

Rubber-covered, Table

310-2(i) (1)

Shielding, Rubber-
Insulated Conductors,
Table 710-5

Varnished Cambric,
multiple-Conductor
cables, Table

310-2(i) (3)

Varnished Cambric,
single-conductors,
Table 310-2(i) (2)

Voltage Marking,
310-2(e) (5)

Properties, Table 8,
Chap. 9

Support, Vertical

Raceways,

300-19(a)

Conduit or Tubing

Combination of Conductors,
percent Area Fill,

Table 3, Chap. 9

Dimensions, Table 4,
Chap. 9

Flexible Metal (3/8 in.),
Table 350-3

Liquidtight Flexible

Metal,

351-4

Number of Conductors

Permitted,

Combinations, Tables 3

to

8, Chap. 9, See 346-6,
and 347-11

Lead-Covered, Table 2,
Chap. 9

New Work, Table 1,
Chap. 9

Rewiring, Table 1A,
Chap. 9

Radius of Bends, Table
346-10(a), 346-10(b)

Supports

Rigid Metal Conduit,
Table 346-12

Rigid Nonmetallic
Conduit, Table 347-8
Continuous Rigid Cable
Supports, Table 318-6(a)
Tables (continued)
General Lighting Unit Loads
by Occupancies, Table
220-2(a)
Gutters, Sheet-Metal
Thickness, Table 374-9(d)
Household Clothes Dryers,
Demand Loads, Table
220-6(b)
Household Ranges and Similar
Cooking Appliances, Demand
Loads, Table 220-5
Live Parts, Separation
Over 600V
Air Separation, Indoors,
Table 710-33
Elevation, 710-34(f)
Working Space, 710-34(a)
Working Clearances, Table
110-16(a)
Motors
Full-Load Currents
AC Single-Phase, Table
430-148
AC 3-Phase, Table 430-
150
AC 2-Phase, 430-149
DC, Table 430-147
Locked Rotor Current
Conversion, Table
430-151
Locked Rotor, Code
Letters, Table 430-
7(b)
Maximum Rating or
Setting, Br. Cir.
Protective Devices,
Tables 430-152, 430-
153
Number and Location,
Overcurrent Units,
Table 430-37
Terminal Housing Tables,
430-12(b),
430-12(c)(1),
430-12(c)(2)
Multifamily Dwellings,
Common Demand Factors,
Table 220-9

Optional Load Calculations,
One-family Residences,
Table 220-7
Radio and TV Equipment,
Antenna Sizes
Amateur Stations,
Table 810-52

Tables (continued)

Receiving Stations,
Table 810-16(a)

Tamperability

Air Circuit Breakers,
240-25(e)
Type S Fuses, 240-22(d)

Taps (see also Splices and
Taps)

Branch-Circuit
Cooking Appliances,
210-19(c), Exc. 1
Individual Fixtures or
Lampholders, 210-19(c),
Exc. 2(b)
Busways, 364-11, Exc. 1
Feeders
10-ft. Rule, 240-15, Exc.

5

25-ft. Rule, 240-15, Exc.

6

Motor, 430-59
Service-entrance Conductors,
230-42

Telegraph Systems, Art. 800**Telephone Exchanges**, Circuit
Load, 220-2, Exc. 4**Telephone Systems**, Art. 800**Television, Radio Equipment**,
Art. 810**Television Studios**, Art. 520,
Art. 530**Television & Radio
Distribution**

Systems, Community Antenna,
Art. 820

Temperature Limitation,
Conductors in Outlet Boxes
for Fixtures, 410-11**Terminal Housing**, 430-145**Terminals**

Connections to, General,
110-14, 250-113
Electric Discharge Tubing,
Signs, Outline Lighting,
600-34
Identification
Motors, Controllers, 430-9
Polarity, 200-9, 200-10

Tests

Deicing and Snow Melting
Systems, 424-80
Emergency Systems, 700-4

Tests

Insulation Resistance,
General, 110-20
Mineral-Insulated Cable,
330-10

Space-Heating Cables,
424-45

Mobile Homes, 550-10
Travel Trailers, 551-10

Television & Radio

Equipment, Art. 810
Distribution Systems,
Art. 820

Theaters

Arc Lamps, 410-51
Assembly Halls, Art. 520
Emergency Lighting Systems,
Art. 700

Grounding, Electrical Fixed
Equip., 250-43

Therapeutic Equipment,

Inductive and Dielectric
Heat

Generating, 665-E

Thermal

Cutout, Definition, Art. 100
Disconnecting Means, 240-

18

Devices

Motors, 430-40
Overcurrent Protection,
240-8

Protection, Definition,
Art. 100

Protector, Definition,
Art. 100

**Thermally Protected (Thermal
Protection)**, Marking on

Motors, 430-7(a) (b)

Three Running Overcurrent

Units, motors, Table 430-37,
Note

Tools, Metal Working Machine,
Art. 670**Tools, Motor Operated**,
Grounding and Double
Insulation, 250-45(c),
250-45(d)**Transformers, Transformer**

Vaults, Art. 450 (see also
Hazardous Locations)
Arc Welders, 630-B
Capacitors, 460-5

Installation, Art. 450
X-ray Equipment, 660-D

Transformers, Transformer

Vaults, (continued)

Electric Discharge Lighting
Systems

1000 Volts or Less, 410-P

More than 1000 Volts, 410-

Q

Instrument, Grounding, 250-L
Connections at Services,
230-73

Isolating, in Anesthetizing
Locations, 517-6(a)

Power and Signal Circuits,
Remote-control, 725-23,
725-33, 725-41, 725-42

Remote-Control Circuits,

for,

430-74(b), 725-23, 725-33

Signs and Outline Lighting,
600-32

Two-winding, Underwater
Lighting Transformers,
680-4(h)

Vaults, 450-C

X-ray Equipment, 660-D

**Transmitting Stations, Radio
and Television, 810-C**

Travel Trailers, Art. 551

Branch Circuits, 551-5

Branch-Circuit Protection,
551-4(b)

Definition, 551-2

Disconnecting Means, 551-
4(a)

Fixed Appliances, 551-7(a)

Grounding, 551-9

Labeling, electrical
entrance, 551-4(c)

Lighting Fixtures, 551-7(b)

Neutral Conductors, 551-9(a)

Power Supply, 551-3

Receptacle Outlets, Types,
551-6

Testing, 551-10

**Trays, Storage Batteries,
480-6(b)**

Tubing (see also Conduit)

Electric Discharge, Sign and
Outline Lighting, 600-33,
600-34

Electrical Metallic, Art.

348

TV & Radio, Arts. 810 and 820

Underfloor Raceways, Art. 354
Conductors,
Number, 354-5
Size, 354-4

Underfloor Raceways,
(continued)
Connections to Cabinets,
Wall

Outlets, 354-15
Covering, 354-3
Dead Ends, 354-10
Discontinued Outlets, 354-7
Fittings at Angles, 354-12
Inserts, 354-14
Junction Boxes, 354-13
Low Points, Avoid, 354-11
Markers, Where Required,
354-9
Splices and Taps, Junction
Boxes, 354-6
Use, 354-2

**Underground Feeder and Branch-
Circuit Cable (Type UF),**
Art. 339
Description and Marking,
339-1
Overcurrent Protection, 339-
4

Use, 330-3

Underground Services, 230-D

Underground Wiring, (see also
Hazardous Locations)
Buried Conductors, Types
USE,

UF, 310-6, 339-3
Conductor Types in Raceways,
310-5
Direct Burial in Earth, 310-
6

Over 600V, 710-3(b)
Rigid Metal Conduit, 346-1
Rigid Nonmetallic Conduit,
347-2
Services, 230-30
Wet Locations, 310-5

Underplaster Extensions,
Art. 344
Boxes and Fittings, 344-3
Extension to Another Floor,
344-5
Installation, 344-4
Materials, 344-2
Use, 344-1

Unit Equipments, Emergency
Lighting, 700-22

Unused Openings
Boxes and Fittings, 370-8

Cabinets and Cutout Boxes,
373-4
Utilization Equipment, Def.,
Art. 100

Vapors, Flammable (see
Hazardous Locations)
Varying, Duty, Definition,
Art. 100

Vaults
Capacitors, 460-2
Film Storage, 530-E
Service Over 600 Volts,
230-106, 710-31
Transformers, 450-C

Vehicle, Electric, Charging,
511-8

Ventilated, Definition,
Art. 100

Ventilating Ducts, Wiring,
300-21, 300-22

Ventilating Piping for Motors,
etc.

Hazardous Locations
Class II Installations,
502-9
Class III Installations,
503-7

Ventilation

Battery Rooms, 480-7(b)
Generators, 445-1 (see also
Hazardous Locations)
Motion Picture Projectors,
540-18
Motors, 430-14(a), 430-16
Positive-Pressure, 500-1,
500-4(b)
Transformers, 450-44, 450-45

**Viewing Tables, Motion
Picture**,
530-D

Voltage and Volts

Branch Circuits, Limits,
210-6
Circuit, Definition, Art.

100

Drop

Branch Circuits, 210-6(c)
Feeders, 215-3
Electric Discharge Lighting,
under 1000 Volts, 410-P;
Over 1000 Volts, 410-Q
General Provisions, 110-5
Ground, to, Definition,
Art. 100
Less than 50, Circuits and
Equip., Art. 720
Limitations, Elevators,

Dumbwaiters, Escalators,
Moving Walks, 620-2

Voltage and Volts

Over 600V Circuits and
Equip., Art. 710
Swimming Pool Underwater
Lighting Fixtures,
680-4(b), 680-4(g)
Wiring Methods, 300-2

Wall or Show Cases,
Conductors,
410-23

Wall-Mounted Ovens (see Ovens,
Wall-Mounted, Ranges,
Cooking
Units)

Warning Signs (Labels), At
Equipment
Induction and Dielectric
Heating, 665-25
Locked Room or Enclosure
with
Live Parts over 600V,
710-34(c)
Services over 600V, 230-102
Transformers, 450-7(d)

Water Heaters, Protection,
422-10

Water Pipe
As Grounding Electrode,
250-81
Connections, 250-112(a),
250-113
Grounding Conductor, 250-
112,
250-113
Resistance, 250-84

Watertight, Definition,
Art. 100

Weatherproof, Definition,
Art. 100

Welders, Electric, Art. 630
Motor-Generator Arc., 630-C
Resistance, 630-D
Transformer Arc, 630-B

Wet Locations (see Damp or Wet
Locations)
Conductors, Types, 310-5
Definition, Art. 100
Electrical Metallic Tubing,
348-4
Enameled Equipment, 300-5(a)
Mounting of Equipment,
300-5(c)
Rigid Metal Conduit, 346-4

Rigid Nonmetallic Conduit,
347-2

Switchboards, 384-5

Switches, 380-4

Window, Show (see Show
Windows)

Wire in Concrete Footings,
Electrodes, 250-83(a)

Wire(s) (see Conductors;
Cords; Fixture Wire)

Wireways, Art. 362

Conductors

Maximum Size, 362-4

Number, 362-5

Dead Ends, 362-9

Definition, 362-1

Extensions, 362-10

Extensions thru Walls, 362-8

Marking, 362-11

Splices and Taps, 362-6

Supports, 362-7

Use, 362-2

Wiring Methods, Types (see
Table of Contents)

Wiring Methods, Gen'l

Requirements, Art. 300 (see
also Hazardous Locations)

Ducts, 300-21, 200-22

Mobile Homes, 550-8

Temporary, 300-23

Theaters and Assembly Halls,
520-4

Travel Trailers, 551-8

Working Space

About Electrical Equipment,
Horizontal Dimensions,
Clear Spaces, Elevation of
Equipment, General, 110-16

Adjacent to Live Parts,
Circuits over 600 Volts,
710-33, 710-34

Workmanlike Installation,
110-12

X-Ray Equipment, Art. 660

Control, 660-B

Guarding and Grounding, 660-

E

Industrial, 660-C

Installation, 660-A

Transformers and Capacitors,
660-D