```
08/06 01:46:52 488   FAN MAIN WATER GAUGE                          ComFail 5.86   PSI   REPEAT [NO Reason]
08/06 01:47:00 491   FAN WEST WATER GAUGE                          ComFail 4.14   PSI   REPEAT [NO Reason]
08/06 01:50:17 487   FAN EAST WATER GAUGE          HI GUAGE        Alarm   4.53   PSI   REPEAT [NO Reason]
08/06 01:56:52 488   FAN MAIN WATER GAUGE                          ComFail 5.94   PSI   REPEAT [NO Reason]
08/06 01:57:00 491   FAN WEST WATER GAUGE                          ComFail 4.14   PSI   REPEAT [NO Reason]

08/06/2007  02:00:00 Genwall                       [S500 V7.5g]
08/06 02:00:17 487   FAN EAST WATER GAUGE          HI GUAGE        Alarm   4.45   PSI   REPEAT [NO Reason]
08/06 02:06:52 488   FAN MAIN WATER GAUGE                          ComFail 5.86   PSI   REPEAT [NO Reason]
08/06 02:07:00 491   FAN WEST WATER GAUGE                          ComFail 4.14   PSI   REPEAT [NO Reason]
08/06 02:10:17 487   FAN EAST WATER GAUGE          HI GUAGE        Alarm   4.45   PSI   REPEAT [NO Reason]
08/06 02:16:52 488   FAN MAIN WATER GAUGE                          ComFail 5.86   PSI   REPEAT [NO Reason]
08/06 02:17:00 491   FAN WEST WATER GAUGE                          ComFail 4.14   PSI   REPEAT [NO Reason]
08/06 02:20:17 487   FAN EAST WATER GAUGE          HI GUAGE        Alarm   4.45   PSI   REPEAT [NO Reason]
08/06 02:26:52 488   FAN MAIN WATER GAUGE                          ComFail 5.86   PSI   REPEAT [NO Reason]
08/06 02:27:00 491   FAN WEST WATER GAUGE                          ComFail 4.14   PSI   REPEAT [NO Reason]
08/06 02:30:17 487   FAN EAST WATER GAUGE          HI GUAGE        Alarm   4.53   PSI   REPEAT [NO Reason]
08/06 02:36:52 488   FAN MAIN WATER GAUGE                          ComFail 5.86   PSI   REPEAT [NO Reason]
08/06 02:37:00 491   FAN WEST WATER GAUGE                          ComFail 4.14   PSI   REPEAT [NO Reason]
08/06 02:40:17 487   FAN EAST WATER GAUGE          HI GUAGE        Alarm   4.45   PSI   REPEAT [NO Reason]
08/06 02:46:52 488   FAN MAIN WATER GAUGE                          ComFail 5.86   PSI   REPEAT [NO Reason]
08/06 02:47:00 491   FAN WEST WATER GAUGE                          ComFail 4.14   PSI   REPEAT [NO Reason]
08/06 02:50:17 487   FAN EAST WATER GAUGE          HI GUAGE        Alarm   4.53   PSI   REPEAT [NO Reason]
08/06 02:51:31 120   CO MAIN WEST SECTION ALARM BOX                ComFail -0.98  PPM
08/06 02:51:31 153   CO CHARGER SCOOP MAIN WEST                    ComFail -0.98  PPM
08/06 02:51:32 156   CO XC121 MAIN WEST #7 BELT LINE               ComFail -0.98  PPM
08/06 02:51:33 158   CO XC135 MAIN WEST #7 BELT LINE               ComFail -0.98  PPM
08/06 02:51:33 157   CO XC128 MAIN WEST #7 BELT LINE               ComFail -0.98  PPM
08/06 02:51:34 122   FIRE SUPPRESSION #5 BELT MAIN W.  OFF         ComFail
08/06 02:51:34 124   POWER #5 BELT MAIN WEST           ON          ComFail
08/06 02:51:34 125   RUN #5 BELT MAIN WEST             ON          ComFail
08/06 02:51:37 131   SLIP #6 BELT                      ON          ComFail
08/06 02:51:37 132   SEQUENCE #6 BELT                  ON          ComFail
08/06 02:51:37 133   REMOTE #6 BELT                    ON          ComFail
08/06 02:51:37 134   FIRE SUPPRESSION #6 BELT          NORMAL      ComFail
08/06 02:51:37 135   RUN #6 BELT                       ON          ComFail
08/06 02:51:39 137   SLIP #7 BELT MAIN WEST            ON          ComFail
08/06 02:51:39 138   SEQUENCE #7 BELT MAIN WEST        ON          ComFail
08/06 02:51:39 139   REMOTE #7 BELT MAIN WEST          ON          ComFail
08/06 02:51:39 140   FIRE SUPPRESSION #7 BELT MAIN W   NORMAL      ComFail
08/06 02:51:39 141   RUN #7 BELT MAIN WEST             ON          ComFail
08/06 02:51:39 142   TAKE-UP #7 BELT MAIN WEST         ON          ComFail
08/06 02:51:50 121   CO MAIN WEST XC103 #4BELT TAIL                ComFail -0.98  PPM
08/06 02:51:51 154   CO 6 BELT TAILPIECE MAIN WEST                 ComFail -0.98  PPM
08/06 02:51:51 155   CO XC111 7 BELT DRIVE MAIN W                  ComFail -0.98  PPM
08/06 02:51:55 151   CO XC113 5 BELT TAILPIECE MAIN W              ComFail -0.98  PPM
08/06 02:52:23 488   FAN MAIN WATER GAUGE              FANS OFF    Alarm   4.22   PSI
08/06 02:52:20   Pt Control: [Sequence] 393    Mode1
08/06 02:52:20   Pt Control: [Sequence] 394    Mode1
08/06 02:52:20   Pt Control: [Sequence] 395    Mode2
08/06 02:52:20   Pt Control: [Sequence] 396    Mode1
08/06 02:52:20   Pt Control: [Sequence] 399    Mode1
08/06 02:52:20   Pt Control: [Sequence] 480    Mode1
08/06 02:52:20   Pt Control: [Sequence] 481    Mode1
08/06 02:52:21 395   ALARM STROBE SHOP INSIDE BATH RM ON           Alarm
08/06 02:52:21 396   ALARM HORN SHOP INSIDE BATH ROOM ON           Alarm
08/06 02:52:21 394   ALARM CO OUTSIDE SAFETY OFFICE   ON           Alarm
08/06 02:52:21 393   ALARM CH4 & FIRE OUTSIDE SAFETY  ON           Alarm
08/06 02:52:22 399   ALARM BOX SHOP AREA              ON           Alarm
08/06 02:52:22 480   FAN ALARM BATHHOUSE STROBE       ON           Alarm
08/06 02:52:22 481   FAN ALARM BATHHOUSE HORN         ON           Alarm
08/06 02:52:34   Pt Control: [Sequence] 393    Mode2
08/06 02:52:35   Pt Control: [Sequence] 394    Mode2
08/06 02:52:36 394   ALARM CO OUTSIDE SAFETY OFFICE   OFF
08/06 02:52:36 393   ALARM CH4 & FIRE OUTSIDE SAFETY  OFF
08/06 02:52:36   Pt Control: [Sequence] 395    Mode1
```