

U.S. Department of Labor  
Mine Safety and Health Administration  
Educational Field and Small Mine Services



Location \_\_\_\_\_ Date \_\_\_\_\_

Competent Person \_\_\_\_\_ Duration \_\_\_\_\_ Time \_\_\_\_\_

## FIREFIGHTING EQUIPMENT

### 1) [56.4200](#) General requirements.

(a) For fighting fires that could endanger persons, each mine shall have

- (1) Onsite firefighting equipment for fighting fires in their early stages; and
- (2) Onsite firefighting equipment for fighting fires beyond their early stages, or the mine shall have made prior arrangements with a local fire department to fight such fires.

(b) This onsite firefighting equipment shall be

- (1) Of the type, size, and quantity that can extinguish fires of any class which could occur as a result of the hazards present; and
- (2) Strategically located, readily accessible, plainly marked, and maintained in fire-ready condition.

### 2) [56.4201](#) Inspection

(a) Firefighting equipment shall be inspected according to the following schedules:

- (1) Fire extinguishers shall be inspected visually at least once a month to determine that they are fully charged and operable.
- (2) At least once every twelve months, maintenance checks shall be made of mechanical parts, the amount and condition of extinguishing agent and expellant, and the condition of the hose, nozzle, and vessel to determine that the fire extinguishers will operate effectively.

### 3) [56.4203](#) Extinguisher recharging or replacement.

Fire extinguishers shall be recharged or replaced with a fully charged extinguisher promptly after any discharge.

### 4) [56.4230](#) Self-propelled equipment.

(a)(1) Whenever a fire or its effects could impede escape from self-propelled equipment, a fire extinguisher shall be on the equipment.

(2) Whenever a fire or its effects would not impede escape from the equipment but could affect the escape of other persons in the area, a fire extinguisher shall be on the equipment or within 100 feet of the equipment.

(b) A fire suppression system may be used as an alternative to fire extinguishers if the system can be manually activated.

(c) Fire extinguishers or fire suppression systems shall be of a type and size that can extinguish fires of any class in their early stages which could originate from the equipment's inherent fire hazards. Fire extinguishers or manual actuators for the suppression system shall be located to permit their use by persons whose escape could be impeded by fire.

• Fatal grams: [56.4201](#),

• Attendees: